



Watkins ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009390	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 105	WF-04072025-009390	1/28/2026	FT-FY26-01122026-009390-A	<2	FT-FY26-01122026-009390-B	<2
WS- 009392	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 110	WF-04072025-009392	1/28/2026	FT-FY26-01122026-009392-A	<2	FT-FY26-01122026-009392-B	<2
WS- 009394	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 115	WF-04072025-009394	1/28/2026	FT-FY26-01122026-009394-A	<2	FT-FY26-01122026-009394-B	<2
WS- 009473	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 120	WF-04072025-009473	1/28/2026	FT-FY26-01122026-009473-A	<2	FT-FY26-01122026-009473-B	<2
WS- 009475	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 125	WF-04072025-009475	1/28/2026	FT-FY26-01122026-009475-A	<2	FT-FY26-01122026-009475-B	<2
WS- 009477	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 130	WF-04072025-009477	1/28/2026	FT-FY26-01122026-009477-A	<2	FT-FY26-01122026-009477-B	<2
WS- 009479	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 140	WF-04072025-009479	1/28/2026	FT-FY26-01122026-009479-A	<2	FT-FY26-01122026-009479-B	<2
WS- 009481	4/7/2025	4/7/2026	1	Combo Fountain	In classroom 135	WF-04072025-009481	1/28/2026	FT-FY26-01122026-009481-A	<2	FT-FY26-01122026-009481-B	<2
WS- 009489	4/7/2025	4/7/2026	1	Break Room	In main office in workroom 151	WF-04072025-009489	1/28/2026	FT-FY26-01122026-009489-A	<2	FT-FY26-01122026-009489-B	<2
WS- 009491	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 425	WF-04072025-009491	1/28/2026	FT-FY26-01122026-009491-A	<2	FT-FY26-01122026-009491-B	<2
WS- 009495	4/7/2025	4/7/2026	3	Combo Fountain	In classroom 305	WF-04072025-009495	1/28/2026	FT-FY26-01122026-009495-A	<2	FT-FY26-01122026-009495-B	<2
WS- 009497	4/7/2025	4/7/2026	2	Combo Fountain	In classroom 215	WF-04072025-009497	1/28/2026	FT-FY26-01122026-009497-A	<2	FT-FY26-01122026-009497-B	<2
WS- 009499	4/7/2025	4/7/2026	2	Combo Fountain	In classroom 220	WF-04072025-009499	1/28/2026	FT-FY26-01122026-009499-A	<2	FT-FY26-01122026-009499-B	<2
WS- 009503	4/7/2025	4/7/2026	1	Cooler	In hallway across from gym room 190 High Left	WF-04072025-009503	1/28/2026	FT-FY26-01122026-009503-A	<2	FT-FY26-01122026-009503-B	<2
WS- 009506	4/7/2025	4/7/2026	1	Health Suite	In health suite room 121	WF-04072025-009506	1/28/2026	FT-FY26-01122026-009506-A	<2	FT-FY26-01122026-009506-B	<2
WS- 009507	4/7/2025	4/7/2026	1	Break Room	In staff workroom 104	WF-04072025-009507	1/28/2026	FT-FY26-01122026-009507-A	<2	FT-FY26-01122026-009507-B	<2
WS- 010100	4/7/2025	4/7/2026	4	Break Room	In staff workroom 404	WF-04072025-010100	1/28/2026	FT-FY26-01122026-010100-A	<2	FT-FY26-01122026-010100-B	<2
WS- 010102	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 405	WF-04072025-010102	1/28/2026	FT-FY26-01122026-010102-A	<2	FT-FY26-01122026-010102-B	<2
WS- 010104	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 410 Low Right	WF-04072025-010104	1/28/2026	FT-FY26-01122026-010104-A	<2	FT-FY26-01122026-010104-B	<2
WS- 010106	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 415	WF-04072025-010106	1/28/2026	FT-FY26-01122026-010106-A	<2	FT-FY26-01122026-010106-B	<2
WS- 010108	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 420	WF-04072025-010108	1/28/2026	FT-FY26-01122026-010108-A	<2	FT-FY26-01122026-010108-B	<2
WS- 010110	4/7/2025	4/7/2026	4	Combo Fountain	In classroom 435	WF-04072025-010110	1/28/2026	FT-FY26-01122026-010110-A	<2	FT-FY26-01122026-010110-B	<2
WS- 010113	4/7/2025	4/7/2026	3	Bottle Filler	In hallway across from elevator 3rd floor	WF-04072025-010113	1/28/2026	FT-FY26-01122026-010113-A	<2	FT-FY26-01122026-010113-B	<2
WS- 010114	4/7/2025	4/7/2026	3	Cooler	In hallway across from elevator 3rd floor High Left	WF-04072025-010114	1/28/2026	FT-FY26-01122026-010114-A	<2	FT-FY26-01122026-010114-B	<2
WS- 010116	4/7/2025	4/7/2026	3	Combo Fountain	In classroom 320	WF-04072025-010116	1/28/2026	FT-FY26-01122026-010116-A	<2	FT-FY26-01122026-010116-B	<2
WS- 010118	4/7/2025	4/7/2026	3	Combo Fountain	In classroom 315	WF-04072025-010118	1/28/2026	FT-FY26-01122026-010118-A	<2	FT-FY26-01122026-010118-B	<2
WS- 010119	4/7/2025	4/7/2026	3	Break Room	In staff lounge 311B	WF-04072025-010119	1/28/2026	FT-FY26-01122026-010119-A	<2	FT-FY26-01122026-010119-B	<2
WS- 010121	4/7/2025	4/7/2026	3	Combo Fountain	In classroom 310	WF-04072025-010121	1/28/2026	FT-FY26-01122026-010121-A	<2	FT-FY26-01122026-010121-B	<2
WS- 010122	4/7/2025	4/7/2026	3	Break Room	In staff workroom 304	WF-04072025-010122	1/28/2026	FT-FY26-01122026-010122-A	2.1	FT-FY26-01122026-010122-B	<2
WS- 010123	4/7/2025	4/7/2026	2	Break Room	In staff workroom 204	WF-04072025-010123	1/28/2026	FT-FY26-01122026-010123-A	<2	FT-FY26-01122026-010123-B	<2
WS- 010218	4/7/2025	4/7/2026	2	Combo Fountain	In classroom 205	WF-04072025-010218	1/28/2026	FT-FY26-01122026-010218-A	<2	FT-FY26-01122026-010218-B	<2
WS- 010220	4/7/2025	4/7/2026	2	Combo Fountain	In classroom 210	WF-04072025-010220	1/28/2026	FT-FY26-01122026-010220-A	<2	FT-FY26-01122026-010220-B	<2
WS- 010225	4/7/2025	4/7/2026	2	Bottle Filler	In hallway across from elevator 2nd floor	WF-04072025-010225	1/28/2026	FT-FY26-01122026-010225-A	<2	FT-FY26-01122026-010225-B	<2
WS- 010227	4/7/2025	4/7/2026	2	Cooler	In hallway across from elevator 2nd floor High Left	WF-04072025-010227	1/28/2026	FT-FY26-01122026-010227-A	<2	FT-FY26-01122026-010227-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009485	12/4/2025	12/4/2026	1	Food Prep Sink	In kitchen 1st clockwise from entry door	WF-12042025-009485	1/28/2026	FT-FY26-01122026-009485-A	<2	FT-FY26-01122026-009485-B	<2
WS- 009486	12/4/2025	12/4/2026	1	Food Prep Sink	In kitchen 2nd from entry door	WF-12042025-009486	1/28/2026	FT-FY26-01122026-009486-A	<2	FT-FY26-01122026-009486-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.