



Watkins Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009390	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 105	WF-04192023-009390	12/15/2023	FT-FY24-11272023-009390-A	<1	FT-FY24-11272023-009390-B	<1	
WS- 009392	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 110	WF-04192023-009392	12/15/2023	FT-FY24-11272023-009392-A	<1	FT-FY24-11272023-009392-B	<1	
WS- 009394	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 115	WF-04192023-009394	12/15/2023	FT-FY24-11272023-009394-A	<1	FT-FY24-11272023-009394-B	<1	
WS- 009473	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 120	WF-04192023-009473	12/15/2023	FT-FY24-11272023-009473-A	<1	FT-FY24-11272023-009473-B	<1	
WS- 009475	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 125	WF-04192023-009475	12/15/2023	FT-FY24-11272023-009475-A	<1	FT-FY24-11272023-009475-B	<1	
WS- 009477	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 130	WF-04192023-009477	12/15/2023	FT-FY24-11272023-009477-A	<1	FT-FY24-11272023-009477-B	<1	
WS- 009479	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 140	WF-04192023-009479	12/15/2023	FT-FY24-11272023-009479-A	<1	FT-FY24-11272023-009479-B	<1	
WS- 009481	4/19/2023	4/19/2024	1	Combo Fountain	In classroom 135	WF-04192023-009481	12/15/2023	FT-FY24-11272023-009481-A	<1	FT-FY24-11272023-009481-B	<1	
WS- 009484	4/19/2023	4/19/2024	1	Bottle Filler	In gym room 190	WF-04192023-009484	12/15/2023	FT-FY24-11272023-009484-A	<1	FT-FY24-11272023-009484-B	<1	
WS- 009489	4/19/2023	4/19/2024	1	Break Room	In main office in workroom 151	WF-04192023-009489	12/15/2023	FT-FY24-11272023-009489-A	<1	FT-FY24-11272023-009489-B	<1	
WS- 009491	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 425	WF-04192023-009491	12/15/2023	FT-FY24-11272023-009491-A	<1	FT-FY24-11272023-009491-B	<1	
WS- 009495	4/19/2023	4/19/2024	3	Combo Fountain	In classroom 305	WF-04192023-009495	12/15/2023	FT-FY24-11272023-009495-A	<1	FT-FY24-11272023-009495-B	<1	
WS- 009497	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 215	WF-04192023-009497	12/15/2023	FT-FY24-11272023-009497-A	<1	FT-FY24-11272023-009497-B	<1	
WS- 009499	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 220	WF-04192023-009499	12/15/2023	FT-FY24-11272023-009499-A	<1	FT-FY24-11272023-009499-B	<1	
WS- 009503	4/19/2023	4/19/2024	1	Cooler	In hallway across from gym room 190	High Left	WF-04192023-009503	12/15/2023	FT-FY24-11272023-009503-A	<1	FT-FY24-11272023-009503-B	<1
WS- 009506	4/19/2023	4/19/2024	1	Health Suite	In health suite room 121	WF-04192023-009506	12/15/2023	FT-FY24-11272023-009506-A	<1	FT-FY24-11272023-009506-B	<1	
WS- 009507	4/19/2023	4/19/2024	1	Break Room	In staff workroom 104	WF-04192023-009507	12/15/2023	FT-FY24-11272023-009507-A	<1	FT-FY24-11272023-009507-B	<1	
WS- 010100	4/19/2023	4/19/2024	4	Break Room	In staff workroom 404	WF-04192023-010100	12/15/2023	FT-FY24-11272023-010100-A	2.0	FT-FY24-11272023-010100-B	<1	
WS- 010102	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 405	WF-04192023-010102	12/15/2023	FT-FY24-11272023-010102-A	<1	FT-FY24-11272023-010102-B	<1	
WS- 010104	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 410	Low Right	WF-04192023-010104	12/15/2023	FT-FY24-11272023-010104-A	<1	FT-FY24-11272023-010104-B	<1
WS- 010106	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 415	WF-04192023-010106	12/15/2023	FT-FY24-11272023-010106-A	<1	FT-FY24-11272023-010106-B	<1	
WS- 010108	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 420	WF-04192023-010108	12/15/2023	FT-FY24-11272023-010108-A	<1	FT-FY24-11272023-010108-B	<1	
WS- 010110	4/19/2023	4/19/2024	4	Combo Fountain	In classroom 435	WF-04192023-010110	12/15/2023	FT-FY24-11272023-010110-A	<1	FT-FY24-11272023-010110-B	<1	
WS- 010112	4/19/2023	4/19/2024	4	Cooler	In hallway across from elevator 4th floor	High Left	WF-04192023-010112	12/15/2023	FT-FY24-11272023-010112-A	<1	FT-FY24-11272023-010112-B	<1
WS- 010113	4/19/2023	4/19/2024	3	Bottle Filler	In hallway across from elevator 3rd floor	WF-04192023-010113	12/15/2023	FT-FY24-11272023-010113-A	<1	FT-FY24-11272023-010113-B	<1	
WS- 010114	4/19/2023	4/19/2024	3	Cooler	In hallway across from elevator 3rd floor	High Left	WF-04192023-010114	12/15/2023	FT-FY24-11272023-010114-A	<1	FT-FY24-11272023-010114-B	<1
WS- 010116	4/19/2023	4/19/2024	3	Combo Fountain	In classroom 320	WF-04192023-010116	12/15/2023	FT-FY24-11272023-010116-A	<1	FT-FY24-11272023-010116-B	<1	
WS- 010118	4/19/2023	4/19/2024	3	Combo Fountain	In classroom 315	WF-04192023-010118	12/15/2023	FT-FY24-11272023-010118-A	<1	FT-FY24-11272023-010118-B	<1	
WS- 010119	4/19/2023	4/19/2024	3	Break Room	In staff lounge 311B	WF-04192023-010119	12/15/2023	FT-FY24-11272023-010119-A	<1	FT-FY24-11272023-010119-B	<1	
WS- 010121	4/19/2023	4/19/2024	3	Combo Fountain	In classroom 310	WF-04192023-010121	12/15/2023	FT-FY24-11272023-010121-A	<1	FT-FY24-11272023-010121-B	<1	
WS- 010122	4/19/2023	4/19/2024	3	Break Room	In staff workroom 304	WF-04192023-010122	12/15/2023	FT-FY24-11272023-010122-A	<1	FT-FY24-11272023-010122-B	<1	
WS- 010123	4/19/2023	4/19/2024	2	Break Room	In staff workroom 204	WF-04192023-010123	12/15/2023	FT-FY24-11272023-010123-A	<1	FT-FY24-11272023-010123-B	<1	
WS- 010218	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 205	WF-04192023-010218	12/15/2023	FT-FY24-11272023-010218-A	<1	FT-FY24-11272023-010218-B	<1	
WS- 010220	4/19/2023	4/19/2024	2	Combo Fountain	In classroom 210	WF-04192023-010220	12/15/2023	FT-FY24-11272023-010220-A	<1	FT-FY24-11272023-010220-B	<1	
WS- 010225	4/19/2023	4/19/2024	2	Bottle Filler	In hallway across from elevator 2nd floor	WF-04192023-010225	12/15/2023	FT-FY24-11272023-010225-A	<1	FT-FY24-11272023-010225-B	<1	
WS- 010227	4/19/2023	4/19/2024	2	Cooler	In hallway across from elevator 2nd floor	High Left	WF-04192023-010227	12/15/2023	FT-FY24-11272023-010227-A	<1	FT-FY24-11272023-010227-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009485	1/19/2023	1/19/2024	1	Food Prep Sink	In kitchen 1st clockwise from entry door	WF-01192023-009485	12/15/2023	FT-FY24-11272023-009485-A	<1	FT-FY24-11272023-009485-B	<1
WS- 009486	1/19/2023	1/19/2024	1	Food Prep Sink	In kitchen 2nd from entry door	WF-01192023-009486	12/15/2023	FT-FY24-11272023-009486-A	<1	FT-FY24-11272023-009486-B	<1