



Watkins ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009390	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 105	WF-06112019-009390	10/30/2019	FT-FY20-102019-009390-A	<1	FT-FY20-102019-009390-B	<1
WS- 009392	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 110	WF-06112019-009392	10/30/2019	FT-FY20-102019-009392-A	<1	FT-FY20-102019-009392-B	<1
WS- 009394	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 115	WF-06112019-009394	10/30/2019	FT-FY20-102019-009394-A	<1	FT-FY20-102019-009394-B	<1
WS- 009473	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 120	WF-06112019-009473	10/30/2019	FT-FY20-102019-009473-A	<1	FT-FY20-102019-009473-B	<1
WS- 009475	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 125	WF-06112019-009475	10/30/2019	FT-FY20-102019-009475-A	<1	FT-FY20-102019-009475-B	<1
WS- 009477	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 130	WF-06112019-009477	10/30/2019	FT-FY20-102019-009477-A	<1	FT-FY20-102019-009477-B	<1
WS- 009479	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 140	WF-06112019-009479	10/30/2019	FT-FY20-102019-009479-A	<1	FT-FY20-102019-009479-B	<1
WS- 009481	6/11/2019	6/11/2020	1	Combo Fountain	In classroom 135	WF-06112019-009481	10/30/2019	FT-FY20-102019-009481-A	<1	FT-FY20-102019-009481-B	<1
WS- 009482	6/11/2019	6/11/2020	1	Cooler	In multipurpose room 190 High Left	WF-06112019-009482	10/30/2019	FT-FY20-102019-009482-A	<1	FT-FY20-102019-009482-B	<1
WS- 009483	6/11/2019	6/11/2020	1	Cooler	In gym room 190	WF-06112019-009483	10/30/2019	FT-FY20-102019-009483-A	<1	FT-FY20-102019-009483-B	<1
WS- 009484	6/11/2019	6/11/2020	1	Bottle Filler	In gym room 190	WF-06112019-009484	10/30/2019	FT-FY20-102019-009484-A	<1	FT-FY20-102019-009484-B	<1
WS- 009489	6/11/2019	6/11/2020	1	Break Room	In main office in workroom 151	WF-06112019-009489	10/30/2019	FT-FY20-102019-009489-A	<1	FT-FY20-102019-009489-B	<1
WS- 009491	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 425	WF-06112019-009491	10/30/2019	FT-FY20-102019-009491-A	<1	FT-FY20-102019-009491-B	<1
WS- 009492	6/11/2019	6/11/2020	4	Cooler	In hallway across from elevator 4th floor Low Right	WF-06112019-009492	10/30/2019	FT-FY20-102019-009492-A	<1	FT-FY20-102019-009492-B	<1
WS- 009493	6/11/2019	6/11/2020	3	Cooler	In hallway across from elevator 3rd floor Low Right	WF-06112019-009493	10/30/2019	FT-FY20-102019-009493-A	<1	FT-FY20-102019-009493-B	<1
WS- 009495	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 305	WF-06112019-009495	10/30/2019	FT-FY20-102019-009495-A	<1	FT-FY20-102019-009495-B	<1
WS- 009497	6/11/2019	6/11/2020	2	Combo Fountain	In classroom 215	WF-06112019-009497	10/30/2019	FT-FY20-102019-009497-A	<1	FT-FY20-102019-009497-B	<1
WS- 009499	6/11/2019	6/11/2020	2	Combo Fountain	In classroom 220	WF-06112019-009499	10/30/2019	FT-FY20-102019-009499-A	<1	FT-FY20-102019-009499-B	<1
WS- 009503	6/11/2019	6/11/2020	1	Cooler	In hallway across from gym room 190 High Left	WF-06112019-009503	10/30/2019	FT-FY20-102019-009503-A	<1	FT-FY20-102019-009503-B	<1
WS- 009504	6/11/2019	6/11/2020	1	Cooler	In hallway across from gym room 190 Low Right	WF-06112019-009504	10/30/2019	FT-FY20-102019-009504-A	<1	FT-FY20-102019-009504-B	<1
WS- 009505	6/11/2019	6/11/2020	1	Bottle Filler	In hallway across from gym room 190	WF-06112019-009505	10/30/2019	FT-FY20-102019-009505-A	<1	FT-FY20-102019-009505-B	<1
WS- 009506	6/11/2019	6/11/2020	1	Health Suite	In health suite room 121	WF-06112019-009506	10/30/2019	FT-FY20-102019-009506-A	<1	FT-FY20-102019-009506-B	<1
WS- 009507	6/11/2019	6/11/2020	1	Break Room	In staff workroom 104	WF-06112019-009507	10/30/2019	FT-FY20-102019-009507-A	<1	FT-FY20-102019-009507-B	<1
WS- 010100	6/11/2019	6/11/2020	4	Break Room	In staff workroom 404	WF-06112019-010100	10/30/2019	FT-FY20-102019-010100-A	<1	FT-FY20-102019-010100-B	<1
WS- 010102	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 405	WF-06112019-010102	10/30/2019	FT-FY20-102019-010102-A	<1	FT-FY20-102019-010102-B	<1
WS- 010104	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 410 Low Right	WF-06112019-010104	10/30/2019	FT-FY20-102019-010104-A	<1	FT-FY20-102019-010104-B	<1
WS- 010106	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 415	WF-06112019-010106	10/30/2019	FT-FY20-102019-010106-A	<1	FT-FY20-102019-010106-B	<1
WS- 010108	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 420	WF-06112019-010108	10/30/2019	FT-FY20-102019-010108-A	<1	FT-FY20-102019-010108-B	<1
WS- 010110	6/11/2019	6/11/2020	4	Combo Fountain	In classroom 435	WF-06112019-010110	10/30/2019	FT-FY20-102019-010110-A	<1	FT-FY20-102019-010110-B	<1
WS- 010111	6/11/2019	6/11/2020	4	Bottle Filler	In hallway across from elevator 4th floor	WF-06112019-010111	10/30/2019	FT-FY20-102019-010111-A	<1	FT-FY20-102019-010111-B	<1
WS- 010112	6/11/2019	6/11/2020	4	Cooler	In hallway across from elevator 4th floor High Left	WF-06112019-010112	10/30/2019	FT-FY20-102019-010112-A	<1	FT-FY20-102019-010112-B	<1
WS- 010113	6/11/2019	6/11/2020	3	Bottle Filler	In hallway across from elevator 3rd floor	WF-06112019-010113	10/30/2019	FT-FY20-102019-010113-A	<1	FT-FY20-102019-010113-B	<1
WS- 010114	6/11/2019	6/11/2020	3	Cooler	In hallway across from elevator 3rd floor High Left	WF-06112019-010114	10/30/2019	FT-FY20-102019-010114-A	<1	FT-FY20-102019-010114-B	<1

WS- 010116	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 320	WF-06112019-010116	10/30/2019	FT-FY20-102019-010116-A	<1	FT-FY20-102019-010116-B	<1	
WS- 010118	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 315	WF-06112019-010118	10/30/2019	FT-FY20-102019-010118-A	<1	FT-FY20-102019-010118-B	<1	
WS- 010119	6/11/2019	6/11/2020	3	Break Room	In staff lounge 311B	WF-06112019-010119	10/30/2019	FT-FY20-102019-010119-A	<1	FT-FY20-102019-010119-B	<1	
WS- 010121	6/11/2019	6/11/2020	3	Combo Fountain	In classroom 310	WF-06112019-010121	10/30/2019	FT-FY20-102019-010121-A	<1	FT-FY20-102019-010121-B	<1	
WS- 010122	6/11/2019	6/11/2020	3	Break Room	In staff workroom 304	WF-06112019-010122	10/30/2019	FT-FY20-102019-010122-A	<1	FT-FY20-102019-010122-B	<1	
WS- 010123	6/11/2019	6/11/2020	2	Break Room	In staff workroom 204	WF-06112019-010123	10/30/2019	FT-FY20-102019-010123-A	<1	FT-FY20-102019-010123-B	<1	
WS- 010218	6/11/2019	6/11/2020	2	Combo Fountain	In classroom 205	WF-06112019-010218	10/30/2019	FT-FY20-102019-010218-A	<1	FT-FY20-102019-010218-B	<1	
WS- 010220	6/11/2019	6/11/2020	2	Combo Fountain	In classroom 210	WF-06112019-010220	10/30/2019	FT-FY20-102019-010220-A	<1	FT-FY20-102019-010220-B	<1	
WS- 010225	6/11/2019	6/11/2020	2	Bottle Filler	In hallway across from elevator 2nd floor	WF-06112019-010225	10/30/2019	FT-FY20-102019-010225-A	<1	FT-FY20-102019-010225-B	<1	
WS- 010226	6/11/2019	6/11/2020	2	Cooler	In hallway across from elevator 2nd floor	Low Right	WF-06112019-010226	10/30/2019	FT-FY20-102019-010226-A	<1	FT-FY20-102019-010226-B	<1
WS- 010227	6/11/2019	6/11/2020	2	Cooler	In hallway across from elevator 2nd floor	High Left	WF-06112019-010227	10/30/2019	FT-FY20-102019-010227-A	<1	FT-FY20-102019-010227-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009485	7/9/2019	7/9/2020	1	Food Prep Sink	In kitchen 1st clockwise from entry door	WF-07092019-009485	10/30/2019	FT-FY20-102019-009485-A	<1	FT-FY20-102019-009485-B	<1
WS- 009486	7/9/2019	7/9/2020	1	Food Prep Sink	In kitchen 2nd from entry door	WF-07092019-009486	10/30/2019	FT-FY20-102019-009486-A	<1	FT-FY20-102019-009486-B	<1