



Watkins Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009390	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 105	WF-06012020-009390	1/8/2021	FT-FY21-012021-009390-A	<1	FT-FY21-012021-009390-B	<1	
WS- 009392	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 110	WF-06012020-009392	1/8/2021	FT-FY21-012021-009392-A	<1	FT-FY21-012021-009392-B	<1	
WS- 009394	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 115	WF-06012020-009394	1/8/2021	FT-FY21-012021-009394-A	<1	FT-FY21-012021-009394-B	<1	
WS- 009473	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 120	WF-06012020-009473	1/8/2021	FT-FY21-012021-009473-A	<1	FT-FY21-012021-009473-B	<1	
WS- 009475	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 125	WF-06012020-009475	1/8/2021	FT-FY21-012021-009475-A	<1	FT-FY21-012021-009475-B	<1	
WS- 009477	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 130	WF-06012020-009477	1/8/2021	FT-FY21-012021-009477-A	<1	FT-FY21-012021-009477-B	<1	
WS- 009479	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 140	WF-06012020-009479	1/8/2021	FT-FY21-012021-009479-A	<1	FT-FY21-012021-009479-B	<1	
WS- 009481	6/1/2020	6/1/2021	1	Combo Fountain	In classroom 135	WF-06012020-009481	1/8/2021	FT-FY21-012021-009481-A	<1	FT-FY21-012021-009481-B	<1	
WS- 009489	6/1/2020	6/1/2021	1	Break Room	In main office in workroom 151	WF-06012020-009489	1/8/2021	FT-FY21-012021-009489-A	<1	FT-FY21-012021-009489-B	<1	
WS- 009491	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 425	WF-06012020-009491	1/8/2021	FT-FY21-012021-009491-A	<1	FT-FY21-012021-009491-B	<1	
WS- 009495	6/1/2020	6/1/2021	3	Combo Fountain	In classroom 305	WF-06012020-009495	1/8/2021	FT-FY21-012021-009495-A	<1	FT-FY21-012021-009495-B	<1	
WS- 009497	6/1/2020	6/1/2021	2	Combo Fountain	In classroom 215	WF-06012020-009497	1/8/2021	FT-FY21-012021-009497-A	<1	FT-FY21-012021-009497-B	<1	
WS- 009499	6/1/2020	6/1/2021	2	Combo Fountain	In classroom 220	WF-06012020-009499	1/8/2021	FT-FY21-012021-009499-A	<1	FT-FY21-012021-009499-B	<1	
WS- 009506	6/1/2020	6/1/2021	1	Health Suite	In health suite room 121	WF-06012020-009506	1/8/2021	FT-FY21-012021-009506-A	<1	FT-FY21-012021-009506-B	<1	
WS- 009507	6/1/2020	6/1/2021	1	Break Room	In staff workroom 104	WF-06012020-009507	1/8/2021	FT-FY21-012021-009507-A	<1	FT-FY21-012021-009507-B	<1	
WS- 010100	6/1/2020	6/1/2021	4	Break Room	In staff workroom 404	WF-06012020-010100	1/8/2021	FT-FY21-012021-010100-A	<1	FT-FY21-012021-010100-B	<1	
WS- 010102	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 405	WF-06012020-010102	1/8/2021	FT-FY21-012021-010102-A	2.2	FT-FY21-012021-010102-B	<1	
WS- 010104	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 410	Low Right	WF-06012020-010104	1/8/2021	FT-FY21-012021-010104-A	<1	FT-FY21-012021-010104-B	<1
WS- 010106	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 415	WF-06012020-010106	1/8/2021	FT-FY21-012021-010106-A	3.3	FT-FY21-012021-010106-B	<1	
WS- 010108	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 420	WF-06012020-010108	1/8/2021	FT-FY21-012021-010108-A	<1	FT-FY21-012021-010108-B	<1	
WS- 010110	6/1/2020	6/1/2021	4	Combo Fountain	In classroom 435	WF-06012020-010110	1/8/2021	FT-FY21-012021-010110-A	<1	FT-FY21-012021-010110-B	<1	
WS- 010111	6/1/2020	6/1/2021	4	Bottle Filler	In hallway across from elevator 4th floor	WF-06012020-010111	1/8/2021	FT-FY21-012021-010111-A	<1	FT-FY21-012021-010111-B	<1	
WS- 010112	6/1/2020	6/1/2021	4	Cooler	In hallway across from elevator 4th floor	High Left	WF-06012020-010112	1/8/2021	FT-FY21-012021-010112-A	<1	FT-FY21-012021-010112-B	<1
WS- 010113	6/1/2020	6/1/2021	3	Bottle Filler	In hallway across from elevator 3rd floor	WF-06012020-010113	1/8/2021	FT-FY21-012021-010113-A	<1	FT-FY21-012021-010113-B	<1	
WS- 010114	6/1/2020	6/1/2021	3	Cooler	In hallway across from elevator 3rd floor	High Left	WF-06012020-010114	1/8/2021	FT-FY21-012021-010114-A	<1	FT-FY21-012021-010114-B	<1
WS- 010116	6/1/2020	6/1/2021	3	Combo Fountain	In classroom 320	WF-06012020-010116	1/8/2021	FT-FY21-012021-010116-A	2.3	FT-FY21-012021-010116-B	<1	
WS- 010118	6/1/2020	6/1/2021	3	Combo Fountain	In classroom 315	WF-06012020-010118	1/8/2021	FT-FY21-012021-010118-A	<1	FT-FY21-012021-010118-B	<1	
WS- 010119	6/1/2020	6/1/2021	3	Break Room	In staff lounge 311B	WF-06012020-010119	1/8/2021	FT-FY21-012021-010119-A	<1	FT-FY21-012021-010119-B	<1	
WS- 010121	6/1/2020	6/1/2021	3	Combo Fountain	In classroom 310	WF-06012020-010121	1/8/2021	FT-FY21-012021-010121-A	<1	FT-FY21-012021-010121-B	<1	
WS- 010122	6/1/2020	6/1/2021	3	Break Room	In staff workroom 304	WF-06012020-010122	1/8/2021	FT-FY21-012021-010122-A	<1	FT-FY21-012021-010122-B	<1	
WS- 010123	6/1/2020	6/1/2021	2	Break Room	In staff workroom 204	WF-06012020-010123	1/8/2021	FT-FY21-012021-010123-A	<1	FT-FY21-012021-010123-B	<1	
WS- 010218	6/1/2020	6/1/2021	2	Combo Fountain	In classroom 205	WF-06012020-010218	1/8/2021	FT-FY21-012021-010218-A	<1	FT-FY21-012021-010218-B	<1	
WS- 010220	6/1/2020	6/1/2021	2	Combo Fountain	In classroom 210	WF-06012020-010220	1/8/2021	FT-FY21-012021-010220-A	<1	FT-FY21-012021-010220-B	<1	

WS- 010225	6/1/2020	6/1/2021	2	Bottle Filler	In hallway across from elevator 2nd floor	WF-06012020-010225	1/8/2021	FT-FY21-012021-010225-A	<1	FT-FY21-012021-010225-B	<1
WS- 010227	6/1/2020	6/1/2021	2	Cooler	In hallway across from elevator 2nd floor High Left	WF-06012020-010227	1/8/2021	FT-FY21-012021-010227-A	<1	FT-FY21-012021-010227-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009486	2/18/2020	2/18/2021	1	Food Prep Sink	In kitchen 2nd from entry door	WF-02182020-009486	1/8/2021	FT-FY21-012021-009486-A	1.9	FT-FY21-012021-009486-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009485	2/18/2020	2/18/2021	1	Food Prep Sink	In kitchen 1st clockwise from entry door	WF-02182020-009485	1/8/2021	FT-FY21-012021-009485-A	5.1	FT-FY21-012021-009485-B	<1

First Re-test (After Plumbing Check)

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009485	1/11/2021	1/11/2022	1	Food Prep Sink	In kitchen 2nd from entry door	WF-01112021-009485	1/23/2021	FT-FY21-012021-009485-A	<1	FT-FY21-012021-009485-B	<1