



# WATKINS LEAD WATER TEST RESULTS

May 24th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010228	Utility	1	in incinerator room	WT-042916-10245- A	1	WT-042916-10245- B	1			
2	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010229	Kitchen	1	in kitchen Left	WT-042916-10246- A	1	WT-042916-10246- B	< 1			
3	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010230	Kitchen	1	in kitchen Right	WT-042916-10247- A	< 1	WT-042916-10247- B	< 1			
4	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010231	Cooler	1	in hallway adjacent to kitchen	WT-042916-10248- A	< 1	WT-042916-10248- B	< 1			
5	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010232	Cooler	1	in hallway adjacent to custodian room	WT-042916-10249- A	< 1	WT-042916-10249- B	< 1			
6	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010233	Cooler	1	in hallway adjacent to teachers restroom	WT-042916-10250- A	< 1	WT-042916-10250- B	< 1			
7	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010234	Cooler	1	in hallway adjacent to room 111	WT-042916-10251- A	< 1	WT-042916-10251- B	< 1			
8	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010235	Classroom	1	in classroom 112	WT-042916-10252- A	2	WT-042916-10252- B	< 1			
9	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010236	Classroom	1	in classroom 113	WT-042916-10253- A	< 1	WT-042916-10253- B	< 1			
10	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010237	Cooler	2	in hallway adjacent to room 207	WT-042916-10254- A	< 1	WT-042916-10254- B	< 1			
11	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010238	Classroom	2	in library	WT-042916-10255- A	4	WT-042916-10255- B	10			
12	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010239	Cooler	2	in hallway adjacent to custodian room	WT-042916-10256- A	< 1	WT-042916-10256- B	< 1			
13	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010240	Classroom	2	in teachers lounge 214	WT-042916-10257- A	< 1	WT-042916-10257- B	< 1			
14	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010241	Cooler	2	in hallway across from south stair	WT-042916-10258- A	< 1	WT-042916-10258- B	< 1			
15	WATKINS ELEMENTARY SCHOOL	5/5/2016	WS- 010242	Cooler	3	in hallway across from south stair	WT-042916-10259- A	< 1	WT-042916-10259- B	< 1			
16	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010243	Cooler	3	in hallway adjacent to restrooms	WT-042916-10260- A	< 1	WT-042916-10260- B	< 1			
17	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010244	Classroom	3	in art room	WT-042916-10261- A	2	WT-042916-10261- B	< 1			
18	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010245	Cooler	3	in hallway adjacent 307	WT-042916-10262- A	< 1	WT-042916-10262- B	< 1			
19	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010246	Classroom	3	in science room 307	WT-042916-10263- A	2	WT-042916-10263- B	5			
20	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010247	Cooler	4	in hallway adjacent to tech room 407	WT-042916-10264- A	< 1	WT-042916-10264- B	< 1			
21	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010248	Classroom	4	in classroom 407	WT-042916-10265- A	3	WT-042916-10265- B	2			
22	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010249	Classroom	3	in science room north	WT-042916-10266- A	43	WT-042916-10266- B	1	Filter will be installed and then retested		
23	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010250	Classroom	3	in science room southeast	WT-042916-10267- A	38	WT-042916-10267- B	< 1	Filter will be installed and then retested		
24	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010251	Classroom	3	in science room west	WT-042916-10268- A	47	WT-042916-10268- B	1	Filter will be installed and then retested		
25	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010252	Cooler	4	in hallway adjacent to restrooms	WT-042916-10269- A	< 1	WT-042916-10269- B	< 1			
26	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010253	Cooler	4	in hallway across from south stair	WT-042916-10270- A	< 1	WT-042916-10270- B	< 1			
27	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010254	Classroom	4	in food lab Left	WT-042916-10271- A	< 1	WT-042916-10271- B	< 1			
28	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010255	Classroom	4	in food lab Mid	WT-042916-10272- A	< 1	WT-042916-10272- B	< 1			
29	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010256	Classroom	4	in food lab ice maker	WT-042916-10273- A	< 1	WT-042916-10273- B	< 1			
30	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010257	Classroom	4	in food lab (shower head) Right	WT-042916-10274- A	< 1	WT-042916-10274- B	< 1			
31	WATKINS ELEMENTARY SCHOOL	5/12/2016	WS- 010408	Classroom	1	in health suite	WT-042916-10425- A	3	WT-042916-10425- B	< 1			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.