



Watkins ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|-------|----------------|---|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 009390 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 105 | WF-06192018-009390 | 10/30/2018 | FT-FY19-102018-009390-A | < 1 | FT-FY19-102018-009390-B | < 1 |
| WS- 009392 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 110 | WF-06192018-009392 | 10/30/2018 | FT-FY19-102018-009392-A | < 1 | FT-FY19-102018-009392-B | < 1 |
| WS- 009394 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 115 | WF-06192018-009394 | 10/30/2018 | FT-FY19-102018-009394-A | < 1 | FT-FY19-102018-009394-B | < 1 |
| WS- 009473 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 120 | WF-06192018-009473 | 10/30/2018 | FT-FY19-102018-009473-A | < 1 | FT-FY19-102018-009473-B | < 1 |
| WS- 009475 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 125 | WF-06192018-009475 | 10/30/2018 | FT-FY19-102018-009475-A | < 1 | FT-FY19-102018-009475-B | < 1 |
| WS- 009477 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 130 | WF-06192018-009477 | 10/30/2018 | FT-FY19-102018-009477-A | < 1 | FT-FY19-102018-009477-B | < 1 |
| WS- 009479 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 140 | WF-06192018-009479 | 10/30/2018 | FT-FY19-102018-009479-A | < 1 | FT-FY19-102018-009479-B | < 1 |
| WS- 009481 | 6/19/2018 | 6/19/2019 | 1 | Combo Fountain | In classroom 135 | WF-06192018-009481 | 10/30/2018 | FT-FY19-102018-009481-A | < 1 | FT-FY19-102018-009481-B | < 1 |
| WS- 009482 | 6/19/2018 | 6/19/2019 | 1 | Cooler | In multipurpose room 190 High Left | WF-06192018-009482 | 10/30/2018 | FT-FY19-102018-009482-A | < 1 | FT-FY19-102018-009482-B | < 1 |
| WS- 009483 | 6/19/2018 | 6/19/2019 | 1 | Cooler | In gym room 190 | WF-06192018-009483 | 10/30/2018 | FT-FY19-102018-009483-A | < 1 | FT-FY19-102018-009483-B | < 1 |
| WS- 009484 | 6/19/2018 | 6/19/2019 | 1 | Bottle Filler | In gym room 190 | WF-06192018-009484 | 10/30/2018 | FT-FY19-102018-009484-A | < 1 | FT-FY19-102018-009484-B | < 1 |
| WS- 009489 | 6/19/2018 | 6/19/2019 | 1 | Break Room | In main office in workroom 151 | WF-06192018-009489 | 10/30/2018 | FT-FY19-102018-009489-A | < 1 | FT-FY19-102018-009489-B | < 1 |
| WS- 009491 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 425 | WF-06192018-009491 | 10/30/2018 | FT-FY19-102018-009491-A | < 1 | FT-FY19-102018-009491-B | < 1 |
| WS- 009492 | 6/19/2018 | 6/19/2019 | 4 | Cooler | In hallway across from elevator 4th floor Low Right | WF-06192018-009492 | 10/30/2018 | FT-FY19-102018-009492-A | < 1 | FT-FY19-102018-009492-B | < 1 |
| WS- 009493 | 6/19/2018 | 6/19/2019 | 3 | Cooler | In hallway across from elevator 3rd floor Low Right | WF-06192018-009493 | 10/30/2018 | FT-FY19-102018-009493-A | < 1 | FT-FY19-102018-009493-B | < 1 |
| WS- 009495 | 6/19/2018 | 6/19/2019 | 3 | Combo Fountain | In classroom 305 | WF-06192018-009495 | 10/30/2018 | FT-FY19-102018-009495-A | < 1 | FT-FY19-102018-009495-B | < 1 |
| WS- 009497 | 6/19/2018 | 6/19/2019 | 2 | Combo Fountain | In classroom 215 | WF-06192018-009497 | 10/30/2018 | FT-FY19-102018-009497-A | < 1 | FT-FY19-102018-009497-B | < 1 |
| WS- 009499 | 6/19/2018 | 6/19/2019 | 2 | Combo Fountain | In classroom 220 | WF-06192018-009499 | 10/30/2018 | FT-FY19-102018-009499-A | < 1 | FT-FY19-102018-009499-B | < 1 |
| WS- 009503 | 6/19/2018 | 6/19/2019 | 1 | Cooler | In hallway across from gym room 190 High Left | WF-06192018-009503 | 10/30/2018 | FT-FY19-102018-009503-A | < 1 | FT-FY19-102018-009503-B | < 1 |
| WS- 009504 | 6/19/2018 | 6/19/2019 | 1 | Cooler | In hallway across from gym room 190 Low Right | WF-06192018-009504 | 10/30/2018 | FT-FY19-102018-009504-A | < 1 | FT-FY19-102018-009504-B | < 1 |
| WS- 009505 | 6/19/2018 | 6/19/2019 | 1 | Bottle Filler | In hallway across from gym room 190 | WF-06192018-009505 | 10/30/2018 | FT-FY19-102018-009505-A | < 1 | FT-FY19-102018-009505-B | < 1 |
| WS- 009506 | 6/19/2018 | 6/19/2019 | 1 | Health Suite | In health suite room 121 | WF-06192018-009506 | 10/30/2018 | FT-FY19-102018-009506-A | < 1 | FT-FY19-102018-009506-B | < 1 |
| WS- 009507 | 6/19/2018 | 6/19/2019 | 1 | Break Room | In staff workroom 104 | WF-06192018-009507 | 10/30/2018 | FT-FY19-102018-009507-A | < 1 | FT-FY19-102018-009507-B | < 1 |
| WS- 010100 | 6/19/2018 | 6/19/2019 | 4 | Break Room | In staff workroom 404 | WF-06192018-010100 | 10/30/2018 | FT-FY19-102018-010100-A | < 1 | FT-FY19-102018-010100-B | < 1 |
| WS- 010102 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 405 | WF-06192018-010102 | 10/30/2018 | FT-FY19-102018-010102-A | < 1 | FT-FY19-102018-010102-B | < 1 |
| WS- 010104 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 410 Low Right | WF-06192018-010104 | 10/30/2018 | FT-FY19-102018-010104-A | < 1 | FT-FY19-102018-010104-B | < 1 |
| WS- 010106 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 415 | WF-06192018-010106 | 10/30/2018 | FT-FY19-102018-010106-A | < 1 | FT-FY19-102018-010106-B | < 1 |
| WS- 010108 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 420 | WF-06192018-010108 | 10/30/2018 | FT-FY19-102018-010108-A | < 1 | FT-FY19-102018-010108-B | < 1 |
| WS- 010110 | 6/19/2018 | 6/19/2019 | 4 | Combo Fountain | In classroom 435 | WF-06192018-010110 | 10/30/2018 | FT-FY19-102018-010110-A | < 1 | FT-FY19-102018-010110-B | < 1 |
| WS- 010111 | 6/19/2018 | 6/19/2019 | 4 | Bottle Filler | In hallway across from elevator 4th floor | WF-06192018-010111 | 10/30/2018 | FT-FY19-102018-010111-A | < 1 | FT-FY19-102018-010111-B | < 1 |
| WS- 010112 | 6/19/2018 | 6/19/2019 | 4 | Cooler | In hallway across from elevator 4th floor High Left | WF-06192018-010112 | 10/30/2018 | FT-FY19-102018-010112-A | < 1 | FT-FY19-102018-010112-B | < 1 |
| WS- 010113 | 6/19/2018 | 6/19/2019 | 3 | Bottle Filler | In hallway across from elevator 3rd floor | WF-06192018-010113 | 10/30/2018 | FT-FY19-102018-010113-A | < 1 | FT-FY19-102018-010113-B | < 1 |
| WS- 010114 | 6/19/2018 | 6/19/2019 | 3 | Cooler | In hallway across from elevator 3rd floor High Left | WF-06192018-010114 | 10/30/2018 | FT-FY19-102018-010114-A | < 1 | FT-FY19-102018-010114-B | < 1 |

| | | | | | | | | | | | | |
|------------|-----------|-----------|---|----------------|---|--------------------|--------------------|-------------------------|-------------------------|-------------------------|-------------------------|-----|
| WS- 010116 | 6/19/2018 | 6/19/2019 | 3 | Combo Fountain | In classroom 320 | WF-06192018-010116 | 10/30/2018 | FT-FY19-102018-010116-A | < 1 | FT-FY19-102018-010116-B | < 1 | |
| WS- 010118 | 6/19/2018 | 6/19/2019 | 3 | Combo Fountain | In classroom 315 | WF-06192018-010118 | 10/30/2018 | FT-FY19-102018-010118-A | < 1 | FT-FY19-102018-010118-B | < 1 | |
| WS- 010119 | 6/19/2018 | 6/19/2019 | 3 | Break Room | In staff lounge 311B | WF-06192018-010119 | 10/30/2018 | FT-FY19-102018-010119-A | < 1 | FT-FY19-102018-010119-B | < 1 | |
| WS- 010121 | 6/19/2018 | 6/19/2019 | 3 | Combo Fountain | In classroom 310 | WF-06192018-010121 | 10/30/2018 | FT-FY19-102018-010121-A | < 1 | FT-FY19-102018-010121-B | < 1 | |
| WS- 010122 | 6/19/2018 | 6/19/2019 | 3 | Break Room | In staff workroom 304 | WF-06192018-010122 | 10/30/2018 | FT-FY19-102018-010122-A | < 1 | FT-FY19-102018-010122-B | < 1 | |
| WS- 010123 | 6/19/2018 | 6/19/2019 | 2 | Break Room | In staff workroom 204 | WF-06192018-010123 | 10/30/2018 | FT-FY19-102018-010123-A | < 1 | FT-FY19-102018-010123-B | < 1 | |
| WS- 010218 | 6/19/2018 | 6/19/2019 | 2 | Combo Fountain | In classroom 205 | WF-06192018-010218 | 10/30/2018 | FT-FY19-102018-010218-A | < 1 | FT-FY19-102018-010218-B | < 1 | |
| WS- 010220 | 6/19/2018 | 6/19/2019 | 2 | Combo Fountain | In classroom 210 | WF-06192018-010220 | 10/30/2018 | FT-FY19-102018-010220-A | < 1 | FT-FY19-102018-010220-B | < 1 | |
| WS- 010225 | 6/19/2018 | 6/19/2019 | 2 | Bottle Filler | In hallway across from elevator 2nd floor | WF-06192018-010225 | 10/30/2018 | FT-FY19-102018-010225-A | < 1 | FT-FY19-102018-010225-B | < 1 | |
| WS- 010226 | 6/19/2018 | 6/19/2019 | 2 | Cooler | In hallway across from elevator 2nd floor | Low Right | WF-06192018-010226 | 10/30/2018 | FT-FY19-102018-010226-A | < 1 | FT-FY19-102018-010226-B | < 1 |
| WS- 010227 | 6/19/2018 | 6/19/2019 | 2 | Cooler | In hallway across from elevator 2nd floor | High Left | WF-06192018-010227 | 10/30/2018 | FT-FY19-102018-010227-A | < 1 | FT-FY19-102018-010227-B | < 1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | |
|---|-------|----------------|--|--|--|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Floor | Device Type | Device Location | | | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 009485 | 1 | Food Prep Sink | In kitchen 1st clockwise from entry door | | | 10/30/2018 | FT-FY19-102018-009485-A | < 1 | FT-FY19-102018-009485-B | < 1 |