



West Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000436	8/2/2021	8/2/2022	1	Combo Fountain	In resource room 110P	WF-08022021-000436	8/18/2021	FT-FY21-082021-000436-A	<1	FT-FY21-082021-000436-B	<1	
WS- 000438	8/2/2021	8/2/2022	1	Health Suite	In health suite treatment room 133	WF-08022021-000438	8/18/2021	FT-FY21-082021-000438-A	<1	FT-FY21-082021-000438-B	<1	
WS- 000439	8/2/2021	8/2/2022	1	Combo Fountain	In health suite treatment room 133	WF-08022021-000439	8/18/2021	FT-FY21-082021-000439-A	<1	FT-FY21-082021-000439-B	<1	
WS- 000441	8/2/2021	8/2/2022	1	Combo Fountain	In reading room 120	WF-08022021-000441	8/18/2021	FT-FY21-082021-000441-A	<1	FT-FY21-082021-000441-B	<1	
WS- 000443	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 150	WF-08022021-000443	8/18/2021	FT-FY21-082021-000443-A	<1	FT-FY21-082021-000443-B	<1	
WS- 000444	8/2/2021	8/2/2022	1	Bathroom	In classroom 150 (bathroom)	WF-08022021-000444	8/18/2021	FT-FY21-082021-000444-A	<1	FT-FY21-082021-000444-B	<1	
WS- 000446	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 151	WF-08022021-000446	8/18/2021	FT-FY21-082021-000446-A	<1	FT-FY21-082021-000446-B	<1	
WS- 000447	8/2/2021	8/2/2022	1	Bathroom	In classroom 151 (bathroom)	WF-08022021-000447	8/18/2021	FT-FY21-082021-000447-A	2.3	FT-FY21-082021-000447-B	<1	
WS- 000449	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 154	WF-08022021-000449	8/18/2021	FT-FY21-082021-000449-A	<1	FT-FY21-082021-000449-B	<1	
WS- 000450	8/2/2021	8/2/2022	1	Bathroom	In classroom 154 (bathroom)	WF-08022021-000450	8/18/2021	FT-FY21-082021-000450-A	<1	FT-FY21-082021-000450-B	<1	
WS- 000452	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 155	WF-08022021-000452	8/18/2021	FT-FY21-082021-000452-A	<1	FT-FY21-082021-000452-B	<1	
WS- 000453	8/2/2021	8/2/2022	1	Bathroom	In classroom 155 (bathroom)	WF-08022021-000453	8/18/2021	FT-FY21-082021-000453-A	1.1	FT-FY21-082021-000453-B	<1	
WS- 000455	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 160	WF-08022021-000455	8/18/2021	FT-FY21-082021-000455-A	<1	FT-FY21-082021-000455-B	<1	
WS- 000456	8/2/2021	8/2/2022	1	Bathroom	In classroom 160 (bathroom)	WF-08022021-000456	8/18/2021	FT-FY21-082021-000456-A	<1	FT-FY21-082021-000456-B	<1	
WS- 000458	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 161	WF-08022021-000458	8/18/2021	FT-FY21-082021-000458-A	<1	FT-FY21-082021-000458-B	<1	
WS- 000459	8/2/2021	8/2/2022	1	Bathroom	In classroom 161 (bathroom)	WF-08022021-000459	8/18/2021	FT-FY21-082021-000459-A	3.7	FT-FY21-082021-000459-B	<1	
WS- 000467	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 164	WF-08022021-000467	8/18/2021	FT-FY21-082021-000467-A	<1	FT-FY21-082021-000467-B	<1	
WS- 000468	8/2/2021	8/2/2022	1	Bathroom	In classroom 164 (bathroom)	WF-08022021-000468	8/18/2021	FT-FY21-082021-000468-A	<1	FT-FY21-082021-000468-B	<1	
WS- 000473	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 165	WF-08022021-000473	8/18/2021	FT-FY21-082021-000473-A	<1	FT-FY21-082021-000473-B	<1	
WS- 000474	8/2/2021	8/2/2022	1	Bathroom	In classroom 165 (bathroom)	WF-08022021-000474	8/18/2021	FT-FY21-082021-000474-A	<1	FT-FY21-082021-000474-B	<1	
WS- 000475	8/2/2021	8/2/2022	1	Bottle Filler	In hallway across from room 144	WF-08022021-000475	8/18/2021	FT-FY21-082021-000475-A	<1	FT-FY21-082021-000475-B	<1	
WS- 000476	8/2/2021	8/2/2022	1	Cooler	In hallway across from room 144	High Left	WF-08022021-000476	8/18/2021	FT-FY21-082021-000476-A	<1	FT-FY21-082021-000476-B	<1
WS- 000477	8/2/2021	8/2/2022	1	Cooler	In hallway across from room 144	Low Right	WF-08022021-000477	8/18/2021	FT-FY21-082021-000477-A	<1	FT-FY21-082021-000477-B	<1
WS- 000478	8/2/2021	8/2/2022	1	Break Room	In teacher collaboration room 144	WF-08022021-000478	8/18/2021	FT-FY21-082021-000478-A	<1	FT-FY21-082021-000478-B	<1	
WS- 000479	8/2/2021	8/2/2022	1	Combo Fountain	In teacher collaboration room 144	WF-08022021-000479	8/18/2021	FT-FY21-082021-000479-A	<1	FT-FY21-082021-000479-B	<1	
WS- 000481	8/2/2021	8/2/2022	1	Combo Fountain	In OT/PT room 170	WF-08022021-000481	8/18/2021	FT-FY21-082021-000481-A	<1	FT-FY21-082021-000481-B	<1	
WS- 000483	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 171	WF-08022021-000483	8/18/2021	FT-FY21-082021-000483-A	<1	FT-FY21-082021-000483-B	<1	
WS- 000485	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 174	WF-08022021-000485	8/18/2021	FT-FY21-082021-000485-A	<1	FT-FY21-082021-000485-B	<1	
WS- 000487	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 175	WF-08022021-000487	8/18/2021	FT-FY21-082021-000487-A	<1	FT-FY21-082021-000487-B	<1	
WS- 000566	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 180	WF-08022021-000566	8/18/2021	FT-FY21-082021-000566-A	<1	FT-FY21-082021-000566-B	<1	
WS- 000567	8/2/2021	8/2/2022	1	Bathroom	In classroom 180 (bathroom)	WF-08022021-000567	8/18/2021	FT-FY21-082021-000567-A	<1	FT-FY21-082021-000567-B	<1	
WS- 000569	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 181	WF-08022021-000569	8/18/2021	FT-FY21-082021-000569-A	<1	FT-FY21-082021-000569-B	<1	
WS- 000572	8/2/2021	8/2/2022	1	Bathroom	In classroom 181 (bathroom)	WF-08022021-000572	8/18/2021	FT-FY21-082021-000572-A	<1	FT-FY21-082021-000572-B	<1	
WS- 000574	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 184	WF-08022021-000574	8/18/2021	FT-FY21-082021-000574-A	<1	FT-FY21-082021-000574-B	<1	

WS-000575	8/2/2021	8/2/2022	1	Bathroom	In classroom 184 (bathroom)	WF-08022021-000575	8/18/2021	FT-FY21-082021-000575-A	<1	FT-FY21-082021-000575-B	<1	
WS-000577	8/2/2021	8/2/2022	1	Combo Fountain	In classroom 185	WF-08022021-000577	8/18/2021	FT-FY21-082021-000577-A	<1	FT-FY21-082021-000577-B	<1	
WS-000578	8/2/2021	8/2/2022	1	Bathroom	In classroom 185 (bathroom)	WF-08022021-000578	8/18/2021	FT-FY21-082021-000578-A	<1	FT-FY21-082021-000578-B	<1	
WS-000579	8/2/2021	8/2/2022	2	Bottle Filler	In gym	WF-08022021-000579	8/18/2021	FT-FY21-082021-000579-A	<1	FT-FY21-082021-000579-B	<1	
WS-000582	8/2/2021	8/2/2022	2	Cooler	In gym	High Left	WF-08022021-000582	8/18/2021	FT-FY21-082021-000582-A	<1	FT-FY21-082021-000582-B	<1
WS-000583	8/2/2021	8/2/2022	2	Cooler	In gym	Low Right	WF-08022021-000583	8/18/2021	FT-FY21-082021-000583-A	<1	FT-FY21-082021-000583-B	<1
WS-000586	8/2/2021	8/2/2022	2	Bottle Filler	In hallway adjacent to room 228T		WF-08022021-000586	8/18/2021	FT-FY21-082021-000586-A	<1	FT-FY21-082021-000586-B	<1
WS-000587	8/2/2021	8/2/2022	2	Cooler	In hallway adjacent to room 228T	High Left	WF-08022021-000587	8/18/2021	FT-FY21-082021-000587-A	<1	FT-FY21-082021-000587-B	<1
WS-000588	8/2/2021	8/2/2022	2	Cooler	In hallway adjacent to room 228T	Low Right	WF-08022021-000588	8/18/2021	FT-FY21-082021-000588-A	<1	FT-FY21-082021-000588-B	<1
WS-000590	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 250		WF-08022021-000590	8/18/2021	FT-FY21-082021-000590-A	<1	FT-FY21-082021-000590-B	<1
WS-000592	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 251	High Left	WF-08022021-000592	8/18/2021	FT-FY21-082021-000592-A	<1	FT-FY21-082021-000592-B	<1
WS-000594	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 251	Low Right	WF-08022021-000594	8/18/2021	FT-FY21-082021-000594-A	<1	FT-FY21-082021-000594-B	<1
WS-000596	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 254		WF-08022021-000596	8/18/2021	FT-FY21-082021-000596-A	<1	FT-FY21-082021-000596-B	<1
WS-000598	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 255		WF-08022021-000598	8/18/2021	FT-FY21-082021-000598-A	<1	FT-FY21-082021-000598-B	<1
WS-000600	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 260		WF-08022021-000600	8/18/2021	FT-FY21-082021-000600-A	<1	FT-FY21-082021-000600-B	<1
WS-000668	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 261		WF-08022021-000668	8/18/2021	FT-FY21-082021-000668-A	<1	FT-FY21-082021-000668-B	<1
WS-000672	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 264		WF-08022021-000672	8/18/2021	FT-FY21-082021-000672-A	<1	FT-FY21-082021-000672-B	<1
WS-000674	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 265		WF-08022021-000674	8/18/2021	FT-FY21-082021-000674-A	<1	FT-FY21-082021-000674-B	<1
WS-000676	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 202		WF-08022021-000676	8/18/2021	FT-FY21-082021-000676-A	<1	FT-FY21-082021-000676-B	<1
WS-000677	8/2/2021	8/2/2022	2	Bottle Filler	In hallway across from cafeteria entrance		WF-08022021-000677	8/18/2021	FT-FY21-082021-000677-A	<1	FT-FY21-082021-000677-B	<1
WS-000678	8/2/2021	8/2/2022	2	Cooler	In hallway across from cafeteria entrance	High Left	WF-08022021-000678	8/18/2021	FT-FY21-082021-000678-A	<1	FT-FY21-082021-000678-B	<1
WS-000679	8/2/2021	8/2/2022	2	Cooler	In hallway across from cafeteria entrance	Low Right	WF-08022021-000679	8/18/2021	FT-FY21-082021-000679-A	<1	FT-FY21-082021-000679-B	<1
WS-000680	8/2/2021	8/2/2022	2	Bottle Filler	In cafeteria		WF-08022021-000680	8/18/2021	FT-FY21-082021-000680-A	<1	FT-FY21-082021-000680-B	<1
WS-000681	8/2/2021	8/2/2022	2	Cooler	In cafeteria	High Left	WF-08022021-000681	8/18/2021	FT-FY21-082021-000681-A	<1	FT-FY21-082021-000681-B	<1
WS-000682	8/2/2021	8/2/2022	2	Cooler	In cafeteria	Low Right	WF-08022021-000682	8/18/2021	FT-FY21-082021-000682-A	<1	FT-FY21-082021-000682-B	<1
WS-000692	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 270	High Right	WF-08022021-000692	8/18/2021	FT-FY21-082021-000692-A	<1	FT-FY21-082021-000692-B	<1
WS-000694	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 271		WF-08022021-000694	8/18/2021	FT-FY21-082021-000694-A	<1	FT-FY21-082021-000694-B	<1
WS-000696	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 274		WF-08022021-000696	8/18/2021	FT-FY21-082021-000696-A	<1	FT-FY21-082021-000696-B	<1
WS-000698	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 275		WF-08022021-000698	8/18/2021	FT-FY21-082021-000698-A	<1	FT-FY21-082021-000698-B	<1
WS-000700	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 280		WF-08022021-000700	8/18/2021	FT-FY21-082021-000700-A	<1	FT-FY21-082021-000700-B	<1
WS-000702	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 281		WF-08022021-000702	8/18/2021	FT-FY21-082021-000702-A	<1	FT-FY21-082021-000702-B	<1
WS-000703	8/2/2021	8/2/2022	2	Break Room	In teacher collaboration room 283		WF-08022021-000703	8/18/2021	FT-FY21-082021-000703-A	<1	FT-FY21-082021-000703-B	<1
WS-000705	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 284		WF-08022021-000705	8/18/2021	FT-FY21-082021-000705-A	<1	FT-FY21-082021-000705-B	<1
WS-000707	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 285		WF-08022021-000707	8/18/2021	FT-FY21-082021-000707-A	<1	FT-FY21-082021-000707-B	<1
WS-000709	8/2/2021	8/2/2022	2	Combo Fountain	In classroom 270	Low Left	WF-08022021-000709	8/18/2021	FT-FY21-082021-000709-A	<1	FT-FY21-082021-000709-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000689	8/2/2021	8/2/2022	2	Food Prep Sink	In kitchen 7th clockwise from entry	WF-08022021-000689	8/18/2021	FT-FY21-082021-000689-A	<1	FT-FY21-082021-000689-B	<1