



WEST EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	WEST EDUCATIONAL CAMPUS	WS- 002845	8/23/2016	1	Health Suite	In health suite	FT-82016-002845-A	< 1	FT-82016-002845-B	< 1
2	WEST EDUCATIONAL CAMPUS	WS- 010175	8/23/2016	Ground Floor	Cooler	In classroom Pre-K West	FT-82016-010175-A	< 1	FT-82016-010175-B	< 1
3	WEST EDUCATIONAL CAMPUS	WS- 010176	8/23/2016	Ground Floor	Classroom Faucet	In classroom Pre-K West Left	FT-72016-010176-A	< 1	FT-72016-010176-B	< 1
4	WEST EDUCATIONAL CAMPUS	WS- 010180	8/23/2016	Ground Floor	Cooler	In hallway adjacent to girls' restroom	FT-82016-010180-A	< 1	FT-82016-010180-B	< 1
5	WEST EDUCATIONAL CAMPUS	WS- 010182	8/23/2016	Ground Floor	Cooler	In health suite	FT-82016-010182-A	< 1	FT-82016-010182-B	< 1
6	WEST EDUCATIONAL CAMPUS	WS- 010183	8/23/2016	Ground Floor	Cooler	In hallway adjacent to health suite	FT-82016-010183-A	< 1	FT-82016-010183-B	< 1
7	WEST EDUCATIONAL CAMPUS	WS- 010184	8/23/2016	Ground Floor	Cooler	In hallway adjacent to boys' restroom	FT-82016-010184-A	< 1	FT-82016-010184-B	< 1
8	WEST EDUCATIONAL CAMPUS	WS- 010186	8/23/2016	Ground Floor	Cooler	In classroom Pre-K South Right	FT-82016-010186-A	< 1	FT-82016-010186-B	< 1
9	WEST EDUCATIONAL CAMPUS	WS- 010187	8/23/2016	1	Cooler	In parents center adjacent to bookroom Left	FT-82016-010187-A	< 1	FT-82016-010187-B	< 1
10	WEST EDUCATIONAL CAMPUS	WS- 010190	8/23/2016	Ground Floor	Cooler	In classroom Pre-K North Left	FT-82016-010190-A	< 1	FT-82016-010190-B	< 1
11	WEST EDUCATIONAL CAMPUS	WS- 010191	8/23/2016	1	Cooler	In parents center adjacent to bookroom Right	FT-82016-010191-A	< 1	FT-82016-010191-B	< 1
12	WEST EDUCATIONAL CAMPUS	WS- 010192	8/23/2016	1	Cooler	In parents center adjacent to restrooms Left	FT-82016-010192-A	< 1	FT-82016-010192-B	< 1
13	WEST EDUCATIONAL CAMPUS	WS- 010193	8/23/2016	1	Cooler	In parents center adjacent to restrooms Right	FT-82016-010193-A	< 1	FT-82016-010193-B	< 1
14	WEST EDUCATIONAL CAMPUS	WS- 010206	8/23/2016	1	Cooler	In staff lounge	FT-82016-010206-A	< 1	FT-82016-010206-B	< 1
15	WEST EDUCATIONAL CAMPUS	WS- 010207	8/23/2016	1	Cooler	In hallway across from staff lounge	FT-82016-010207-A	< 1	FT-82016-010207-B	< 1
16	WEST EDUCATIONAL CAMPUS	WS- 010208	8/23/2016	1	Cooler	In multi-purpose room adjacent to kitchen	FT-82016-010208-A	< 1	FT-82016-010208-B	< 1
17	WEST EDUCATIONAL CAMPUS	WS- 010209	8/23/2016	1	Cooler	In hallway adjacent to gym Left	FT-82016-010209-A	< 1	FT-82016-010209-B	< 1
18	WEST EDUCATIONAL CAMPUS	WS- 010210	8/23/2016	1	Cooler	In hallway adjacent to gym Right	FT-82016-010210-A	< 1	FT-82016-010210-B	< 1
19	WEST EDUCATIONAL CAMPUS	WS- 010212	8/23/2016	1	Food Prep Sink	In kitchen Right	FT-72016-010212-A	< 1	FT-72016-010212-B	< 1
20	WEST EDUCATIONAL CAMPUS	WS- 010213	8/23/2016	1	Cooler	In gym Left	FT-82016-010213-A	< 1	FT-82016-010213-B	< 1
21	WEST EDUCATIONAL CAMPUS	WS- 010214	8/23/2016	1	Cooler	In gym Low Right	FT-82016-010214-A	< 1	FT-82016-010214-B	< 1
22	WEST EDUCATIONAL CAMPUS	WS- 010215	8/23/2016	2	Cooler	In hallway adjacent to dark room	FT-82016-010215-A	< 1	FT-82016-010215-B	< 1