



WEST LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010175	Cooler	Ground Floor	In classroom pre K west	WT-042916-10192- A	< 1	WT-042916-10192- B	< 1				
2 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010176	Classroom	Ground Floor	In classroom pre K west Left	WT-042916-10193- A	39	WT-042916-10193- B	3.1	Filter will be installed and then retested			
3 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010177	Classroom	Ground Floor	In classroom pre k west Mid	WT-042916-10194- A	9.4	WT-042916-10194- B	7.4				
4 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010178	Classroom	Ground Floor	In hallway adjacent to speech room	WT-042916-10195- A	5.4	WT-042916-10195- B	< 1				
5 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010179	Classroom	Ground Floor	In classroom pre K west Right	WT-042916-10196- A	< 1	WT-042916-10196- B	< 1				
6 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010180	Classroom	Ground Floor	In hallway adjacent to women restroom	WT-042916-10197- A	< 1	WT-042916-10197- B	< 1				
7 WEST EDUCATIONAL CAMPUS	5/4/2016	WS- 010181	Utility	Basement	In boiler room	WT-042916-10198- A	< 1	WT-042916-10198- B	< 1				
8 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010182	Classroom	Ground Floor	In health suite	WT-042916-10199- A	< 1	WT-042916-10199- B	< 1				
9 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010183	Cooler	Ground Floor	In hallway adjacent to health suit	WT-042916-10200- A	< 1	WT-042916-10200- B	< 1				
10 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010184	Cooler	Ground Floor	In hallway adjacent to men restroom	WT-042916-10201- A	< 1	WT-042916-10201- B	< 1				
11 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010185	Classroom	Ground Floor	In classroom pre K east third from left	WT-042916-10202- A	1.4	WT-042916-10202- B	< 1				
12 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010186	Cooler	Ground Floor	In classroom pre K south Right	WT-042916-10203- A	< 1	WT-042916-10203- B	< 1				
13 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010187	Cooler	1	In parents center southwest Left	WT-042916-10204- A	< 1	WT-042916-10204- B	< 1				
14 WEST EDUCATIONAL CAMPUS	5/4/2016	WS- 010188	Classroom	Ground Floor	In classroom pre k east second from left	WT-042916-10205- A	< 1	WT-042916-10205- B	< 1				
15 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010189	Classroom	Ground Floor	In classroom pre k east first from left	WT-042916-10206- A	< 1	WT-042916-10206- B	< 1				
16 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010190	Cooler	Ground Floor	In classroom pre k north Left	WT-042916-10207- A	< 1	WT-042916-10207- B	< 1				
17 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010191	Cooler	1	In parent center southwest Right	WT-042916-10208- A	< 1	WT-042916-10208- B	< 1				
18 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010192	Cooler	1	In parent center northeast Left	WT-042916-10209- A	< 1	WT-042916-10209- B	< 1				
19 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010193	Cooler	1	In parent center northeast Right	WT-042916-10210- A	< 1	WT-042916-10210- B	< 1				
20 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010194	Classroom	1	In science room south wall	WT-042916-10211- A	2.8	WT-042916-10211- B	< 1				
21 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010195	Classroom	1	In science room west wall	WT-042916-10212- A	45	WT-042916-10212- B	< 1	Filter will be installed and then retested			
22 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010196	Classroom	1	In science room north wall Left	WT-042916-10213- A	4.8	WT-042916-10213- B	< 1				
23 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010197	Classroom	1	In science room north wall Right	WT-042916-10214- A	2.4	WT-042916-10214- B	< 1				
24 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010198	Classroom	1	In science room east wall Left	WT-042916-10215- A	< 1	WT-042916-10215- B	< 1				
25 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010199	Classroom	1	In science room east wall Right	WT-042916-10216- A	4.7	WT-042916-10216- B	< 1				
26 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010200	Classroom	1	In art room west Left	WT-042916-10217- A	< 1	WT-042916-10217- B	< 1				
27 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010201	Classroom	1	In art room west wall Right	WT-042916-10218- A	< 1	WT-042916-10218- B	< 1				
28 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010202	Classroom	1	In art room north wall Left	WT-042916-10219- A	< 1	WT-042916-10219- B	< 1				
29 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010203	Classroom	1	In art room north wall Right	WT-042916-10220- A	< 1	WT-042916-10220- B	< 1				
30 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010204	Classroom	1	In art room east wall	WT-042916-10221- A	9.7	WT-042916-10221- B	< 1				
31 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010205	Classroom	1	In art room south wall	WT-042916-10222- A	< 1	WT-042916-10222- B	< 1				
32 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010206	Cooler	1	In staff lounge	WT-042916-10223- A	< 1	WT-042916-10223- B	< 1				
33 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010207	Cooler	1	In hallway across from staff lounge	WT-042916-10224- A	< 1	WT-042916-10224- B	1.9				
34 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010208	Cooler	1	In all purpose room adjacent to kitchen	WT-042916-10225- A	< 1	WT-042916-10225- B	< 1				
35 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010209	Cooler	1	In hallway adjacent to gym Left	WT-042916-10226- A	< 1	WT-042916-10226- B	< 1				
36 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010210	Cooler	1	In hallway adjacent to gym Right	WT-042916-10227- A	< 1	WT-042916-10227- B	< 1				
37 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010211	Kitchen	1	In kitchen (shower head)	WT-042916-10228- A	< 1	WT-042916-10228- B	1.4				
38 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010212	Kitchen	1	In kitchen Right	WT-042916-10229- A	< 1	WT-042916-10229- B	< 1				
39 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010213	Cooler	1	In gym Left	WT-042916-10230- A	< 1	WT-042916-10230- B	< 1				
40 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010214	Cooler	1	In gym Right Low	WT-042916-10231- A	< 1	WT-042916-10231- B	< 1				
41 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010215	Cooler	2	In hallway adjacent to dark room	WT-042916-10232- A	< 1	WT-042916-10232- B	< 1				
42 WEST EDUCATIONAL CAMPUS	5/11/2016	WS- 010216	Classroom	2	In hallway kitchen	WT-042916-10233- A	4.3	WT-042916-10233- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.