



# West EC Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002845	5/21/2018	5/21/2019	Ground Floor	Health Suite	In health suite	WF-05212018-002845	11/12/2018	FT-FY19-112018-002845-A	< 1	FT-FY19-112018-002845-B	< 1
WS- 002846	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K West, in support kitchenette	WF-09242018-002846	11/12/2018	FT-FY19-112018-002846-A	< 1	FT-FY19-112018-002846-B	< 1
WS- 010175	5/21/2018	5/21/2019	Ground Floor	Cooler	In classroom Pre-K West	WF-05212018-010175	11/12/2018	FT-FY19-112018-010175-A	< 1	FT-FY19-112018-010175-B	< 1
WS- 010176	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K West	Left WF-09242018-010176	11/12/2018	FT-FY19-112018-010176-A	< 1	FT-FY19-112018-010176-B	< 1
WS- 010177	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K West	Mid WF-09242018-010177	11/12/2018	FT-FY19-112018-010177-A	< 1	FT-FY19-112018-010177-B	< 1
WS- 010179	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K West	Right WF-09242018-010179	11/12/2018	FT-FY19-112018-010179-A	< 1	FT-FY19-112018-010179-B	< 1
WS- 010180	5/21/2018	5/21/2019	Ground Floor	Cooler	In hallway adjacent to girls' restroom	WF-05212018-010180	11/12/2018	FT-FY19-112018-010180-A	< 1	FT-FY19-112018-010180-B	< 1
WS- 010182	5/21/2018	5/21/2019	Ground Floor	Cooler	In health suite	WF-05212018-010182	11/12/2018	FT-FY19-112018-010182-A	< 1	FT-FY19-112018-010182-B	< 1
WS- 010183	5/21/2018	5/21/2019	Ground Floor	Cooler	In hallway adjacent to health suite	WF-05212018-010183	11/12/2018	FT-FY19-112018-010183-A	< 1	FT-FY19-112018-010183-B	< 1
WS- 010184	5/21/2018	5/21/2019	Ground Floor	Cooler	In hallway adjacent to boys' restroom	WF-05212018-010184	11/12/2018	FT-FY19-112018-010184-A	< 1	FT-FY19-112018-010184-B	< 1
WS- 010185	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K East	Right WF-09242018-010185	11/12/2018	FT-FY19-112018-010185-A	3	FT-FY19-112018-010185-B	2.3
WS- 010186	5/21/2018	5/21/2019	Ground Floor	Cooler	In classroom Pre-K South	Right WF-05212018-010186	11/12/2018	FT-FY19-112018-010186-A	< 1	FT-FY19-112018-010186-B	< 1
WS- 010187	5/21/2018	5/21/2019	1	Cooler	In parents center adjacent to bookroom	Left WF-05212018-010187	11/12/2018	FT-FY19-112018-010187-A	< 1	FT-FY19-112018-010187-B	< 1
WS- 010188	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K East	Mid WF-09242018-010188	11/12/2018	FT-FY19-112018-010188-A	< 1	FT-FY19-112018-010188-B	< 1
WS- 010189	9/24/2018	9/24/2019	Ground Floor	Classroom Faucet	In classroom Pre-K East	Left WF-09242018-010189	11/12/2018	FT-FY19-112018-010189-A	1.2	FT-FY19-112018-010189-B	1.1
WS- 010190	5/21/2018	5/21/2019	Ground Floor	Cooler	In classroom Pre-K North	Left WF-05212018-010190	11/12/2018	FT-FY19-112018-010190-A	< 1	FT-FY19-112018-010190-B	< 1
WS- 010191	5/21/2018	5/21/2019	1	Cooler	In parents center adjacent to bookroom	Right WF-05212018-010191	11/12/2018	FT-FY19-112018-010191-A	< 1	FT-FY19-112018-010191-B	< 1
WS- 010192	5/21/2018	5/21/2019	1	Cooler	In parents center adjacent to restrooms	Left WF-05212018-010192	11/12/2018	FT-FY19-112018-010192-A	< 1	FT-FY19-112018-010192-B	< 1
WS- 010193	5/21/2018	5/21/2019	1	Cooler	In parents center adjacent to restrooms	Right WF-05212018-010193	11/12/2018	FT-FY19-112018-010193-A	< 1	FT-FY19-112018-010193-B	< 1
WS- 010206	5/21/2018	5/21/2019	1	Cooler	In staff lounge	WF-05212018-010206	11/12/2018	FT-FY19-112018-010206-A	< 1	FT-FY19-112018-010206-B	< 1
WS- 010207	5/21/2018	5/21/2019	1	Cooler	In hallway across from staff lounge	WF-05212018-010207	11/12/2018	FT-FY19-112018-010207-A	< 1	FT-FY19-112018-010207-B	< 1
WS- 010208	5/21/2018	5/21/2019	1	Cooler	In multi-purpose room adjacent to kitchen	WF-05212018-010208	11/12/2018	FT-FY19-112018-010208-A	< 1	FT-FY19-112018-010208-B	< 1
WS- 010209	5/21/2018	5/21/2019	1	Cooler	In hallway adjacent to gym	Left WF-05212018-010209	11/12/2018	FT-FY19-112018-010209-A	< 1	FT-FY19-112018-010209-B	< 1
WS- 010210	5/21/2018	5/21/2019	1	Cooler	In hallway adjacent to gym	Right WF-05212018-010210	11/12/2018	FT-FY19-112018-010210-A	< 1	FT-FY19-112018-010210-B	< 1
WS- 010213	5/21/2018	5/21/2019	1	Cooler	In gym	High Left WF-05212018-010213	11/12/2018	FT-FY19-112018-010213-A	< 1	FT-FY19-112018-010213-B	< 1
WS- 010214	5/21/2018	5/21/2019	1	Cooler	In gym	Low Right WF-05212018-010214	11/12/2018	FT-FY19-112018-010214-A	< 1	FT-FY19-112018-010214-B	< 1
WS- 010215	5/21/2018	5/21/2019	2	Cooler	In hallway adjacent to dark room	WF-05212018-010215	11/12/2018	FT-FY19-112018-010215-A	< 1	FT-FY19-112018-010215-B	< 1
WS- 010216	5/21/2018	5/21/2019	2	Break Room	In staff lounge	WF-05212018-010216	11/12/2018	FT-FY19-112018-010216-A	< 1	FT-FY19-112018-010216-B	< 1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010212	1	Food Prep Sink	In kitchen	Right	11/12/2018	FT-FY19-112018-010212-A	< 1	FT-FY19-112018-010212-B	< 1