



Wheatley EC Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001304	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G08	WF-08042025-001304	12/17/2025	FT-FY26-12082025-001304-A	<2	FT-FY26-12082025-001304-B	<2
WS- 001305	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G08	WF-02102025-001305	12/17/2025	FT-FY26-12082025-001305-A	<2	FT-FY26-12082025-001305-B	<2
WS- 001306	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G31	WF-08042025-001306	12/17/2025	FT-FY26-12082025-001306-A	<2	FT-FY26-12082025-001306-B	<2
WS- 001307	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G31	WF-02102025-001307	12/17/2025	FT-FY26-12082025-001307-A	<2	FT-FY26-12082025-001307-B	<2
WS- 001310	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G05	WF-08042025-001310	12/17/2025	FT-FY26-12082025-001310-A	<2	FT-FY26-12082025-001310-B	<2
WS- 001311	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G05	WF-02102025-001311	12/17/2025	FT-FY26-12082025-001311-A	<2	FT-FY26-12082025-001311-B	<2
WS- 001312	2/10/2025	2/10/2026	Ground Floor	Break Room	In staff lounge G33	WF-02102025-001312	12/17/2025	FT-FY26-12082025-001312-A	<2	FT-FY26-12082025-001312-B	<2
WS- 001315	2/10/2025	2/10/2026	Ground Floor	Health Suite	In health suite G41B	WF-02102025-001315	12/17/2025	FT-FY26-12082025-001315-A	<2	FT-FY26-12082025-001315-B	<2
WS- 001319	2/10/2025	2/10/2026	Ground Floor	Cooler	In hallway adjacent to room G46 High Left	WF-02102025-001319	12/17/2025	FT-FY26-12082025-001319-A	<2	FT-FY26-12082025-001319-B	<2
WS- 001321	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G51	WF-02102025-001321	12/17/2025	FT-FY26-12082025-001321-A	<2	FT-FY26-12082025-001321-B	<2
WS- 001322	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G51	WF-08042025-001322	12/17/2025	FT-FY26-12082025-001322-A	<2	FT-FY26-12082025-001322-B	<2
WS- 001323	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G54	WF-02102025-001323	12/17/2025	FT-FY26-12082025-001323-A	<2	FT-FY26-12082025-001323-B	<2
WS- 001324	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G54	WF-08042025-001324	12/17/2025	FT-FY26-12082025-001324-A	<2	FT-FY26-12082025-001324-B	<2
WS- 001326	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G57	WF-02102025-001326	12/17/2025	FT-FY26-12082025-001326-A	<2	FT-FY26-12082025-001326-B	<2
WS- 001327	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G57	WF-08042025-001327	12/17/2025	FT-FY26-12082025-001327-A	<2	FT-FY26-12082025-001327-B	<2
WS- 001329	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G58	WF-08042025-001329	12/17/2025	FT-FY26-12082025-001329-A	<2	FT-FY26-12082025-001329-B	<2
WS- 001330	2/10/2025	2/10/2026	Ground Floor	Combo Fountain	In classroom G59	WF-02102025-001330	12/17/2025	FT-FY26-12082025-001330-A	<2	FT-FY26-12082025-001330-B	<2
WS- 001331	8/4/2025	8/4/2026	Ground Floor	Combo Faucet	In classroom G59	WF-08042025-001331	12/17/2025	FT-FY26-12082025-001331-A	<2	FT-FY26-12082025-001331-B	<2
WS- 001332	2/10/2025	2/10/2026	Ground Floor	Cooler	In hallway adjacent to room G15 High Left	WF-02102025-001332	12/17/2025	FT-FY26-12082025-001332-A	<2	FT-FY26-12082025-001332-B	<2
WS- 001333	2/10/2025	2/10/2026	Ground Floor	Cooler	In hallway adjacent to room G15 Low Right	WF-02102025-001333	12/17/2025	FT-FY26-12082025-001333-A	<2	FT-FY26-12082025-001333-B	<2
WS- 001334	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 103	WF-02102025-001334	12/17/2025	FT-FY26-12082025-001334-A	<2	FT-FY26-12082025-001334-B	<2
WS- 001335	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 103	WF-08042025-001335	12/17/2025	FT-FY26-12082025-001335-A	<2	FT-FY26-12082025-001335-B	<2
WS- 001336	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent to room 105 Low Right	WF-02102025-001336	12/17/2025	FT-FY26-12082025-001336-A	<2	FT-FY26-12082025-001336-B	<2
WS- 001337	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent to room 105 High Left	WF-02102025-001337	12/17/2025	FT-FY26-12082025-001337-A	<2	FT-FY26-12082025-001337-B	<2
WS- 001338	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 111	WF-02102025-001338	12/17/2025	FT-FY26-12082025-001338-A	<2	FT-FY26-12082025-001338-B	<2
WS- 001339	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 111	WF-08042025-001339	12/17/2025	FT-FY26-12082025-001339-A	<2	FT-FY26-12082025-001339-B	<2
WS- 001340	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 113	WF-02102025-001340	12/17/2025	FT-FY26-12082025-001340-A	<2	FT-FY26-12082025-001340-B	<2
WS- 001341	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 113	WF-08042025-001341	12/17/2025	FT-FY26-12082025-001341-A	<2	FT-FY26-12082025-001341-B	<2
WS- 001342	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 114	WF-02102025-001342	12/17/2025	FT-FY26-12082025-001342-A	<2	FT-FY26-12082025-001342-B	<2
WS- 001343	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 114	WF-08042025-001343	12/17/2025	FT-FY26-12082025-001343-A	<2	FT-FY26-12082025-001343-B	<2
WS- 001345	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 115	WF-08042025-001345	12/17/2025	FT-FY26-12082025-001345-A	<2	FT-FY26-12082025-001345-B	<2
WS- 001346	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 136	WF-02102025-001346	12/17/2025	FT-FY26-12082025-001346-A	<2	FT-FY26-12082025-001346-B	<2
WS- 001347	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 136	WF-08042025-001347	12/17/2025	FT-FY26-12082025-001347-A	<2	FT-FY26-12082025-001347-B	<2
WS- 001348	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 135	WF-02102025-001348	12/17/2025	FT-FY26-12082025-001348-A	<2	FT-FY26-12082025-001348-B	<2

WS- 001349	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 135		WF-08042025-001349	12/17/2025	FT-FY26-12082025-001349-A	<2	FT-FY26-12082025-001349-B	<2
WS- 001350	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 107		WF-02102025-001350	12/17/2025	FT-FY26-12082025-001350-A	<2	FT-FY26-12082025-001350-B	<2
WS- 001351	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 107		WF-08042025-001351	12/17/2025	FT-FY26-12082025-001351-A	<2	FT-FY26-12082025-001351-B	<2
WS- 001352	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent to room 148	High Left	WF-02102025-001352	12/17/2025	FT-FY26-12082025-001352-A	<2	FT-FY26-12082025-001352-B	<2
WS- 001353	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent to room 148	Low Right	WF-02102025-001353	12/17/2025	FT-FY26-12082025-001353-A	<2	FT-FY26-12082025-001353-B	<2
WS- 001354	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 123		WF-02102025-001354	12/17/2025	FT-FY26-12082025-001354-A	<2	FT-FY26-12082025-001354-B	<2
WS- 001355	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 123		WF-08042025-001355	12/17/2025	FT-FY26-12082025-001355-A	<2	FT-FY26-12082025-001355-B	<2
WS- 001356	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 125		WF-02102025-001356	12/17/2025	FT-FY26-12082025-001356-A	<2	FT-FY26-12082025-001356-B	<2
WS- 001357	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 125		WF-08042025-001357	12/17/2025	FT-FY26-12082025-001357-A	<2	FT-FY26-12082025-001357-B	<2
WS- 001358	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 128		WF-02102025-001358	12/17/2025	FT-FY26-12082025-001358-A	<2	FT-FY26-12082025-001358-B	<2
WS- 001359	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 128		WF-08042025-001359	12/17/2025	FT-FY26-12082025-001359-A	<2	FT-FY26-12082025-001359-B	<2
WS- 001360	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 131		WF-02102025-001360	12/17/2025	FT-FY26-12082025-001360-A	<2	FT-FY26-12082025-001360-B	<2
WS- 001361	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 131		WF-08042025-001361	12/17/2025	FT-FY26-12082025-001361-A	<2	FT-FY26-12082025-001361-B	<2
WS- 001362	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 224		WF-02102025-001362	12/17/2025	FT-FY26-12082025-001362-A	<2	FT-FY26-12082025-001362-B	<2
WS- 001363	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 224		WF-08042025-001363	12/17/2025	FT-FY26-12082025-001363-A	<2	FT-FY26-12082025-001363-B	<2
WS- 001364	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 225		WF-02102025-001364	12/17/2025	FT-FY26-12082025-001364-A	<2	FT-FY26-12082025-001364-B	<2
WS- 001365	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 225		WF-08042025-001365	12/17/2025	FT-FY26-12082025-001365-A	<2	FT-FY26-12082025-001365-B	<2
WS- 001366	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 227		WF-02102025-001366	12/17/2025	FT-FY26-12082025-001366-A	<2	FT-FY26-12082025-001366-B	<2
WS- 001367	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 227		WF-08042025-001367	12/17/2025	FT-FY26-12082025-001367-A	<2	FT-FY26-12082025-001367-B	<2
WS- 001368	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 229		WF-02102025-001368	12/17/2025	FT-FY26-12082025-001368-A	<2	FT-FY26-12082025-001368-B	<2
WS- 001369	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 229		WF-08042025-001369	12/17/2025	FT-FY26-12082025-001369-A	<2	FT-FY26-12082025-001369-B	<2
WS- 001370	2/10/2025	2/10/2026	2	Cooler	In hallway across from room 232	High Left	WF-02102025-001370	12/17/2025	FT-FY26-12082025-001370-A	<2	FT-FY26-12082025-001370-B	<2
WS- 001371	2/10/2025	2/10/2026	2	Cooler	In hallway across from room 232	Low Right	WF-02102025-001371	12/17/2025	FT-FY26-12082025-001371-A	<2	FT-FY26-12082025-001371-B	<2
WS- 001372	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 234		WF-02102025-001372	12/17/2025	FT-FY26-12082025-001372-A	<2	FT-FY26-12082025-001372-B	<2
WS- 001373	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 234		WF-08042025-001373	12/17/2025	FT-FY26-12082025-001373-A	<2	FT-FY26-12082025-001373-B	<2
WS- 001374	2/13/2025	2/13/2026	2	Break Room	In break room 235		WF-02132025-001374	12/17/2025	FT-FY26-12082025-001374-A	<2	FT-FY26-12082025-001374-B	<2
WS- 001376	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 207		WF-08042025-001376	12/17/2025	FT-FY26-12082025-001376-A	<2	FT-FY26-12082025-001376-B	<2
WS- 001378	2/10/2025	2/10/2026	2	Cooler	In hallway adjacent to room 205	Low Right	WF-02102025-001378	12/17/2025	FT-FY26-12082025-001378-A	<2	FT-FY26-12082025-001378-B	<2
WS- 001379	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 203		WF-02102025-001379	12/17/2025	FT-FY26-12082025-001379-A	<2	FT-FY26-12082025-001379-B	<2
WS- 001380	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 203		WF-08042025-001380	12/17/2025	FT-FY26-12082025-001380-A	<2	FT-FY26-12082025-001380-B	<2
WS- 001381	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 211		WF-02102025-001381	12/17/2025	FT-FY26-12082025-001381-A	<2	FT-FY26-12082025-001381-B	<2
WS- 001382	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 211		WF-08042025-001382	12/17/2025	FT-FY26-12082025-001382-A	<2	FT-FY26-12082025-001382-B	<2
WS- 001383	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 215		WF-02102025-001383	12/17/2025	FT-FY26-12082025-001383-A	<2	FT-FY26-12082025-001383-B	<2
WS- 001384	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 215		WF-08042025-001384	12/17/2025	FT-FY26-12082025-001384-A	<2	FT-FY26-12082025-001384-B	<2
WS- 001385	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 222		WF-02102025-001385	12/17/2025	FT-FY26-12082025-001385-A	<2	FT-FY26-12082025-001385-B	<2
WS- 001386	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 222		WF-08042025-001386	12/17/2025	FT-FY26-12082025-001386-A	<2	FT-FY26-12082025-001386-B	<2
WS- 001387	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 213		WF-02102025-001387	12/17/2025	FT-FY26-12082025-001387-A	<2	FT-FY26-12082025-001387-B	<2
WS- 001388	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 213		WF-08042025-001388	12/17/2025	FT-FY26-12082025-001388-A	<2	FT-FY26-12082025-001388-B	<2
WS- 001574	2/10/2025	2/10/2026	2	Bottle Filler	In hallway across from room 232		WF-02102025-001574	12/17/2025	FT-FY26-12082025-001574-A	<2	FT-FY26-12082025-001574-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001302	11/26/2025	11/26/2026	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-11262025-001302	12/17/2025	FT-FY26-12082025-001302-A	<2	FT-FY26-12082025-001302-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.