



Wheatley Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001304	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G08	WF-08222022-001304	12/14/2022	FT-FY23-11182022-001304-A	<1	FT-FY23-11182022-001304-B	<1	
WS- 001305	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G08	WF-02272022-001305	12/14/2022	FT-FY23-11182022-001305-A	<1	FT-FY23-11182022-001305-B	<1	
WS- 001306	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G31	WF-08222022-001306	12/14/2022	FT-FY23-11182022-001306-A	<1	FT-FY23-11182022-001306-B	<1	
WS- 001307	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G31	WF-02272022-001307	12/14/2022	FT-FY23-11182022-001307-A	<1	FT-FY23-11182022-001307-B	<1	
WS- 001310	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G05	WF-08222022-001310	12/14/2022	FT-FY23-11182022-001310-A	<1	FT-FY23-11182022-001310-B	<1	
WS- 001311	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G05	WF-02272022-001311	12/14/2022	FT-FY23-11182022-001311-A	<1	FT-FY23-11182022-001311-B	<1	
WS- 001315	2/27/2022	2/27/2023	Ground Floor	Health Suite	In health suite G41B	WF-02272022-001315	12/14/2022	FT-FY23-11182022-001315-A	<1	FT-FY23-11182022-001315-B	<1	
WS- 001319	2/27/2022	2/27/2023	Ground Floor	Cooler	In hallway adjacent to room G46	High Left	WF-02272022-001319	12/14/2022	FT-FY23-11182022-001319-A	<1	FT-FY23-11182022-001319-B	<1
WS- 001320	2/27/2022	2/27/2023	Ground Floor	Cooler	In hallway adjacent to room G46	Low Right	WF-02272022-001320	12/14/2022	FT-FY23-11182022-001320-A	<1	FT-FY23-11182022-001320-B	<1
WS- 001321	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G51	WF-02272022-001321	12/14/2022	FT-FY23-11182022-001321-A	<1	FT-FY23-11182022-001321-B	<1	
WS- 001322	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G51	WF-08222022-001322	12/14/2022	FT-FY23-11182022-001322-A	<1	FT-FY23-11182022-001322-B	<1	
WS- 001323	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G54	WF-02272022-001323	12/14/2022	FT-FY23-11182022-001323-A	<1	FT-FY23-11182022-001323-B	<1	
WS- 001324	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G54	WF-08222022-001324	12/14/2022	FT-FY23-11182022-001324-A	<1	FT-FY23-11182022-001324-B	<1	
WS- 001326	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G57	WF-02272022-001326	12/14/2022	FT-FY23-11182022-001326-A	<1	FT-FY23-11182022-001326-B	<1	
WS- 001327	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G57	WF-08222022-001327	12/14/2022	FT-FY23-11182022-001327-A	<1	FT-FY23-11182022-001327-B	<1	
WS- 001328	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G58	WF-02272022-001328	12/14/2022	FT-FY23-11182022-001328-A	<1	FT-FY23-11182022-001328-B	<1	
WS- 001329	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G58	WF-08222022-001329	12/14/2022	FT-FY23-11182022-001329-A	<1	FT-FY23-11182022-001329-B	<1	
WS- 001330	2/27/2022	2/27/2023	Ground Floor	Combo Fountain	In classroom G59	WF-02272022-001330	12/14/2022	FT-FY23-11182022-001330-A	<1	FT-FY23-11182022-001330-B	<1	
WS- 001331	8/22/2022	8/22/2023	Ground Floor	Combo Faucet	In classroom G59	WF-08222022-001331	12/14/2022	FT-FY23-11182022-001331-A	<1	FT-FY23-11182022-001331-B	<1	
WS- 001333	2/27/2022	2/27/2023	Ground Floor	Cooler	In hallway adjacent to room G15	Low Right	WF-02272022-001333	12/14/2022	FT-FY23-11182022-001333-A	<1	FT-FY23-11182022-001333-B	<1
WS- 001334	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 103	WF-02272022-001334	12/14/2022	FT-FY23-11182022-001334-A	<1	FT-FY23-11182022-001334-B	<1	
WS- 001335	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 103	WF-08222022-001335	12/14/2022	FT-FY23-11182022-001335-A	<1	FT-FY23-11182022-001335-B	<1	
WS- 001336	2/27/2022	2/27/2023	1	Cooler	In hallway adjacent to room 105	Low Right	WF-02272022-001336	12/14/2022	FT-FY23-11182022-001336-A	<1	FT-FY23-11182022-001336-B	<1
WS- 001337	2/27/2022	2/27/2023	1	Cooler	In hallway adjacent to room 105	High Left	WF-02272022-001337	12/14/2022	FT-FY23-11182022-001337-A	<1	FT-FY23-11182022-001337-B	<1
WS- 001338	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 111	WF-02272022-001338	12/14/2022	FT-FY23-11182022-001338-A	<1	FT-FY23-11182022-001338-B	<1	
WS- 001339	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 111	WF-08222022-001339	12/14/2022	FT-FY23-11182022-001339-A	<1	FT-FY23-11182022-001339-B	<1	
WS- 001340	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 113	WF-02272022-001340	12/14/2022	FT-FY23-11182022-001340-A	<1	FT-FY23-11182022-001340-B	<1	
WS- 001341	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 113	WF-08222022-001341	12/14/2022	FT-FY23-11182022-001341-A	<1	FT-FY23-11182022-001341-B	<1	
WS- 001342	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 114	WF-02272022-001342	12/14/2022	FT-FY23-11182022-001342-A	<1	FT-FY23-11182022-001342-B	<1	
WS- 001343	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 114	WF-08222022-001343	12/14/2022	FT-FY23-11182022-001343-A	<1	FT-FY23-11182022-001343-B	<1	
WS- 001344	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 115	WF-02272022-001344	12/14/2022	FT-FY23-11182022-001344-A	<1	FT-FY23-11182022-001344-B	<1	
WS- 001345	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 115	WF-08222022-001345	12/14/2022	FT-FY23-11182022-001345-A	<1	FT-FY23-11182022-001345-B	<1	
WS- 001346	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 136	WF-02272022-001346	12/14/2022	FT-FY23-11182022-001346-A	<1	FT-FY23-11182022-001346-B	<1	
WS- 001347	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 136	WF-08222022-001347	12/14/2022	FT-FY23-11182022-001347-A	<1	FT-FY23-11182022-001347-B	<1	
WS- 001348	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 135	WF-02272022-001348	12/14/2022	FT-FY23-11182022-001348-A	<1	FT-FY23-11182022-001348-B	<1	

WS-001349	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 135		WF-08222022-001349	12/14/2022	FT-FY23-11182022-001349-A	<1	FT-FY23-11182022-001349-B	<1
WS-001350	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 107		WF-02272022-001350	12/14/2022	FT-FY23-11182022-001350-A	2.1	FT-FY23-11182022-001350-B	<1
WS-001351	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 107		WF-08222022-001351	12/14/2022	FT-FY23-11182022-001351-A	<1	FT-FY23-11182022-001351-B	<1
WS-001354	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 123		WF-02272022-001354	12/14/2022	FT-FY23-11182022-001354-A	<1	FT-FY23-11182022-001354-B	<1
WS-001355	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 123		WF-08222022-001355	12/14/2022	FT-FY23-11182022-001355-A	<1	FT-FY23-11182022-001355-B	<1
WS-001356	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 125		WF-02272022-001356	12/14/2022	FT-FY23-11182022-001356-A	<1	FT-FY23-11182022-001356-B	<1
WS-001357	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 125		WF-08222022-001357	12/14/2022	FT-FY23-11182022-001357-A	<1	FT-FY23-11182022-001357-B	<1
WS-001358	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 128		WF-02272022-001358	12/14/2022	FT-FY23-11182022-001358-A	<1	FT-FY23-11182022-001358-B	<1
WS-001359	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 128		WF-08222022-001359	12/14/2022	FT-FY23-11182022-001359-A	<1	FT-FY23-11182022-001359-B	<1
WS-001360	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 131		WF-02272022-001360	12/14/2022	FT-FY23-11182022-001360-A	<1	FT-FY23-11182022-001360-B	<1
WS-001361	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 131		WF-08222022-001361	12/14/2022	FT-FY23-11182022-001361-A	<1	FT-FY23-11182022-001361-B	<1
WS-001362	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 224		WF-02272022-001362	12/14/2022	FT-FY23-11182022-001362-A	<1	FT-FY23-11182022-001362-B	<1
WS-001363	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 224		WF-08222022-001363	12/14/2022	FT-FY23-11182022-001363-A	1.6	FT-FY23-11182022-001363-B	1.5
WS-001364	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 225		WF-02272022-001364	12/14/2022	FT-FY23-11182022-001364-A	<1	FT-FY23-11182022-001364-B	<1
WS-001365	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 225		WF-08222022-001365	12/14/2022	FT-FY23-11182022-001365-A	<1	FT-FY23-11182022-001365-B	<1
WS-001366	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 227		WF-02272022-001366	12/14/2022	FT-FY23-11182022-001366-A	<1	FT-FY23-11182022-001366-B	<1
WS-001367	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 227		WF-08222022-001367	12/14/2022	FT-FY23-11182022-001367-A	<1	FT-FY23-11182022-001367-B	<1
WS-001368	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 229		WF-02272022-001368	12/14/2022	FT-FY23-11182022-001368-A	<1	FT-FY23-11182022-001368-B	<1
WS-001369	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 229		WF-08222022-001369	12/14/2022	FT-FY23-11182022-001369-A	<1	FT-FY23-11182022-001369-B	<1
WS-001371	2/27/2022	2/27/2023	2	Cooler	In hallway across from room 232	Low Right	WF-02272022-001371	12/14/2022	FT-FY23-11182022-001371-A	<1	FT-FY23-11182022-001371-B	<1
WS-001372	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 234		WF-02272022-001372	12/14/2022	FT-FY23-11182022-001372-A	<1	FT-FY23-11182022-001372-B	<1
WS-001373	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 234		WF-08222022-001373	12/14/2022	FT-FY23-11182022-001373-A	<1	FT-FY23-11182022-001373-B	<1
WS-001374	2/27/2022	2/27/2023	2	Break Room	In break room 235		WF-02272022-001374	12/14/2022	FT-FY23-11182022-001374-A	<1	FT-FY23-11182022-001374-B	<1
WS-001375	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 207		WF-02272022-001375	12/14/2022	FT-FY23-11182022-001375-A	<1	FT-FY23-11182022-001375-B	<1
WS-001376	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 207		WF-08222022-001376	12/14/2022	FT-FY23-11182022-001376-A	<1	FT-FY23-11182022-001376-B	<1
WS-001378	2/27/2022	2/27/2023	2	Cooler	In hallway adjacent to room 205	Low Right	WF-02272022-001378	12/14/2022	FT-FY23-11182022-001378-A	1.6	FT-FY23-11182022-001378-B	1.6
WS-001379	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 203		WF-02272022-001379	12/14/2022	FT-FY23-11182022-001379-A	1.3	FT-FY23-11182022-001379-B	1.6
WS-001380	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 203		WF-08222022-001380	12/14/2022	FT-FY23-11182022-001380-A	1.4	FT-FY23-11182022-001380-B	1.7
WS-001381	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 211		WF-02272022-001381	12/14/2022	FT-FY23-11182022-001381-A	<1	FT-FY23-11182022-001381-B	<1
WS-001382	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 211		WF-08222022-001382	12/14/2022	FT-FY23-11182022-001382-A	<1	FT-FY23-11182022-001382-B	<1
WS-001383	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 215		WF-02272022-001383	12/14/2022	FT-FY23-11182022-001383-A	<1	FT-FY23-11182022-001383-B	<1
WS-001384	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 215		WF-08222022-001384	12/14/2022	FT-FY23-11182022-001384-A	<1	FT-FY23-11182022-001384-B	<1
WS-001385	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 222		WF-02272022-001385	12/14/2022	FT-FY23-11182022-001385-A	<1	FT-FY23-11182022-001385-B	<1
WS-001386	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 222		WF-08222022-001386	12/14/2022	FT-FY23-11182022-001386-A	<1	FT-FY23-11182022-001386-B	<1
WS-001387	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 213		WF-02272022-001387	12/14/2022	FT-FY23-11182022-001387-A	<1	FT-FY23-11182022-001387-B	<1
WS-001388	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 213		WF-08222022-001388	12/14/2022	FT-FY23-11182022-001388-A	1.0	FT-FY23-11182022-001388-B	1.0

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001302	1/12/2022	1/12/2023	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	Left	WF-01122022-001302	12/14/2022	FT-FY23-11182022-001302-A	<1	FT-FY23-11182022-001302-B	<1