



Wheatley Education Campus Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001304	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G08	WF-08142023-001304	12/5/2023	FT-FY24-11012023-001304-A	<1	FT-FY24-11012023-001304-B	<1	
WS- 001305	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G08	WF-02212023-001305	12/5/2023	FT-FY24-11012023-001305-A	2.5	FT-FY24-11012023-001305-B	<1	
WS- 001306	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G31	WF-08142023-001306	12/5/2023	FT-FY24-11012023-001306-A	<1	FT-FY24-11012023-001306-B	<1	
WS- 001307	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G31	WF-02212023-001307	12/5/2023	FT-FY24-11012023-001307-A	<1	FT-FY24-11012023-001307-B	<1	
WS- 001310	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G05	WF-08142023-001310	12/5/2023	FT-FY24-11012023-001310-A	<1	FT-FY24-11012023-001310-B	<1	
WS- 001311	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G05	WF-02212023-001311	12/5/2023	FT-FY24-11012023-001311-A	<1	FT-FY24-11012023-001311-B	<1	
WS- 001312	2/21/2023	2/21/2024	Ground Floor	Break Room	In staff lounge G33	WF-02212023-001312	12/5/2023	FT-FY24-11012023-001312-A	<1	FT-FY24-11012023-001312-B	<1	
WS- 001315	2/21/2023	2/21/2024	Ground Floor	Health Suite	In health suite G41B	WF-02212023-001315	12/5/2023	FT-FY24-11012023-001315-A	2.8	FT-FY24-11012023-001315-B	<1	
WS- 001319	2/21/2023	2/21/2024	Ground Floor	Cooler	In hallway adjacent to room G46	High Left	WF-02212023-001319	12/5/2023	FT-FY24-11012023-001319-A	<1	FT-FY24-11012023-001319-B	<1
WS- 001321	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G51	WF-02212023-001321	12/5/2023	FT-FY24-11012023-001321-A	<1	FT-FY24-11012023-001321-B	<1	
WS- 001323	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G54	WF-02212023-001323	12/5/2023	FT-FY24-11012023-001323-A	<1	FT-FY24-11012023-001323-B	<1	
WS- 001324	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G54	WF-08142023-001324	12/5/2023	FT-FY24-11012023-001324-A	<1	FT-FY24-11012023-001324-B	<1	
WS- 001326	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G57	WF-02212023-001326	12/5/2023	FT-FY24-11012023-001326-A	<1	FT-FY24-11012023-001326-B	<1	
WS- 001327	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G57	WF-08142023-001327	12/5/2023	FT-FY24-11012023-001327-A	<1	FT-FY24-11012023-001327-B	<1	
WS- 001328	2/21/2023	2/21/2024	Ground Floor	Combo Fountain	In classroom G58	WF-02212023-001328	12/5/2023	FT-FY24-11012023-001328-A	1.7	FT-FY24-11012023-001328-B	<1	
WS- 001329	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G58	WF-08142023-001329	12/5/2023	FT-FY24-11012023-001329-A	<1	FT-FY24-11012023-001329-B	<1	
WS- 001331	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G59	WF-08142023-001331	12/5/2023	FT-FY24-11012023-001331-A	<1	FT-FY24-11012023-001331-B	<1	
WS- 001332	2/21/2023	2/21/2024	Ground Floor	Cooler	In hallway adjacent to room G15	High Left	WF-02212023-001332	12/5/2023	FT-FY24-11012023-001332-A	<1	FT-FY24-11012023-001332-B	<1
WS- 001333	2/21/2023	2/21/2024	Ground Floor	Cooler	In hallway adjacent to room G15	Low Right	WF-02212023-001333	12/5/2023	FT-FY24-11012023-001333-A	<1	FT-FY24-11012023-001333-B	<1
WS- 001334	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 103	WF-02212023-001334	12/5/2023	FT-FY24-11012023-001334-A	<1	FT-FY24-11012023-001334-B	<1	
WS- 001335	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 103	WF-08142023-001335	12/5/2023	FT-FY24-11012023-001335-A	<1	FT-FY24-11012023-001335-B	<1	
WS- 001336	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to room 105	Low Right	WF-02212023-001336	12/5/2023	FT-FY24-11012023-001336-A	<1	FT-FY24-11012023-001336-B	<1
WS- 001337	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to room 105	High Left	WF-02212023-001337	12/5/2023	FT-FY24-11012023-001337-A	<1	FT-FY24-11012023-001337-B	<1
WS- 001338	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 111	WF-02212023-001338	12/5/2023	FT-FY24-11012023-001338-A	<1	FT-FY24-11012023-001338-B	<1	
WS- 001339	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 111	WF-08142023-001339	12/5/2023	FT-FY24-11012023-001339-A	3.6	FT-FY24-11012023-001339-B	1.0	
WS- 001340	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 113	WF-02212023-001340	12/5/2023	FT-FY24-11012023-001340-A	<1	FT-FY24-11012023-001340-B	<1	
WS- 001341	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 113	WF-08142023-001341	12/5/2023	FT-FY24-11012023-001341-A	<1	FT-FY24-11012023-001341-B	<1	
WS- 001343	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 114	WF-08142023-001343	12/5/2023	FT-FY24-11012023-001343-A	2.9	FT-FY24-11012023-001343-B	<1	
WS- 001345	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 115	WF-08142023-001345	12/5/2023	FT-FY24-11012023-001345-A	2.0	FT-FY24-11012023-001345-B	<1	
WS- 001346	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 136	WF-02212023-001346	12/5/2023	FT-FY24-11012023-001346-A	<1	FT-FY24-11012023-001346-B	<1	
WS- 001347	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 136	WF-08142023-001347	12/5/2023	FT-FY24-11012023-001347-A	1.8	FT-FY24-11012023-001347-B	<1	
WS- 001348	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 135	WF-02212023-001348	12/5/2023	FT-FY24-11012023-001348-A	<1	FT-FY24-11012023-001348-B	<1	
WS- 001349	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 135	WF-08142023-001349	12/5/2023	FT-FY24-11012023-001349-A	2.1	FT-FY24-11012023-001349-B	<1	
WS- 001350	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 107	WF-02212023-001350	12/5/2023	FT-FY24-11012023-001350-A	<1	FT-FY24-11012023-001350-B	<1	
WS- 001351	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 107	WF-08142023-001351	12/5/2023	FT-FY24-11012023-001351-A	1.7	FT-FY24-11012023-001351-B	<1	

WS-001352	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to room 148	High Left	WF-02212023-001352	12/5/2023	FT-FY24-11012023-001352-A	<1	FT-FY24-11012023-001352-B	<1
WS-001353	2/21/2023	2/21/2024	1	Cooler	In hallway adjacent to room 148	Low Right	WF-02212023-001353	12/5/2023	FT-FY24-11012023-001353-A	<1	FT-FY24-11012023-001353-B	<1
WS-001354	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 123		WF-02212023-001354	12/5/2023	FT-FY24-11012023-001354-A	<1	FT-FY24-11012023-001354-B	<1
WS-001356	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 125		WF-02212023-001356	12/5/2023	FT-FY24-11012023-001356-A	<1	FT-FY24-11012023-001356-B	<1
WS-001357	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 125		WF-08142023-001357	12/5/2023	FT-FY24-11012023-001357-A	<1	FT-FY24-11012023-001357-B	<1
WS-001359	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 128		WF-08142023-001359	12/5/2023	FT-FY24-11012023-001359-A	4.3	FT-FY24-11012023-001359-B	<1
WS-001360	2/21/2023	2/21/2024	1	Combo Fountain	In classroom 131		WF-02212023-001360	12/5/2023	FT-FY24-11012023-001360-A	<1	FT-FY24-11012023-001360-B	<1
WS-001361	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 131		WF-08142023-001361	12/5/2023	FT-FY24-11012023-001361-A	2.3	FT-FY24-11012023-001361-B	<1
WS-001362	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 224		WF-02212023-001362	12/5/2023	FT-FY24-11012023-001362-A	<1	FT-FY24-11012023-001362-B	<1
WS-001364	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 225		WF-02212023-001364	12/5/2023	FT-FY24-11012023-001364-A	<1	FT-FY24-11012023-001364-B	<1
WS-001366	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 227		WF-02212023-001366	12/5/2023	FT-FY24-11012023-001366-A	<1	FT-FY24-11012023-001366-B	<1
WS-001367	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 227		WF-08142023-001367	12/5/2023	FT-FY24-11012023-001367-A	2.0	FT-FY24-11012023-001367-B	<1
WS-001368	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 229		WF-02212023-001368	12/5/2023	FT-FY24-11012023-001368-A	<1	FT-FY24-11012023-001368-B	<1
WS-001369	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 229		WF-08142023-001369	12/5/2023	FT-FY24-11012023-001369-A	<1	FT-FY24-11012023-001369-B	<1
WS-001370	2/21/2023	2/21/2024	2	Cooler	In hallway across from room 232	High Left	WF-02212023-001370	12/5/2023	FT-FY24-11012023-001370-A	<1	FT-FY24-11012023-001370-B	<1
WS-001371	2/21/2023	2/21/2024	2	Cooler	In hallway across from room 232	Low Right	WF-02212023-001371	12/5/2023	FT-FY24-11012023-001371-A	<1	FT-FY24-11012023-001371-B	<1
WS-001372	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 234		WF-02212023-001372	12/5/2023	FT-FY24-11012023-001372-A	<1	FT-FY24-11012023-001372-B	<1
WS-001373	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 234		WF-08142023-001373	12/5/2023	FT-FY24-11012023-001373-A	2.4	FT-FY24-11012023-001373-B	<1
WS-001374	2/21/2023	2/21/2024	2	Break Room	In break room 235		WF-02212023-001374	12/5/2023	FT-FY24-11012023-001374-A	1.5	FT-FY24-11012023-001374-B	<1
WS-001376	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 207		WF-08142023-001376	12/5/2023	FT-FY24-11012023-001376-A	<1	FT-FY24-11012023-001376-B	<1
WS-001378	2/21/2023	2/21/2024	2	Cooler	In hallway adjacent to room 205	Low Right	WF-02212023-001378	12/5/2023	FT-FY24-11012023-001378-A	<1	FT-FY24-11012023-001378-B	<1
WS-001379	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 203		WF-02212023-001379	12/5/2023	FT-FY24-11012023-001379-A	<1	FT-FY24-11012023-001379-B	<1
WS-001381	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 211		WF-02212023-001381	12/5/2023	FT-FY24-11012023-001381-A	<1	FT-FY24-11012023-001381-B	<1
WS-001382	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 211		WF-08142023-001382	12/5/2023	FT-FY24-11012023-001382-A	1.8	FT-FY24-11012023-001382-B	<1
WS-001383	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 215		WF-02212023-001383	12/5/2023	FT-FY24-11012023-001383-A	<1	FT-FY24-11012023-001383-B	<1
WS-001384	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 215		WF-08142023-001384	12/5/2023	FT-FY24-11012023-001384-A	<1	FT-FY24-11012023-001384-B	<1
WS-001385	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 222		WF-02212023-001385	12/5/2023	FT-FY24-11012023-001385-A	<1	FT-FY24-11012023-001385-B	<1
WS-001386	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 222		WF-08142023-001386	12/5/2023	FT-FY24-11012023-001386-A	<1	FT-FY24-11012023-001386-B	<1
WS-001387	2/21/2023	2/21/2024	2	Combo Fountain	In classroom 213		WF-02212023-001387	12/5/2023	FT-FY24-11012023-001387-A	<1	FT-FY24-11012023-001387-B	<1
WS-001574	2/21/2023	2/21/2024	2	Bottle Filler	In hallway across from room 232		WF-02212023-001574	12/5/2023	FT-FY24-11012023-001574-A	<1	FT-FY24-11012023-001574-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001302	12/22/2022	12/22/2023	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	Left	WF-12222022-001302	12/5/2023	FT-FY24-11012023-001302-A	<1	FT-FY24-11012023-001302-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001322	8/14/2023	8/14/2024	Ground Floor	Combo Faucet	In classroom G51	WF-08142023-001322	12/5/2023	FT-FY24-11012023-001322-A	11.1	FT-FY24-11012023-001322-B	<1

WS-001355	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 123	WF-08142023-001355	12/5/2023	FT-FY24-11012023-001355-A	12.6	FT-FY24-11012023-001355-B	<1
WS-001363	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 224	WF-08142023-001363	12/5/2023	FT-FY24-11012023-001363-A	15.3	FT-FY24-11012023-001363-B	1.2
WS-001365	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 225	WF-08142023-001365	12/5/2023	FT-FY24-11012023-001365-A	13.8	FT-FY24-11012023-001365-B	1.2
WS-001380	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 203	WF-08142023-001380	12/5/2023	FT-FY24-11012023-001380-A	16.9	FT-FY24-11012023-001380-B	<1
WS-001388	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 213	WF-08142023-001388	12/5/2023	FT-FY24-11012023-001388-A	19.5	FT-FY24-11012023-001388-B	1.7