



Wheatley Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001304	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G08	WF-09082020-001304	3/17/2021	FT-FY21-032021-001304-A	<1	FT-FY21-032021-001304-B	<1	
WS-001305	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G08	WF-03082021-001305	3/17/2021	FT-FY21-032021-001305-A	<1	FT-FY21-032021-001305-B	<1	
WS-001306	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G31	WF-09082020-001306	3/17/2021	FT-FY21-032021-001306-A	<1	FT-FY21-032021-001306-B	<1	
WS-001307	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G31	WF-03082021-001307	3/17/2021	FT-FY21-032021-001307-A	<1	FT-FY21-032021-001307-B	<1	
WS-001310	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G05	WF-09082020-001310	3/17/2021	FT-FY21-032021-001310-A	<1	FT-FY21-032021-001310-B	<1	
WS-001311	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G05	WF-03082021-001311	3/17/2021	FT-FY21-032021-001311-A	<1	FT-FY21-032021-001311-B	<1	
WS-001312	3/8/2021	3/8/2022	Ground Floor	Break Room	In staff lounge G33	WF-03082021-001312	3/17/2021	FT-FY21-032021-001312-A	<1	FT-FY21-032021-001312-B	<1	
WS-001315	3/8/2021	3/8/2022	Ground Floor	Health Suite	In health suite G41B	WF-03082021-001315	3/17/2021	FT-FY21-032021-001315-A	<1	FT-FY21-032021-001315-B	<1	
WS-001319	3/8/2021	3/8/2022	Ground Floor	Cooler	In hallway adjacent to room G46	High Left	WF-03082021-001319	3/17/2021	FT-FY21-032021-001319-A	<1	FT-FY21-032021-001319-B	<1
WS-001320	3/8/2021	3/8/2022	Ground Floor	Cooler	In hallway adjacent to room G46	Low Right	WF-03082021-001320	3/17/2021	FT-FY21-032021-001320-A	<1	FT-FY21-032021-001320-B	<1
WS-001321	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G51	WF-03082021-001321	3/17/2021	FT-FY21-032021-001321-A	<1	FT-FY21-032021-001321-B	<1	
WS-001322	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G51	WF-09082020-001322	3/17/2021	FT-FY21-032021-001322-A	1.4	FT-FY21-032021-001322-B	<1	
WS-001323	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G54	WF-03082021-001323	3/17/2021	FT-FY21-032021-001323-A	<1	FT-FY21-032021-001323-B	<1	
WS-001324	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G54	WF-09082020-001324	3/17/2021	FT-FY21-032021-001324-A	1.4	FT-FY21-032021-001324-B	<1	
WS-001326	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G57	WF-03082021-001326	3/17/2021	FT-FY21-032021-001326-A	<1	FT-FY21-032021-001326-B	<1	
WS-001328	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G58	WF-03082021-001328	3/17/2021	FT-FY21-032021-001328-A	<1	FT-FY21-032021-001328-B	<1	
WS-001329	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G58	WF-09082020-001329	3/17/2021	FT-FY21-032021-001329-A	<1	FT-FY21-032021-001329-B	<1	
WS-001330	3/8/2021	3/8/2022	Ground Floor	Combo Fountain	In classroom G59	WF-03082021-001330	3/17/2021	FT-FY21-032021-001330-A	<1	FT-FY21-032021-001330-B	<1	
WS-001331	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G59	WF-09082020-001331	3/17/2021	FT-FY21-032021-001331-A	<1	FT-FY21-032021-001331-B	<1	
WS-001332	3/8/2021	3/8/2022	Ground Floor	Cooler	In hallway adjacent to room G15	High Left	WF-03082021-001332	3/17/2021	FT-FY21-032021-001332-A	<1	FT-FY21-032021-001332-B	<1
WS-001333	3/8/2021	3/8/2022	Ground Floor	Cooler	In hallway adjacent to room G15	Low Right	WF-03082021-001333	3/17/2021	FT-FY21-032021-001333-A	<1	FT-FY21-032021-001333-B	<1
WS-001334	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 103	WF-03082021-001334	3/17/2021	FT-FY21-032021-001334-A	<1	FT-FY21-032021-001334-B	<1	
WS-001335	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 103	WF-09082020-001335	3/17/2021	FT-FY21-032021-001335-A	<1	FT-FY21-032021-001335-B	<1	
WS-001338	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 111	WF-03082021-001338	3/17/2021	FT-FY21-032021-001338-A	<1	FT-FY21-032021-001338-B	<1	
WS-001339	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 111	WF-09082020-001339	3/17/2021	FT-FY21-032021-001339-A	<1	FT-FY21-032021-001339-B	<1	
WS-001340	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 113	WF-03082021-001340	3/17/2021	FT-FY21-032021-001340-A	<1	FT-FY21-032021-001340-B	<1	
WS-001341	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 113	WF-09082020-001341	3/17/2021	FT-FY21-032021-001341-A	<1	FT-FY21-032021-001341-B	<1	
WS-001342	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 114	WF-03082021-001342	3/17/2021	FT-FY21-032021-001342-A	<1	FT-FY21-032021-001342-B	<1	
WS-001343	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 114	WF-09082020-001343	3/17/2021	FT-FY21-032021-001343-A	<1	FT-FY21-032021-001343-B	<1	
WS-001345	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 115	WF-09082020-001345	3/17/2021	FT-FY21-032021-001345-A	<1	FT-FY21-032021-001345-B	<1	
WS-001346	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 136	WF-03082021-001346	3/17/2021	FT-FY21-032021-001346-A	<1	FT-FY21-032021-001346-B	<1	
WS-001347	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 136	WF-09082020-001347	3/17/2021	FT-FY21-032021-001347-A	1.0	FT-FY21-032021-001347-B	<1	

WS-001348	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 135		WF-03082021-001348	3/17/2021	FT-FY21-032021-001348-A	<1	FT-FY21-032021-001348-B	<1
WS-001349	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 135		WF-09082020-001349	3/17/2021	FT-FY21-032021-001349-A	<1	FT-FY21-032021-001349-B	<1
WS-001350	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 107		WF-03082021-001350	3/17/2021	FT-FY21-032021-001350-A	<1	FT-FY21-032021-001350-B	<1
WS-001351	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 107		WF-09082020-001351	3/17/2021	FT-FY21-032021-001351-A	<1	FT-FY21-032021-001351-B	<1
WS-001352	3/8/2021	3/8/2022	1	Cooler	In hallway adjacent to room 148	High Left	WF-03082021-001352	3/17/2021	FT-FY21-032021-001352-A	<1	FT-FY21-032021-001352-B	<1
WS-001353	3/8/2021	3/8/2022	1	Cooler	In hallway adjacent to room 148	Low Right	WF-03082021-001353	3/17/2021	FT-FY21-032021-001353-A	<1	FT-FY21-032021-001353-B	<1
WS-001354	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 123		WF-03082021-001354	3/17/2021	FT-FY21-032021-001354-A	<1	FT-FY21-032021-001354-B	<1
WS-001355	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 123		WF-09082020-001355	3/17/2021	FT-FY21-032021-001355-A	<1	FT-FY21-032021-001355-B	<1
WS-001356	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 125		WF-03082021-001356	3/17/2021	FT-FY21-032021-001356-A	<1	FT-FY21-032021-001356-B	<1
WS-001357	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 125		WF-09082020-001357	3/17/2021	FT-FY21-032021-001357-A	<1	FT-FY21-032021-001357-B	<1
WS-001358	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 128		WF-03082021-001358	3/17/2021	FT-FY21-032021-001358-A	<1	FT-FY21-032021-001358-B	<1
WS-001359	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 128		WF-09082020-001359	3/17/2021	FT-FY21-032021-001359-A	<1	FT-FY21-032021-001359-B	<1
WS-001360	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 131		WF-03082021-001360	3/17/2021	FT-FY21-032021-001360-A	<1	FT-FY21-032021-001360-B	<1
WS-001361	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 131		WF-09082020-001361	3/17/2021	FT-FY21-032021-001361-A	<1	FT-FY21-032021-001361-B	<1
WS-001362	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 224		WF-03082021-001362	3/17/2021	FT-FY21-032021-001362-A	<1	FT-FY21-032021-001362-B	<1
WS-001363	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 224		WF-09082020-001363	3/17/2021	FT-FY21-032021-001363-A	1.1	FT-FY21-032021-001363-B	<1
WS-001364	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 225		WF-03082021-001364	3/17/2021	FT-FY21-032021-001364-A	<1	FT-FY21-032021-001364-B	<1
WS-001365	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 225		WF-09082020-001365	3/17/2021	FT-FY21-032021-001365-A	<1	FT-FY21-032021-001365-B	<1
WS-001366	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 227		WF-03082021-001366	3/17/2021	FT-FY21-032021-001366-A	<1	FT-FY21-032021-001366-B	<1
WS-001367	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 227		WF-09082020-001367	3/17/2021	FT-FY21-032021-001367-A	<1	FT-FY21-032021-001367-B	<1
WS-001368	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 229		WF-03082021-001368	3/17/2021	FT-FY21-032021-001368-A	<1	FT-FY21-032021-001368-B	<1
WS-001369	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 229		WF-09082020-001369	3/17/2021	FT-FY21-032021-001369-A	<1	FT-FY21-032021-001369-B	<1
WS-001370	3/8/2021	3/8/2022	2	Cooler	In hallway across from room 232	High Left	WF-03082021-001370	3/17/2021	FT-FY21-032021-001370-A	<1	FT-FY21-032021-001370-B	<1
WS-001371	3/8/2021	3/8/2022	2	Cooler	In hallway across from room 232	Low Right	WF-03082021-001371	3/17/2021	FT-FY21-032021-001371-A	<1	FT-FY21-032021-001371-B	<1
WS-001372	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 234		WF-03082021-001372	3/17/2021	FT-FY21-032021-001372-A	<1	FT-FY21-032021-001372-B	<1
WS-001373	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 234		WF-09082020-001373	3/17/2021	FT-FY21-032021-001373-A	<1	FT-FY21-032021-001373-B	<1
WS-001374	3/8/2021	3/8/2022	2	Break Room	In break room 235		WF-03082021-001374	3/17/2021	FT-FY21-032021-001374-A	<1	FT-FY21-032021-001374-B	<1
WS-001375	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 207		WF-03082021-001375	3/17/2021	FT-FY21-032021-001375-A	<1	FT-FY21-032021-001375-B	<1
WS-001376	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 207		WF-09082020-001376	3/17/2021	FT-FY21-032021-001376-A	<1	FT-FY21-032021-001376-B	<1
WS-001378	3/8/2021	3/8/2022	2	Cooler	In hallway adjacent to room 205	Low Right	WF-03082021-001378	3/17/2021	FT-FY21-032021-001378-A	<1	FT-FY21-032021-001378-B	<1
WS-001379	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 203		WF-03082021-001379	3/17/2021	FT-FY21-032021-001379-A	<1	FT-FY21-032021-001379-B	<1
WS-001380	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 203		WF-09082020-001380	3/17/2021	FT-FY21-032021-001380-A	3.4	FT-FY21-032021-001380-B	1.3
WS-001381	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 211		WF-03082021-001381	3/17/2021	FT-FY21-032021-001381-A	<1	FT-FY21-032021-001381-B	<1
WS-001382	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 211		WF-09082020-001382	3/17/2021	FT-FY21-032021-001382-A	<1	FT-FY21-032021-001382-B	<1
WS-001383	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 215		WF-03082021-001383	3/17/2021	FT-FY21-032021-001383-A	<1	FT-FY21-032021-001383-B	<1
WS-001384	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 215		WF-09082020-001384	3/17/2021	FT-FY21-032021-001384-A	<1	FT-FY21-032021-001384-B	<1
WS-001385	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 222		WF-03082021-001385	3/17/2021	FT-FY21-032021-001385-A	<1	FT-FY21-032021-001385-B	<1
WS-001386	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 222		WF-09082020-001386	3/17/2021	FT-FY21-032021-001386-A	<1	FT-FY21-032021-001386-B	<1

WS- 001387	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 213	WF-03082021-001387	3/17/2021	FT-FY21-032021-001387-A	<1	FT-FY21-032021-001387-B	<1
WS- 001388	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 213	WF-09082020-001388	3/17/2021	FT-FY21-032021-001388-A	1.0	FT-FY21-032021-001388-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001302	1/18/2021	1/18/2022	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-01182021-001302	3/17/2021	FT-FY21-032021-001302-A	1.0	FT-FY21-032021-001302-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001327	9/8/2020	9/8/2021	Ground Floor	Combo Faucet	In classroom G57	WF-09082020-001327	3/17/2021	FT-FY21-032021-001327-A	<1	FT-FY21-032021-001327-B	5.3