



# Wheatley EC Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001304	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G08	WF-09172019-001304	11/19/2019	FT-FY20-112019-001304-A	<1	FT-FY20-112019-001304-B	<1
WS- 001305	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G08	WF-03252019-001305	11/19/2019	FT-FY20-112019-001305-A	<1	FT-FY20-112019-001305-B	<1
WS- 001306	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G31	WF-09172019-001306	11/19/2019	FT-FY20-112019-001306-A	<1	FT-FY20-112019-001306-B	<1
WS- 001307	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G31	WF-03252019-001307	11/19/2019	FT-FY20-112019-001307-A	<1	FT-FY20-112019-001307-B	<1
WS- 001310	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G05	WF-09172019-001310	11/19/2019	FT-FY20-112019-001310-A	<1	FT-FY20-112019-001310-B	<1
WS- 001311	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G05	WF-03252019-001311	11/19/2019	FT-FY20-112019-001311-A	<1	FT-FY20-112019-001311-B	<1
WS- 001312	3/25/2019	3/25/2020	Ground Floor	Break Room	In staff lounge G33	WF-03252019-001312	11/19/2019	FT-FY20-112019-001312-A	<1	FT-FY20-112019-001312-B	<1
WS- 001315	3/25/2019	3/25/2020	Ground Floor	Health Suite	In health suite G41B	WF-03252019-001315	11/19/2019	FT-FY20-112019-001315-A	2.4	FT-FY20-112019-001315-B	<1
WS- 001319	3/25/2019	3/25/2020	Ground Floor	Cooler	In hallway adjacent to room G46 High Left	WF-03252019-001319	11/19/2019	FT-FY20-112019-001319-A	<1	FT-FY20-112019-001319-B	<1
WS- 001320	3/25/2019	3/25/2020	Ground Floor	Cooler	In hallway adjacent to room G46 Low Right	WF-03252019-001320	11/19/2019	FT-FY20-112019-001320-A	<1	FT-FY20-112019-001320-B	<1
WS- 001321	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G51	WF-03252019-001321	11/19/2019	FT-FY20-112019-001321-A	<1	FT-FY20-112019-001321-B	<1
WS- 001322	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G51	WF-09172019-001322	11/19/2019	FT-FY20-112019-001322-A	<1	FT-FY20-112019-001322-B	<1
WS- 001323	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G54	WF-03252019-001323	11/19/2019	FT-FY20-112019-001323-A	<1	FT-FY20-112019-001323-B	<1
WS- 001324	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G54	WF-09172019-001324	11/19/2019	FT-FY20-112019-001324-A	2.4	FT-FY20-112019-001324-B	<1
WS- 001326	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G57	WF-03252019-001326	11/19/2019	FT-FY20-112019-001326-A	<1	FT-FY20-112019-001326-B	<1
WS- 001327	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G57	WF-09172019-001327	11/19/2019	FT-FY20-112019-001327-A	<1	FT-FY20-112019-001327-B	<1
WS- 001328	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G58	WF-03252019-001328	11/19/2019	FT-FY20-112019-001328-A	1	FT-FY20-112019-001328-B	<1
WS- 001329	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G58	WF-09172019-001329	11/19/2019	FT-FY20-112019-001329-A	<1	FT-FY20-112019-001329-B	<1
WS- 001330	3/25/2019	3/25/2020	Ground Floor	Combo Fountain	In classroom G59	WF-03252019-001330	11/19/2019	FT-FY20-112019-001330-A	<1	FT-FY20-112019-001330-B	<1
WS- 001331	9/17/2019	9/17/2020	Ground Floor	Combo Faucet	In classroom G59	WF-09172019-001331	11/19/2019	FT-FY20-112019-001331-A	<1	FT-FY20-112019-001331-B	<1
WS- 001332	3/25/2019	3/25/2020	Ground Floor	Cooler	In hallway adjacent to room G15 High Left	WF-03252019-001332	11/19/2019	FT-FY20-112019-001332-A	<1	FT-FY20-112019-001332-B	<1
WS- 001333	3/25/2019	3/25/2020	Ground Floor	Cooler	In hallway adjacent to room G15 Low Right	WF-03252019-001333	11/19/2019	FT-FY20-112019-001333-A	<1	FT-FY20-112019-001333-B	<1
WS- 001334	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 103	WF-03252019-001334	11/19/2019	FT-FY20-112019-001334-A	<1	FT-FY20-112019-001334-B	<1
WS- 001335	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 103	WF-09172019-001335	11/19/2019	FT-FY20-112019-001335-A	<1	FT-FY20-112019-001335-B	<1
WS- 001336	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent to room 105 Low Right	WF-03252019-001336	11/19/2019	FT-FY20-112019-001336-A	<1	FT-FY20-112019-001336-B	<1
WS- 001337	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent to room 105 High Left	WF-03252019-001337	11/19/2019	FT-FY20-112019-001337-A	<1	FT-FY20-112019-001337-B	<1
WS- 001338	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 111	WF-03252019-001338	11/19/2019	FT-FY20-112019-001338-A	<1	FT-FY20-112019-001338-B	<1
WS- 001339	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 111	WF-09172019-001339	11/19/2019	FT-FY20-112019-001339-A	<1	FT-FY20-112019-001339-B	<1
WS- 001340	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 113	WF-03252019-001340	11/19/2019	FT-FY20-112019-001340-A	<1	FT-FY20-112019-001340-B	<1
WS- 001341	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 113	WF-09172019-001341	11/19/2019	FT-FY20-112019-001341-A	<1	FT-FY20-112019-001341-B	<1
WS- 001342	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 114	WF-03252019-001342	11/19/2019	FT-FY20-112019-001342-A	<1	FT-FY20-112019-001342-B	<1
WS- 001343	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 114	WF-09172019-001343	11/19/2019	FT-FY20-112019-001343-A	<1	FT-FY20-112019-001343-B	<1
WS- 001344	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 115	WF-03252019-001344	11/19/2019	FT-FY20-112019-001344-A	<1	FT-FY20-112019-001344-B	<1

WS- 001345	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 115		WF-09172019-001345	11/19/2019	FT-FY20-112019-001345-A	<1	FT-FY20-112019-001345-B	<1
WS- 001346	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 136		WF-03252019-001346	11/19/2019	FT-FY20-112019-001346-A	<1	FT-FY20-112019-001346-B	<1
WS- 001347	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 136		WF-09172019-001347	11/19/2019	FT-FY20-112019-001347-A	<1	FT-FY20-112019-001347-B	<1
WS- 001348	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 135		WF-03252019-001348	11/19/2019	FT-FY20-112019-001348-A	<1	FT-FY20-112019-001348-B	<1
WS- 001349	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 135		WF-09172019-001349	11/19/2019	FT-FY20-112019-001349-A	1.3	FT-FY20-112019-001349-B	<1
WS- 001350	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 107		WF-03252019-001350	11/19/2019	FT-FY20-112019-001350-A	<1	FT-FY20-112019-001350-B	<1
WS- 001351	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 107		WF-09172019-001351	11/19/2019	FT-FY20-112019-001351-A	<1	FT-FY20-112019-001351-B	<1
WS- 001352	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent to room 148	High Left	WF-03252019-001352	11/19/2019	FT-FY20-112019-001352-A	<1	FT-FY20-112019-001352-B	<1
WS- 001353	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent to room 148	Low Right	WF-03252019-001353	11/19/2019	FT-FY20-112019-001353-A	<1	FT-FY20-112019-001353-B	<1
WS- 001354	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 123		WF-03252019-001354	11/19/2019	FT-FY20-112019-001354-A	<1	FT-FY20-112019-001354-B	<1
WS- 001355	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 123		WF-09172019-001355	11/19/2019	FT-FY20-112019-001355-A	3.1	FT-FY20-112019-001355-B	<1
WS- 001356	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 125		WF-03252019-001356	11/19/2019	FT-FY20-112019-001356-A	<1	FT-FY20-112019-001356-B	<1
WS- 001357	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 125		WF-09172019-001357	11/19/2019	FT-FY20-112019-001357-A	<1	FT-FY20-112019-001357-B	<1
WS- 001359	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 128		WF-09172019-001359	11/19/2019	FT-FY20-112019-001359-A	<1	FT-FY20-112019-001359-B	<1
WS- 001360	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 131		WF-03252019-001360	11/19/2019	FT-FY20-112019-001360-A	<1	FT-FY20-112019-001360-B	<1
WS- 001361	9/17/2019	9/17/2020	1	Combo Faucet	In classroom 131		WF-09172019-001361	11/19/2019	FT-FY20-112019-001361-A	<1	FT-FY20-112019-001361-B	<1
WS- 001362	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 224		WF-03252019-001362	11/19/2019	FT-FY20-112019-001362-A	<1	FT-FY20-112019-001362-B	<1
WS- 001363	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 224		WF-09172019-001363	11/19/2019	FT-FY20-112019-001363-A	1.1	FT-FY20-112019-001363-B	<1
WS- 001364	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 225		WF-03252019-001364	11/19/2019	FT-FY20-112019-001364-A	<1	FT-FY20-112019-001364-B	<1
WS- 001365	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 225		WF-09172019-001365	11/19/2019	FT-FY20-112019-001365-A	1.1	FT-FY20-112019-001365-B	<1
WS- 001366	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 227		WF-03252019-001366	11/19/2019	FT-FY20-112019-001366-A	<1	FT-FY20-112019-001366-B	<1
WS- 001367	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 227		WF-09172019-001367	11/19/2019	FT-FY20-112019-001367-A	<1	FT-FY20-112019-001367-B	<1
WS- 001368	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 229		WF-03252019-001368	11/19/2019	FT-FY20-112019-001368-A	<1	FT-FY20-112019-001368-B	<1
WS- 001369	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 229		WF-09172019-001369	11/19/2019	FT-FY20-112019-001369-A	<1	FT-FY20-112019-001369-B	<1
WS- 001370	3/25/2019	3/25/2020	2	Cooler	In hallway across from room 232	High Left	WF-03252019-001370	11/19/2019	FT-FY20-112019-001370-A	<1	FT-FY20-112019-001370-B	<1
WS- 001371	3/25/2019	3/25/2020	2	Cooler	In hallway across from room 232	Low Right	WF-03252019-001371	11/19/2019	FT-FY20-112019-001371-A	<1	FT-FY20-112019-001371-B	<1
WS- 001372	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 234		WF-03252019-001372	11/19/2019	FT-FY20-112019-001372-A	<1	FT-FY20-112019-001372-B	<1
WS- 001373	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 234		WF-09172019-001373	11/19/2019	FT-FY20-112019-001373-A	<1	FT-FY20-112019-001373-B	<1
WS- 001374	3/25/2019	3/25/2020	2	Break Room	In break room 235		WF-03252019-001374	11/19/2019	FT-FY20-112019-001374-A	<1	FT-FY20-112019-001374-B	<1
WS- 001375	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 207		WF-03252019-001375	11/19/2019	FT-FY20-112019-001375-A	<1	FT-FY20-112019-001375-B	<1
WS- 001376	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 207		WF-09172019-001376	11/19/2019	FT-FY20-112019-001376-A	<1	FT-FY20-112019-001376-B	<1
WS- 001378	3/25/2019	3/25/2020	2	Cooler	In hallway adjacent to room 205	Low Right	WF-03252019-001378	11/19/2019	FT-FY20-112019-001378-A	<1	FT-FY20-112019-001378-B	<1
WS- 001379	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 203		WF-03252019-001379	11/19/2019	FT-FY20-112019-001379-A	<1	FT-FY20-112019-001379-B	<1
WS- 001380	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 203		WF-09172019-001380	11/19/2019	FT-FY20-112019-001380-A	1	FT-FY20-112019-001380-B	<1
WS- 001381	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 211		WF-03252019-001381	11/19/2019	FT-FY20-112019-001381-A	<1	FT-FY20-112019-001381-B	<1
WS- 001382	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 211		WF-09172019-001382	11/19/2019	FT-FY20-112019-001382-A	<1	FT-FY20-112019-001382-B	<1
WS- 001383	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 215		WF-03252019-001383	11/19/2019	FT-FY20-112019-001383-A	<1	FT-FY20-112019-001383-B	<1
WS- 001384	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 215		WF-09172019-001384	11/19/2019	FT-FY20-112019-001384-A	<1	FT-FY20-112019-001384-B	<1
WS- 001385	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 222		WF-03252019-001385	11/19/2019	FT-FY20-112019-001385-A	<1	FT-FY20-112019-001385-B	<1

WS- 001386	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 222	WF-09172019-001386	11/19/2019	FT-FY20-112019-001386-A	<1	FT-FY20-112019-001386-B	<1
WS- 001387	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 213	WF-03252019-001387	11/19/2019	FT-FY20-112019-001387-A	<1	FT-FY20-112019-001387-B	<1
WS- 001388	9/17/2019	9/17/2020	2	Combo Faucet	In classroom 213	WF-09172019-001388	11/19/2019	FT-FY20-112019-001388-A	<1	FT-FY20-112019-001388-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001302	7/8/2019	7/8/2020	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-07082019-001302	11/19/2019	FT-FY20-112019-001302-A	<1	FT-FY20-112019-001302-B	<1