



WHEATLEY EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001301	8/21/2016	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door Mid	FT-72016-001301-A	< 1	FT-72016-001301-B	< 1
2	WHEATLEY EDUCATIONAL CAMPUS	WS- 001302	8/21/2016	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door Left	FT-72016-001302-A	< 1	FT-72016-001302-B	< 1
3	WHEATLEY EDUCATIONAL CAMPUS	WS- 001305	8/21/2016	Ground Floor	Fountain	In Classroom G08	FT-82016-001305-A	< 1	FT-82016-001305-B	< 1
4	WHEATLEY EDUCATIONAL CAMPUS	WS- 001307	8/21/2016	Ground Floor	Fountain	In classroom G31	FT-82016-001307-A	< 1	FT-82016-001307-B	< 1
5	WHEATLEY EDUCATIONAL CAMPUS	WS- 001311	8/21/2016	Ground Floor	Fountain	In classroom G05	FT-82016-001311-A	< 1	FT-82016-001311-B	< 1
6	WHEATLEY EDUCATIONAL CAMPUS	WS- 001315	8/21/2016	Ground Floor	Health Suite	In health suite G41B	FT-82016-001315-A	< 1	FT-82016-001315-B	< 1
7	WHEATLEY EDUCATIONAL CAMPUS	WS- 001319	8/21/2016	Ground Floor	Cooler	In hallway adjacent to room G46 High Left	FT-82016-001319-A	< 1	FT-82016-001319-B	< 1
8	WHEATLEY EDUCATIONAL CAMPUS	WS- 001320	8/21/2016	Ground Floor	Cooler	In hallway adjacent to room G46 Low Right	FT-82016-001320-A	< 1	FT-82016-001320-B	< 1
9	WHEATLEY EDUCATIONAL CAMPUS	WS- 001321	8/21/2016	Ground Floor	Fountain	In classroom G51	FT-82016-001321-A	< 1	FT-82016-001321-B	< 1
10	WHEATLEY EDUCATIONAL CAMPUS	WS- 001323	8/21/2016	Ground Floor	Fountain	In classroom G54	FT-82016-001323-A	< 1	FT-82016-001323-B	< 1
11	WHEATLEY EDUCATIONAL CAMPUS	WS- 001326	8/21/2016	Ground Floor	Fountain	In classroom G57	FT-82016-001326-A	< 1	FT-82016-001326-B	< 1
12	WHEATLEY EDUCATIONAL CAMPUS	WS- 001328	8/21/2016	Ground Floor	Fountain	In classroom G58	FT-82016-001328-A	< 1	FT-82016-001328-B	< 1
13	WHEATLEY EDUCATIONAL CAMPUS	WS- 001330	8/21/2016	Ground Floor	Fountain	In classroom G59	FT-82016-001330-A	< 1	FT-82016-001330-B	< 1
14	WHEATLEY EDUCATIONAL CAMPUS	WS- 001332	8/21/2016	Ground Floor	Cooler	In hallway adjacent to room G15 High Left	FT-82016-001332-A	< 1	FT-82016-001332-B	< 1
15	WHEATLEY EDUCATIONAL CAMPUS	WS- 001333	8/21/2016	Ground Floor	Cooler	In hallway adjacent to room G15 Low Right	FT-82016-001333-A	< 1	FT-82016-001333-B	< 1
16	WHEATLEY EDUCATIONAL CAMPUS	WS- 001334	8/21/2016	1	Fountain	In classroom 103	FT-82016-001334-A	< 1	FT-82016-001334-B	< 1
17	WHEATLEY EDUCATIONAL CAMPUS	WS- 001336	8/21/2016	1	Cooler	In hallway adjacent to room 105 Low Right	FT-82016-001336-A	< 1	FT-82016-001336-B	< 1
18	WHEATLEY EDUCATIONAL CAMPUS	WS- 001337	8/21/2016 10/10/2016	1	Cooler	In hallway adjacent to room 105 High Left	FT-82016-001337-A Re-test A	1.3 < 1	FT-82016-001337-B Re-test B	< 1 < 1
19	WHEATLEY EDUCATIONAL CAMPUS	WS- 001338	8/21/2016	1	Fountain	In classroom 111	FT-82016-001338-A	< 1	FT-82016-001338-B	< 1
20	WHEATLEY EDUCATIONAL CAMPUS	WS- 001340	8/21/2016	1	Fountain	In classroom 113	FT-72016-001340-A	< 1	FT-72016-001340-B	< 1
21	WHEATLEY EDUCATIONAL CAMPUS	WS- 001342	8/21/2016	1	Fountain	In classroom 114	FT-72016-001342-A	< 1	FT-72016-001342-B	< 1
22	WHEATLEY EDUCATIONAL CAMPUS	WS- 001344	8/21/2016	1	Fountain	In classroom 115	FT-82016-001344-A	< 1	FT-82016-001344-B	< 1
23	WHEATLEY EDUCATIONAL CAMPUS	WS- 001346	8/21/2016	1	Fountain	In classroom 107	FT-82016-001346-A	< 1	FT-82016-001346-B	< 1
24	WHEATLEY EDUCATIONAL CAMPUS	WS- 001348	8/21/2016	1	Fountain	In classroom 135	FT-82016-001348-A	< 1	FT-82016-001348-B	< 1
25	WHEATLEY EDUCATIONAL CAMPUS	WS- 001350	8/21/2016	1	Fountain	In classroom 107	FT-82016-001350-A	< 1	FT-82016-001350-B	< 1
26	WHEATLEY EDUCATIONAL CAMPUS	WS- 001352	8/21/2016	1	Cooler	In hallway adjacent to room 148 High Left	FT-82016-001352-A	< 1	FT-82016-001352-B	< 1
27	WHEATLEY EDUCATIONAL CAMPUS	WS- 001353	8/21/2016	1	Cooler	In hallway adjacent to room 148 Low Right	FT-82016-001353-A	< 1	FT-82016-001353-B	< 1
28	WHEATLEY EDUCATIONAL CAMPUS	WS- 001354	8/21/2016	1	Fountain	In classroom 123	FT-82016-001354-A	< 1	FT-82016-001354-B	< 1
29	WHEATLEY EDUCATIONAL CAMPUS	WS- 001356	8/21/2016	1	Fountain	In classroom 125	FT-72016-001356-A	< 1	FT-72016-001356-B	< 1
30	WHEATLEY EDUCATIONAL CAMPUS	WS- 001358	8/21/2016	1	Fountain	In classroom 128	FT-82016-001358-A	< 1	FT-82016-001358-B	< 1
31	WHEATLEY EDUCATIONAL CAMPUS	WS- 001360	8/21/2016	1	Fountain	In classroom 131	FT-82016-001360-A	< 1	FT-82016-001360-B	< 1
32	WHEATLEY EDUCATIONAL CAMPUS	WS- 001362	8/21/2016	2	Fountain	In classroom 224	FT-82016-001362-A	< 1	FT-82016-001362-B	< 1
33	WHEATLEY EDUCATIONAL CAMPUS	WS- 001364	8/21/2016	2	Fountain	In classroom 225	FT-82016-001364-A	< 1	FT-82016-001364-B	< 1
34	WHEATLEY EDUCATIONAL CAMPUS	WS- 001366	8/21/2016	2	Fountain	In classroom 227	FT-82016-001366-A	< 1	FT-82016-001366-B	< 1
35	WHEATLEY EDUCATIONAL CAMPUS	WS- 001368	8/21/2016	2	Fountain	In classroom 229	FT-72016-001368-A	< 1	FT-72016-001368-B	< 1
36	WHEATLEY EDUCATIONAL CAMPUS	WS- 001370	8/21/2016	2	Cooler	In hallway across from room 232 High Left	FT-82016-001370-A	< 1	FT-82016-001370-B	< 1
37	WHEATLEY EDUCATIONAL CAMPUS	WS- 001371	8/21/2016	2	Cooler	In hallway across from room 232 Low Right	FT-82016-001371-A	< 1	FT-82016-001371-B	< 1
38	WHEATLEY EDUCATIONAL CAMPUS	WS- 001372	8/21/2016	2	Fountain	In classroom 234	FT-82016-001372-A	< 1	FT-82016-001372-B	< 1
39	WHEATLEY EDUCATIONAL CAMPUS	WS- 001375	8/21/2016	2	Fountain	In classroom 207	FT-82016-001375-A	< 1	FT-82016-001375-B	< 1
40	WHEATLEY EDUCATIONAL CAMPUS	WS- 001377	8/21/2016	2	Cooler	In hallway adjacent to room 205 High Left	FT-82016-001377-A	< 1	FT-82016-001377-B	< 1
41	WHEATLEY EDUCATIONAL CAMPUS	WS- 001378	8/21/2016	2	Cooler	In hallway adjacent to room 205 Low Right	FT-82016-001378-A	< 1	FT-82016-001378-B	< 1
42	WHEATLEY EDUCATIONAL CAMPUS	WS- 001379	8/21/2016	2	Fountain	In classroom 203	FT-82016-001379-A	< 1	FT-82016-001379-B	< 1
43	WHEATLEY EDUCATIONAL CAMPUS	WS- 001381	8/21/2016	2	Fountain	In classroom 211	FT-82016-001381-A	< 1	FT-82016-001381-B	< 1
44	WHEATLEY EDUCATIONAL CAMPUS	WS- 001383	8/21/2016	2	Fountain	In classroom 215	FT-82016-001383-A	< 1	FT-82016-001383-B	< 1
45	WHEATLEY EDUCATIONAL CAMPUS	WS- 001385	8/21/2016	2	Fountain	In classroom 222	FT-82016-001385-A	< 1	FT-82016-001385-B	< 1
46	WHEATLEY EDUCATIONAL CAMPUS	WS- 001387	8/21/2016	2	Fountain	In classroom 213	FT-82016-001387-A	< 1	FT-82016-001387-B	< 1