



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	WHEATLEY EC	5/3/2016	WS- 001390	Classroom	2	In 214 Right	WT-042916-1407- A	3.27	WT-042916-1407- B	1.76				
2	WHEATLEY EC	5/3/2016	WS- 001389	Classroom	2	In 214 Left	WT-042916-1406- A	< 1	WT-042916-1406- B	< 1				
3	WHEATLEY EC	5/3/2016	WS- 001388	Classroom	2	In 213	WT-042916-1405- A	< 1	WT-042916-1405- B	< 1				
4	WHEATLEY EC	5/3/2016	WS- 001387	Fountain	2	In 213	WT-042916-1404- A	< 1	WT-042916-1404- B	< 1				
5	WHEATLEY EC	5/3/2016	WS- 001386	Classroom	2	In classroom 222	WT-042916-1403- A	1.99	WT-042916-1403- B	1.17				
6	WHEATLEY EC	5/3/2016	WS- 001385	Fountain	2	In classroom 222	WT-042916-1402- A	< 1	WT-042916-1402- B	< 1				
7	WHEATLEY EC	5/3/2016	WS- 001384	Classroom	2	In 215	WT-042916-1401- A	< 1	WT-042916-1401- B	< 1				
8	WHEATLEY EC	5/3/2016	WS- 001383	Fountain	2	In 215	WT-042916-1400- A	4.54	WT-042916-1400- B	< 1				
9	WHEATLEY EC	5/3/2016	WS- 001382	Classroom	2	In 211	WT-042916-1399- A	2.44	WT-042916-1399- B	5.84				
10	WHEATLEY EC	5/3/2016	WS- 001381	Fountain	2	In 211	WT-042916-1398- A	< 1	WT-042916-1398- B	4.61				
11	WHEATLEY EC	5/3/2016	WS- 001380	Classroom	2	In 203	WT-042916-1397- A	1.61	WT-042916-1397- B	1.2				
12	WHEATLEY EC	5/3/2016	WS- 001379	Fountain	2	In 203	WT-042916-1396- A	< 1	WT-042916-1396- B	< 1				
13	WHEATLEY EC	5/3/2016	WS- 001378	Cooler	2	In hallway adjacent to 205	WT-042916-1395- A	< 1	WT-042916-1395- B	< 1				
14	WHEATLEY EC	5/3/2016	WS- 001377	Cooler	2	In hallway adjacent to 205 Left High	WT-042916-1394- A	< 1	WT-042916-1394- B	< 1				
15	WHEATLEY EC	5/3/2016	WS- 001376	Classroom	2	In 207	WT-042916-1393- A	< 1	WT-042916-1393- B	< 1				
16	WHEATLEY EC	5/3/2016	WS- 001375	Fountain	2	In 207	WT-042916-1392- A	< 1	WT-042916-1392- B	< 1				
17	WHEATLEY EC	5/3/2016	WS- 001374	Kitchen	2	In room 235	WT-042916-1391- A	< 1	WT-042916-1391- B	< 1				
18	WHEATLEY EC	5/3/2016	WS- 001373	Classroom	2	In classroom 234	WT-042916-1390- A	< 1	WT-042916-1390- B	< 1				
19	WHEATLEY EC	5/3/2016	WS- 001372	Fountain	2	In classroom 234	WT-042916-1389- A	< 1	WT-042916-1389- B	< 1				
20	WHEATLEY EC	5/3/2016	WS- 001371	Cooler	2	In hallway adjacent to lockers by classroom 222 Right Low	WT-042916-1388- A	< 1	WT-042916-1388- B	< 1				
21	WHEATLEY EC	5/3/2016	WS- 001370	Cooler	2	In hallway adjacent to lockers by classroom 222 Left High	WT-042916-1387- A	< 1	WT-042916-1387- B	< 1				
22	WHEATLEY EC	5/3/2016	WS- 001369	Classroom	2	In classroom 229	WT-042916-1386- A	1.23	WT-042916-1386- B	< 1				
23	WHEATLEY EC	5/3/2016	WS- 001367	Classroom	2	In classroom 227	WT-042916-1384- A	2.06	WT-042916-1384- B	< 1				
24	WHEATLEY EC	5/3/2016	WS- 001366	Fountain	2	In classroom 227	WT-042916-1383- A	< 1	WT-042916-1383- B	< 1				
25	WHEATLEY EC	5/3/2016	WS- 001365	Classroom	2	In classroom 225	WT-042916-1382- A	< 1	WT-042916-1382- B	< 1				
26	WHEATLEY EC	5/3/2016	WS- 001364	Fountain	2	In classroom 225	WT-042916-1381- A	< 1	WT-042916-1381- B	< 1				
27	WHEATLEY EC	5/3/2016	WS- 001363	Classroom	2	In classroom 224	WT-042916-1380- A	1.28	WT-042916-1380- B	7.36				



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
28	WHEATLEY EC	5/3/2016	WS- 001362	Fountain	2	In classroom 224	WT-042916-1379- A	< 1	WT-042916-1379- B	< 1				
29	WHEATLEY EC	5/3/2016	WS- 001361	Classroom	1	In classroom 131	WT-042916-1378- A	1.19	WT-042916-1378- B	6.7				
30	WHEATLEY EC	5/3/2016	WS- 001360	Fountain	1	In classroom 131	WT-042916-1377- A	< 1	WT-042916-1377- B	< 1				
31	WHEATLEY EC	5/3/2016	WS- 001359	Classroom	1	In 128	WT-042916-1376- A	< 1	WT-042916-1376- B	1.19				
32	WHEATLEY EC	5/3/2016	WS- 001358	Fountain	1	In 128	WT-042916-1375- A	< 1	WT-042916-1375- B	< 1				
33	WHEATLEY EC	5/3/2016	WS- 001357	Classroom	1	In classroom 125	WT-042916-1374- A	1.56	WT-042916-1374- B	< 1				
34	WHEATLEY EC	5/3/2016	WS- 001355	Classroom	1	In classroom 123	WT-042916-1372- A	< 1	WT-042916-1372- B	< 1				
35	WHEATLEY EC	5/3/2016	WS- 001354	Fountain	1	In classroom 123	WT-042916-1371- A	< 1	WT-042916-1371- B	< 1				
36	WHEATLEY EC	5/3/2016	WS- 001353	Cooler	1	In hallway adjacent to 148 Right Low	WT-042916-1370- A	< 1	WT-042916-1370- B	< 1				
37	WHEATLEY EC	5/3/2016	WS- 001352	Cooler	1	In hallway adjacent to 148 Left High	WT-042916-1369- A	< 1	WT-042916-1369- B	< 1				
38	WHEATLEY EC	5/3/2016	WS- 001351	Classroom	1	In classroom 107	WT-042916-1368- A	2.63	WT-042916-1368- B	1.56				
39	WHEATLEY EC	5/3/2016	WS- 001350	Fountain	1	In classroom 107	WT-042916-1367- A	< 1	WT-042916-1367- B	< 1				
40	WHEATLEY EC	5/3/2016	WS- 001349	Classroom	1	In classroom 135	WT-042916-1366- A	< 1	WT-042916-1366- B	< 1				
41	WHEATLEY EC	5/3/2016	WS- 001348	Fountain	1	In classroom 135	WT-042916-1365- A	< 1	WT-042916-1365- B	< 1				
42	WHEATLEY EC	5/3/2016	WS- 001347	Classroom	1	In 107	WT-042916-1364- A	1.86	WT-042916-1364- B	< 1				
43	WHEATLEY EC	5/3/2016	WS- 001346	Fountain	1	In 107	WT-042916-1363- A	4.25	WT-042916-1363- B	1.75				
44	WHEATLEY EC	5/3/2016	WS- 001345	Classroom	1	In classroom 115	WT-042916-1362- A	< 1	WT-042916-1362- B	< 1				
45	WHEATLEY EC	5/3/2016	WS- 001344	Fountain	1	In classroom 111	WT-042916-1361- A	< 1	WT-042916-1361- B	< 1				
46	WHEATLEY EC	5/3/2016	WS- 001343	Classroom	1	In 114	WT-042916-1360- A	6.11	WT-042916-1360- B	9.61				
47	WHEATLEY EC	5/3/2016	WS- 001341	Classroom	1	In classroom 113	WT-042916-1358- A	< 1	WT-042916-1358- B	1.63				
48	WHEATLEY EC	5/3/2016	WS- 001339	Classroom	1	In 111	WT-042916-1356- A	< 1	WT-042916-1356- B	1.01				
49	WHEATLEY EC	5/3/2016	WS- 001338	Fountain	1	In 111	WT-042916-1355- A	< 1	WT-042916-1355- B	1.13				
50	WHEATLEY EC	5/3/2016	WS- 001335	Classroom	1	In 103	WT-042916-1352- A	1.07	WT-042916-1352- B	< 1				
51	WHEATLEY EC	5/3/2016	WS- 001334	Fountain	1	In 103	WT-042916-1351- A	< 1	WT-042916-1351- B	< 1				
52	WHEATLEY EC	5/3/2016	WS- 001331	Classroom	Ground Floor	In G-59	WT-042916-1348- A	7.6	WT-042916-1348- B	< 1				
53	WHEATLEY EC	5/3/2016	WS- 001329	Classroom	Ground Floor	In classroom G58	WT-042916-1346- A	275	WT-042916-1346- B	6.34	Filtered	6/13/2016	<1	<1
54	WHEATLEY EC	5/3/2016	WS- 001327	Classroom	Ground Floor	In G-57	WT-042916-1344- A	< 1	WT-042916-1344- B	< 1				



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
55	WHEATLEY EC	5/3/2016	WS- 001326	Fountain	Ground Floor	In classroom G-57	WT-042916-1343- A	< 1	WT-042916-1343- B	< 1				
56	WHEATLEY EC	5/3/2016	WS- 001325	Classroom	Ground Floor	In classroom G-55	WT-042916-1342- A	< 1	WT-042916-1342- B	< 1				
57	WHEATLEY EC	5/3/2016	WS- 001324	Classroom	Ground Floor	In G-54	WT-042916-1341- A	< 1	WT-042916-1341- B	2.4				
58	WHEATLEY EC	5/3/2016	WS- 001323	Fountain	Ground Floor	In classroom G-54	WT-042916-1340- A	< 1	WT-042916-1340- B	< 1				
59	WHEATLEY EC	5/3/2016	WS- 001322	Classroom	Ground Floor	In G-51	WT-042916-1339- A	< 1	WT-042916-1339- B	< 1				
60	WHEATLEY EC	5/3/2016	WS- 001321	Fountain	Ground Floor	In classroom G-51	WT-042916-1338- A	< 1	WT-042916-1338- B	< 1				
61	WHEATLEY EC	5/3/2016	WS- 001320	Cooler	Ground Floor	In hallway adjacent to room G-46 Right Low	WT-042916-1337- A	< 1	WT-042916-1337- B	< 1				
62	WHEATLEY EC	5/3/2016	WS- 001319	Cooler	Ground Floor	In hallway next to room G-46 High	WT-042916-1336- A	< 1	WT-042916-1336- B	< 1				
63	WHEATLEY EC	5/3/2016	WS- 001318	Classroom	Ground Floor	In room G-46	WT-042916-1335- A	< 1	WT-042916-1335- B	< 1				
64	WHEATLEY EC	5/3/2016	WS- 001317	Break Room	Ground Floor	In room G-42	WT-042916-1334- A	1.52	WT-042916-1334- B	< 1				
65	WHEATLEY EC	5/2/2016	WS- 001316	Break Room	Ground Floor	In main office G-62	WT-042916-1333- A	< 1	WT-042916-1333- B	< 1				
66	WHEATLEY EC	5/3/2016	WS- 001315	Health Suite	Ground Floor	In room G-41	WT-042916-1332- A	1.04	WT-042916-1332- B	< 1				
67	WHEATLEY EC	5/3/2016	WS- 001314	Classroom	Ground Floor	In classroom G-32 Mid	WT-042916-1331- A	< 1	WT-042916-1331- B	< 1				
68	WHEATLEY EC	5/3/2016	WS- 001313	Break Room	Ground Floor	In room G33 (icemaker)	WT-042916-1330- A	< 1	WT-042916-1330- B	< 1				
69	WHEATLEY EC	5/3/2016	WS- 001312	Break Room	Ground Floor	In room G33	WT-042916-1329- A	< 1	WT-042916-1329- B	< 1				
70	WHEATLEY EC	5/3/2016	WS- 001311	Fountain	Ground Floor	In classroom G-05	WT-042916-1328- A	1.49	WT-042916-1328- B	< 1				
71	WHEATLEY EC	5/3/2016	WS- 001310	Classroom	Ground Floor	In classroom G-05	WT-042916-1327- A	< 1	WT-042916-1327- B	< 1				
72	WHEATLEY EC	5/3/2016	WS- 001309	Classroom	Ground Floor	In classroom G-32 Right	WT-042916-1326- A	1.11	WT-042916-1326- B	< 1				
73	WHEATLEY EC	5/3/2016	WS- 001308	Classroom	Ground Floor	In classroom G-32 Left	WT-042916-1325- A	1.32	WT-042916-1325- B	2.59				
74	WHEATLEY EC	5/3/2016	WS- 001307	Fountain	Ground Floor	In classroom G-31	WT-042916-1324- A	< 1	WT-042916-1324- B	< 1				
75	WHEATLEY EC	5/3/2016	WS- 001306	Classroom	Ground Floor	In classroom G-31	WT-042916-1323- A	< 1	WT-042916-1323- B	< 1				
76	WHEATLEY EC	5/3/2016	WS- 001305	Fountain	Ground Floor	In Classroom G-08	WT-042916-1322- A	< 1	WT-042916-1322- B	< 1				
77	WHEATLEY EC	5/3/2016	WS- 001304	Classroom	Ground Floor	In classroom G-08	WT-042916-1321- A	< 1	WT-042916-1321- B	< 1				
78	WHEATLEY EC	5/3/2016	WS- 001303	Classroom	Ground Floor	South wall	WT-042916-1320- A	< 1	WT-042916-1320- B	< 1				
79	WHEATLEY EC	5/3/2016	WS- 001302	Cooler	Ground Floor	In hallway adjacent to room G-46 Left High	WT-042916-1319- A	< 1	WT-042916-1319- B	< 1				
80	WHEATLEY EC	5/3/2016	WS- 001301	Kitchen	Ground Floor	West wall Right	WT-042916-1318- A	< 1	WT-042916-1318- B	< 1				
81	WHEATLEY EC	5/3/2016	WS- 001300	Kitchen	Ground Floor	Spray nozzle hose	WT-042916-1317- A	5.08	WT-042916-1317- B	< 1				



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
82	WHEATLEY EC	5/3/2016	WS-001299	Utility	Basement	Main water source	WT-042916-1316- A	91.6	WT-042916-1316- B	35.5	Not accessible to children			

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.