



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
1	WHEATLEY EC	5/3/2016	WS- 001390	Classroom	2	In 214 Right	WT-042916-1407- A	3.27	WT-042916-1407- B	1.76			
2	WHEATLEY EC	5/3/2016	WS- 001389	Classroom	2	In 214 Left	WT-042916-1406- A	< 1	WT-042916-1406- B	< 1			
3	WHEATLEY EC	5/3/2016	WS- 001388	Classroom	2	In 213	WT-042916-1405- A	< 1	WT-042916-1405- B	< 1			
4	WHEATLEY EC	5/3/2016	WS- 001387	Fountain	2	In 213	WT-042916-1404- A	< 1	WT-042916-1404- B	< 1			
5	WHEATLEY EC	5/3/2016	WS- 001386	Classroom	2	In classroom 222	WT-042916-1403- A	1.99	WT-042916-1403- B	1.17			
6	WHEATLEY EC	5/3/2016	WS- 001385	Fountain	2	In classroom 222	WT-042916-1402- A	< 1	WT-042916-1402- B	< 1			
7	WHEATLEY EC	5/3/2016	WS- 001384	Classroom	2	In 215	WT-042916-1401- A	< 1	WT-042916-1401- B	< 1			
8	WHEATLEY EC	5/3/2016	WS- 001383	Fountain	2	In 215	WT-042916-1400- A	4.54	WT-042916-1400- B	< 1			
9	WHEATLEY EC	5/3/2016	WS- 001382	Classroom	2	In 211	WT-042916-1399- A	2.44	WT-042916-1399- B	5.84			
10	WHEATLEY EC	5/3/2016	WS- 001381	Fountain	2	In 211	WT-042916-1398- A	< 1	WT-042916-1398- B	4.61			
11	WHEATLEY EC	5/3/2016	WS- 001380	Classroom	2	In 203	WT-042916-1397- A	1.61	WT-042916-1397- B	1.2			
12	WHEATLEY EC	5/3/2016	WS- 001379	Fountain	2	In 203	WT-042916-1396- A	< 1	WT-042916-1396- B	< 1			
13	WHEATLEY EC	5/3/2016	WS- 001378	Cooler	2	In hallway adjacent to 205	WT-042916-1395- A	< 1	WT-042916-1395- B	< 1			
14	WHEATLEY EC	5/3/2016	WS- 001377	Cooler	2	In hallway adjacent to 205 Left High	WT-042916-1394- A	< 1	WT-042916-1394- B	< 1			
15	WHEATLEY EC	5/3/2016	WS- 001376	Classroom	2	In 207	WT-042916-1393- A	< 1	WT-042916-1393- B	< 1			
16	WHEATLEY EC	5/3/2016	WS- 001375	Fountain	2	In 207	WT-042916-1392- A	< 1	WT-042916-1392- B	< 1			
17	WHEATLEY EC	5/3/2016	WS- 001374	Kitchen	2	In room 235	WT-042916-1391- A	< 1	WT-042916-1391- B	< 1			
18	WHEATLEY EC	5/3/2016	WS- 001373	Classroom	2	In classroom 234	WT-042916-1390- A	< 1	WT-042916-1390- B	< 1			
19	WHEATLEY EC	5/3/2016	WS- 001372	Fountain	2	In classroom 234	WT-042916-1389- A	< 1	WT-042916-1389- B	< 1			
20	WHEATLEY EC	5/3/2016	WS- 001371	Cooler	2	In hallway adjacent to lockers by classroom 222 Right Low	WT-042916-1388- A	< 1	WT-042916-1388- B	< 1			
21	WHEATLEY EC	5/3/2016	WS- 001370	Cooler	2	In hallway adjacent to lockers by classroom 222 Left High	WT-042916-1387- A	< 1	WT-042916-1387- B	< 1			
22	WHEATLEY EC	5/3/2016	WS- 001369	Classroom	2	In classroom 229	WT-042916-1386- A	1.23	WT-042916-1386- B	< 1			
23	WHEATLEY EC	5/3/2016	WS- 001367	Classroom	2	In classroom 227	WT-042916-1384- A	2.06	WT-042916-1384- B	< 1			
24	WHEATLEY EC	5/3/2016	WS- 001366	Fountain	2	In classroom 227	WT-042916-1383- A	< 1	WT-042916-1383- B	< 1			
25	WHEATLEY EC	5/3/2016	WS- 001365	Classroom	2	In classroom 225	WT-042916-1382- A	< 1	WT-042916-1382- B	< 1			
26	WHEATLEY EC	5/3/2016	WS- 001364	Fountain	2	In classroom 225	WT-042916-1381- A	< 1	WT-042916-1381- B	< 1			



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
27	WHEATLEY EC	5/3/2016	WS- 001363	Classroom	2	In classroom 224	WT-042916-1380- A	1.28	WT-042916-1380- B	7.36			
28	WHEATLEY EC	5/3/2016	WS- 001362	Fountain	2	In classroom 224	WT-042916-1379- A	< 1	WT-042916-1379- B	< 1			
29	WHEATLEY EC	5/3/2016	WS- 001361	Classroom	1	In classroom 131	WT-042916-1378- A	1.19	WT-042916-1378- B	6.7			
30	WHEATLEY EC	5/3/2016	WS- 001360	Fountain	1	In classroom 131	WT-042916-1377- A	< 1	WT-042916-1377- B	< 1			
31	WHEATLEY EC	5/3/2016	WS- 001359	Classroom	1	In 128	WT-042916-1376- A	< 1	WT-042916-1376- B	1.19			
32	WHEATLEY EC	5/3/2016	WS- 001358	Fountain	1	In 128	WT-042916-1375- A	< 1	WT-042916-1375- B	< 1			
33	WHEATLEY EC	5/3/2016	WS- 001357	Classroom	1	In classroom 125	WT-042916-1374- A	1.56	WT-042916-1374- B	< 1			
34	WHEATLEY EC	5/3/2016	WS- 001355	Classroom	1	In classroom 123	WT-042916-1372- A	< 1	WT-042916-1372- B	< 1			
35	WHEATLEY EC	5/3/2016	WS- 001354	Fountain	1	In classroom 123	WT-042916-1371- A	< 1	WT-042916-1371- B	< 1			
36	WHEATLEY EC	5/3/2016	WS- 001353	Cooler	1	In hallway adjacent to 148 Right Low	WT-042916-1370- A	< 1	WT-042916-1370- B	< 1			
37	WHEATLEY EC	5/3/2016	WS- 001352	Cooler	1	In hallway adjacent to 148 Left High	WT-042916-1369- A	< 1	WT-042916-1369- B	< 1			
38	WHEATLEY EC	5/3/2016	WS- 001351	Classroom	1	In classroom 107	WT-042916-1368- A	2.63	WT-042916-1368- B	1.56			
39	WHEATLEY EC	5/3/2016	WS- 001350	Fountain	1	In classroom 107	WT-042916-1367- A	< 1	WT-042916-1367- B	< 1			
40	WHEATLEY EC	5/3/2016	WS- 001349	Classroom	1	In classroom 135	WT-042916-1366- A	< 1	WT-042916-1366- B	< 1			
41	WHEATLEY EC	5/3/2016	WS- 001348	Fountain	1	In classroom 135	WT-042916-1365- A	< 1	WT-042916-1365- B	< 1			
42	WHEATLEY EC	5/3/2016	WS- 001347	Classroom	1	In 107	WT-042916-1364- A	1.86	WT-042916-1364- B	< 1			
43	WHEATLEY EC	5/3/2016	WS- 001346	Fountain	1	In 107	WT-042916-1363- A	4.25	WT-042916-1363- B	1.75			
44	WHEATLEY EC	5/3/2016	WS- 001345	Classroom	1	In classroom 115	WT-042916-1362- A	< 1	WT-042916-1362- B	< 1			
45	WHEATLEY EC	5/3/2016	WS- 001344	Fountain	1	In classroom 111	WT-042916-1361- A	< 1	WT-042916-1361- B	< 1			
46	WHEATLEY EC	5/3/2016	WS- 001343	Classroom	1	In 114	WT-042916-1360- A	6.11	WT-042916-1360- B	9.61			
47	WHEATLEY EC	5/3/2016	WS- 001341	Classroom	1	In classroom 113	WT-042916-1358- A	< 1	WT-042916-1358- B	1.63			
48	WHEATLEY EC	5/3/2016	WS- 001339	Classroom	1	In 111	WT-042916-1356- A	< 1	WT-042916-1356- B	1.01			
49	WHEATLEY EC	5/3/2016	WS- 001338	Fountain	1	In 111	WT-042916-1355- A	< 1	WT-042916-1355- B	1.13			
50	WHEATLEY EC	5/3/2016	WS- 001335	Classroom	1	In 103	WT-042916-1352- A	1.07	WT-042916-1352- B	< 1			
51	WHEATLEY EC	5/3/2016	WS- 001334	Fountain	1	In 103	WT-042916-1351- A	< 1	WT-042916-1351- B	< 1			
52	WHEATLEY EC	5/3/2016	WS- 001331	Classroom	Ground Floor	In G-59	WT-042916-1348- A	7.6	WT-042916-1348- B	< 1			



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
53	WHEATLEY EC	5/3/2016	WS- 001329	Classroom	Ground Floor	In classroom G58	WT-042916-1346- A	275	WT-042916-1346- B	6.34	Filtration		
54	WHEATLEY EC	5/3/2016	WS- 001327	Classroom	Ground Floor	In G-57	WT-042916-1344- A	< 1	WT-042916-1344- B	< 1			
55	WHEATLEY EC	5/3/2016	WS- 001326	Fountain	Ground Floor	In classroom G-57	WT-042916-1343- A	< 1	WT-042916-1343- B	< 1			
56	WHEATLEY EC	5/3/2016	WS- 001325	Classroom	Ground Floor	In classroom G-55	WT-042916-1342- A	< 1	WT-042916-1342- B	< 1			
57	WHEATLEY EC	5/3/2016	WS- 001324	Classroom	Ground Floor	In G-54	WT-042916-1341- A	< 1	WT-042916-1341- B	2.4			
58	WHEATLEY EC	5/3/2016	WS- 001323	Fountain	Ground Floor	In classroom G-54	WT-042916-1340- A	< 1	WT-042916-1340- B	< 1			
59	WHEATLEY EC	5/3/2016	WS- 001322	Classroom	Ground Floor	In G-51	WT-042916-1339- A	< 1	WT-042916-1339- B	< 1			
60	WHEATLEY EC	5/3/2016	WS- 001321	Fountain	Ground Floor	In classroom G-51	WT-042916-1338- A	< 1	WT-042916-1338- B	< 1			
61	WHEATLEY EC	5/3/2016	WS- 001320	Cooler	Ground Floor	In hallway adjacent to room G-46 Right Low	WT-042916-1337- A	< 1	WT-042916-1337- B	< 1			
62	WHEATLEY EC	5/3/2016	WS- 001319	Cooler	Ground Floor	In hallway next to room G-46 High	WT-042916-1336- A	< 1	WT-042916-1336- B	< 1			
63	WHEATLEY EC	5/3/2016	WS- 001318	Classroom	Ground Floor	In room G-46	WT-042916-1335- A	< 1	WT-042916-1335- B	< 1			
64	WHEATLEY EC	5/3/2016	WS- 001317	Break Room	Ground Floor	In room G-42	WT-042916-1334- A	1.52	WT-042916-1334- B	< 1			
65	WHEATLEY EC	5/2/2016	WS- 001316	Break Room	Ground Floor	In main office G-62	WT-042916-1333- A	< 1	WT-042916-1333- B	< 1			
66	WHEATLEY EC	5/3/2016	WS- 001315	Health Suite	Ground Floor	In room G-41	WT-042916-1332- A	1.04	WT-042916-1332- B	< 1			
67	WHEATLEY EC	5/3/2016	WS- 001314	Classroom	Ground Floor	In classroom G-32 Mid	WT-042916-1331- A	< 1	WT-042916-1331- B	< 1			
68	WHEATLEY EC	5/3/2016	WS- 001313	Break Room	Ground Floor	In room G33 (icemaker)	WT-042916-1330- A	< 1	WT-042916-1330- B	< 1			
69	WHEATLEY EC	5/3/2016	WS- 001312	Break Room	Ground Floor	In room G33	WT-042916-1329- A	< 1	WT-042916-1329- B	< 1			
70	WHEATLEY EC	5/3/2016	WS- 001311	Fountain	Ground Floor	In classroom G-05	WT-042916-1328- A	1.49	WT-042916-1328- B	< 1			
71	WHEATLEY EC	5/3/2016	WS- 001310	Classroom	Ground Floor	In classroom G-05	WT-042916-1327- A	< 1	WT-042916-1327- B	< 1			
72	WHEATLEY EC	5/3/2016	WS- 001309	Classroom	Ground Floor	In classroom G-32 Right	WT-042916-1326- A	1.11	WT-042916-1326- B	< 1			
73	WHEATLEY EC	5/3/2016	WS- 001308	Classroom	Ground Floor	In classroom G-32 Left	WT-042916-1325- A	1.32	WT-042916-1325- B	2.59			
74	WHEATLEY EC	5/3/2016	WS- 001307	Fountain	Ground Floor	In classroom G-31	WT-042916-1324- A	< 1	WT-042916-1324- B	< 1			
75	WHEATLEY EC	5/3/2016	WS- 001306	Classroom	Ground Floor	In classroom G-31	WT-042916-1323- A	< 1	WT-042916-1323- B	< 1			
76	WHEATLEY EC	5/3/2016	WS- 001305	Fountain	Ground Floor	In Classroom G-08	WT-042916-1322- A	< 1	WT-042916-1322- B	< 1			
77	WHEATLEY EC	5/3/2016	WS- 001304	Classroom	Ground Floor	In classroom G-08	WT-042916-1321- A	< 1	WT-042916-1321- B	< 1			
78	WHEATLEY EC	5/3/2016	WS- 001303	Classroom	Ground Floor	South wall	WT-042916-1320- A	< 1	WT-042916-1320- B	< 1			



WHEATLEY LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
79	WHEATLEY EC	5/3/2016	WS- 001302	Cooler	Ground Floor	In hallway adjacent to room G-46 Left High	WT-042916-1319- A	< 1	WT-042916-1319- B	< 1			
80	WHEATLEY EC	5/3/2016	WS- 001301	Kitchen	Ground Floor	West wall Right	WT-042916-1318- A	< 1	WT-042916-1318- B	< 1			
81	WHEATLEY EC	5/3/2016	WS- 001300	Kitchen	Ground Floor	Spray nozzle hose	WT-042916-1317- A	5.08	WT-042916-1317- B	< 1			
82	WHEATLEY EC	5/3/2016	WS- 001299	Utility	Basement	Main water source	WT-042916-1316- A	91.6	WT-042916-1316- B	35.5	Non-drinking Water Source Flush		

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.