



WHEATLEY EC LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001380	1/9/2017	2	Combo Faucet	In classroom 203	FT-112016-001380-A	< 1	FT-112016-001380-B	< 1
2	WHEATLEY EDUCATIONAL CAMPUS	WS- 001388	1/9/2017	2	Combo Faucet	In classroom 213	FT-112016-001388-A	< 1	FT-112016-001388-B	< 1
3	WHEATLEY EDUCATIONAL CAMPUS	WS- 001365	1/9/2017	2	Combo Faucet	In classroom 225	FT-112016-001365-A	< 1	FT-112016-001365-B	< 1
4	WHEATLEY EDUCATIONAL CAMPUS	WS- 001363	1/9/2017	2	Combo Faucet	In classroom 224	FT-112016-001363-A	< 1	FT-112016-001363-B	< 1
5	WHEATLEY EDUCATIONAL CAMPUS	WS- 001324	1/9/2017	Ground Floor	Combo Faucet	In classroom G54	FT-112016-001324-A	< 1	FT-112016-001324-B	< 1
6	WHEATLEY EDUCATIONAL CAMPUS	WS- 001347	1/9/2017	1	Combo Faucet	In classroom 136	FT-112016-001347-A	< 1	FT-112016-001347-B	< 1
7	WHEATLEY EDUCATIONAL CAMPUS	WS- 001355	1/9/2017	1	Combo Faucet	In classroom 123	FT-112016-001355-A	< 1	FT-112016-001355-B	< 1
8	WHEATLEY EDUCATIONAL CAMPUS	WS- 001304	1/9/2017	Ground Floor	Combo Faucet	In classroom G08	FT-112016-001304-A	< 1	FT-112016-001304-B	< 1
9	WHEATLEY EDUCATIONAL CAMPUS	WS- 001339	1/9/2017	1	Combo Faucet	In classroom 111	FT-112016-001339-A	< 1	FT-112016-001339-B	< 1
10	WHEATLEY EDUCATIONAL CAMPUS	WS- 001359	1/9/2017	1	Combo Faucet	In classroom 128	FT-112016-001359-A	< 1	FT-112016-001359-B	< 1
11	WHEATLEY EDUCATIONAL CAMPUS	WS- 001310	1/9/2017	Ground Floor	Combo Faucet	In classroom G05	FT-112016-001310-A	< 1	FT-112016-001310-B	< 1
12	WHEATLEY EDUCATIONAL CAMPUS	WS- 001312	1/9/2017	Ground Floor	Break Room	In staff lounge G33	FT-112016-001312-A	< 1	FT-112016-001312-B	< 1
Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001306	1/9/2017	Ground Floor	Combo Faucet	In classroom G31	FT-112016-001306-A	1.5	FT-112016-001306-B	< 1
2	WHEATLEY EDUCATIONAL CAMPUS	WS- 001322	1/9/2017	Ground Floor	Combo Faucet	In classroom G51	FT-112016-001322-A	1.1	FT-112016-001322-B	< 1
3	WHEATLEY EDUCATIONAL CAMPUS	WS- 001327	1/9/2017	Ground Floor	Combo Faucet	In classroom G57	FT-112016-001327-A	1.5	FT-112016-001327-B	< 1
4	WHEATLEY EDUCATIONAL CAMPUS	WS- 001329	1/9/2017	Ground Floor	Combo Faucet	In classroom G58	FT-112016-001329-A	2.7	FT-112016-001329-B	< 1
5	WHEATLEY EDUCATIONAL CAMPUS	WS- 001331	1/9/2017	Ground Floor	Combo Faucet	In classroom G59	FT-112016-001331-A	3.6	FT-112016-001331-B	< 1
6	WHEATLEY EDUCATIONAL CAMPUS	WS- 001335	1/9/2017	1	Combo Faucet	In classroom 103	FT-112016-001335-A	2.1	FT-112016-001335-B	< 1
7	WHEATLEY EDUCATIONAL CAMPUS	WS- 001341	1/9/2017	1	Combo Faucet	In classroom 113	FT-112016-001341-A	2.9	FT-112016-001341-B	< 1
8	WHEATLEY EDUCATIONAL CAMPUS	WS- 001343	1/9/2017	1	Combo Faucet	In classroom 114	FT-112016-001343-A	4.3	FT-112016-001343-B	< 1
9	WHEATLEY EDUCATIONAL CAMPUS	WS- 001345	1/9/2017	1	Combo Faucet	In classroom 115	FT-112016-001345-A	1.1	FT-112016-001345-B	< 1
10	WHEATLEY EDUCATIONAL CAMPUS	WS- 001349	1/9/2017	1	Combo Faucet	In classroom 135	FT-112016-001349-A	2	FT-112016-001349-B	< 1
11	WHEATLEY EDUCATIONAL CAMPUS	WS- 001351	1/9/2017	1	Combo Faucet	In classroom 107	FT-112016-001351-A	2.1	FT-112016-001351-B	< 1
12	WHEATLEY EDUCATIONAL CAMPUS	WS- 001357	1/9/2017	1	Combo Faucet	In classroom 125	FT-112016-001357-A	5	FT-112016-001357-B	< 1
13	WHEATLEY EDUCATIONAL CAMPUS	WS- 001361	1/9/2017	1	Combo Faucet	In classroom 131	FT-112016-001361-A	2.7	FT-112016-001361-B	< 1
14	WHEATLEY EDUCATIONAL CAMPUS	WS- 001367	1/9/2017	2	Combo Faucet	In classroom 227	FT-112016-001367-A	2.1	FT-112016-001367-B	< 1
15	WHEATLEY EDUCATIONAL CAMPUS	WS- 001369	1/9/2017	2	Combo Faucet	In classroom 229	FT-112016-001369-A	2.8	FT-112016-001369-B	< 1
16	WHEATLEY EDUCATIONAL CAMPUS	WS- 001373	1/9/2017	2	Combo Faucet	In classroom 234	FT-112016-001373-A	1.1	FT-112016-001373-B	< 1
17	WHEATLEY EDUCATIONAL CAMPUS	WS- 001376	1/9/2017	2	Combo Faucet	In classroom 207	FT-112016-001376-A	3.6	FT-112016-001376-B	< 1
18	WHEATLEY EDUCATIONAL CAMPUS	WS- 001382	1/9/2017	2	Combo Faucet	In classroom 211	FT-112016-001382-A	2.5	FT-112016-001382-B	< 1
19	WHEATLEY EDUCATIONAL CAMPUS	WS- 001384	1/9/2017	2	Combo Faucet	In classroom 215	FT-112016-001384-A	1.3	FT-112016-001384-B	< 1
20	WHEATLEY EDUCATIONAL CAMPUS	WS- 001386	1/9/2017	2	Combo Faucet	In classroom 222	FT-112016-001386-A	2.3	FT-112016-001386-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001322	2/8/2017	Ground Floor	Combo Faucet	In classroom G51	FT-112016-001322-A	< 1	FT-112016-001322-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001306	2/8/2017	Ground Floor	Combo Faucet	In classroom G31	FT-112016-001306-A	2.3	FT-112016-001306-B	< 1
2	WHEATLEY EDUCATIONAL CAMPUS	WS- 001327	2/8/2017	Ground Floor	Combo Faucet	In classroom G57	FT-112016-001327-A	5	FT-112016-001327-B	< 1
3	WHEATLEY EDUCATIONAL CAMPUS	WS- 001329	2/8/2017	Ground Floor	Combo Faucet	In classroom G58	FT-112016-001329-A	7.1	FT-112016-001329-B	< 1
4	WHEATLEY EDUCATIONAL CAMPUS	WS- 001331	2/8/2017	Ground Floor	Combo Faucet	In classroom G59	FT-112016-001331-A	3	FT-112016-001331-B	< 1
5	WHEATLEY EDUCATIONAL CAMPUS	WS- 001335	2/8/2017	1	Combo Faucet	In classroom 103	FT-112016-001335-A	2.9	FT-112016-001335-B	< 1
6	WHEATLEY EDUCATIONAL CAMPUS	WS- 001341	2/8/2017	1	Combo Faucet	In classroom 113	FT-112016-001341-A	2.6	FT-112016-001341-B	< 1
7	WHEATLEY EDUCATIONAL CAMPUS	WS- 001343	2/8/2017	1	Combo Faucet	In classroom 114	FT-112016-001343-A	2.2	FT-112016-001343-B	< 1
8	WHEATLEY EDUCATIONAL CAMPUS	WS- 001345	2/8/2017	1	Combo Faucet	In classroom 115	FT-112016-001345-A	1.1	FT-112016-001345-B	< 1
9	WHEATLEY EDUCATIONAL CAMPUS	WS- 001349	2/8/2017	1	Combo Faucet	In classroom 135	FT-112016-001349-A	1	FT-112016-001349-B	< 1
10	WHEATLEY EDUCATIONAL CAMPUS	WS- 001351	2/8/2017	1	Combo Faucet	In classroom 107	FT-112016-001351-A	2.9	FT-112016-001351-B	< 1
11	WHEATLEY EDUCATIONAL CAMPUS	WS- 001357	2/8/2017	1	Combo Faucet	In classroom 125	FT-112016-001357-A	2.9	FT-112016-001357-B	< 1
12	WHEATLEY EDUCATIONAL CAMPUS	WS- 001361	2/8/2017	1	Combo Faucet	In classroom 131	FT-112016-001361-A	2.6	FT-112016-001361-B	< 1
13	WHEATLEY EDUCATIONAL CAMPUS	WS- 001367	2/8/2017	2	Combo Faucet	In classroom 227	FT-112016-001367-A	3.9	FT-112016-001367-B	< 1
14	WHEATLEY EDUCATIONAL CAMPUS	WS- 001369	2/8/2017	2	Combo Faucet	In classroom 229	FT-112016-001369-A	2.8	FT-112016-001369-B	< 1
15	WHEATLEY EDUCATIONAL CAMPUS	WS- 001373	2/8/2017	2	Combo Faucet	In classroom 234	FT-112016-001373-A	2.2	FT-112016-001373-B	< 1
16	WHEATLEY EDUCATIONAL CAMPUS	WS- 001376	2/8/2017	2	Combo Faucet	In classroom 207	FT-112016-001376-A	1.9	FT-112016-001376-B	< 1
17	WHEATLEY EDUCATIONAL CAMPUS	WS- 001382	2/8/2017	2	Combo Faucet	In classroom 211	FT-112016-001382-A	1.8	FT-112016-001382-B	< 1
18	WHEATLEY EDUCATIONAL CAMPUS	WS- 001384	2/8/2017	2	Combo Faucet	In classroom 215	FT-112016-001384-A	2.6	FT-112016-001384-B	< 1
19	WHEATLEY EDUCATIONAL CAMPUS	WS- 001386	2/8/2017	2	Combo Faucet	In classroom 222	FT-112016-001386-A	4.6	FT-112016-001386-B	< 1

Second Filter Re-Test (After Device Replacement)

Less than 1 ppb - Device Returned to Service										
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001327	3/27/2017	Ground Floor	Combo Faucet	In classroom G57	FT-112016-001327-A	< 1	FT-112016-001327-B	< 1
Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WHEATLEY EDUCATIONAL CAMPUS	WS- 001306	3/27/2017	Ground Floor	Combo Faucet	In classroom G31	FT-112016-001306-A	7.3	FT-112016-001306-B	< 1
2	WHEATLEY EDUCATIONAL CAMPUS	WS- 001329	3/27/2017	Ground Floor	Combo Faucet	In classroom G58	FT-112016-001329-A	3.6	FT-112016-001329-B	< 1
3	WHEATLEY EDUCATIONAL CAMPUS	WS- 001331	3/27/2017	Ground Floor	Combo Faucet	In classroom G59	FT-112016-001331-A	1.3	FT-112016-001331-B	< 1
4	WHEATLEY EDUCATIONAL CAMPUS	WS- 001335	3/27/2017	1	Combo Faucet	In classroom 103	FT-112016-001335-A	2.5	FT-112016-001335-B	< 1
5	WHEATLEY EDUCATIONAL CAMPUS	WS- 001341	3/27/2017	1	Combo Faucet	In classroom 113	FT-112016-001341-A	6.3	FT-112016-001341-B	< 1
6	WHEATLEY EDUCATIONAL CAMPUS	WS- 001343	3/27/2017	1	Combo Faucet	In classroom 114	FT-112016-001343-A	6.2	FT-112016-001343-B	< 1
7	WHEATLEY EDUCATIONAL CAMPUS	WS- 001345	3/27/2017	1	Combo Faucet	In classroom 115	FT-112016-001345-A	1.3	FT-112016-001345-B	< 1
8	WHEATLEY EDUCATIONAL CAMPUS	WS- 001349	3/27/2017	1	Combo Faucet	In classroom 135	FT-112016-001349-A	2.9	FT-112016-001349-B	< 1
9	WHEATLEY EDUCATIONAL CAMPUS	WS- 001351	3/27/2017	1	Combo Faucet	In classroom 107	FT-112016-001351-A	2	FT-112016-001351-B	< 1
10	WHEATLEY EDUCATIONAL CAMPUS	WS- 001357	3/27/2017	1	Combo Faucet	In classroom 125	FT-112016-001357-A	5	FT-112016-001357-B	< 1
11	WHEATLEY EDUCATIONAL CAMPUS	WS- 001361	3/27/2017	1	Combo Faucet	In classroom 131	FT-112016-001361-A	5.3	FT-112016-001361-B	< 1
12	WHEATLEY EDUCATIONAL CAMPUS	WS- 001367	3/27/2017	2	Combo Faucet	In classroom 227	FT-112016-001367-A	3.9	FT-112016-001367-B	< 1
13	WHEATLEY EDUCATIONAL CAMPUS	WS- 001369	3/27/2017	2	Combo Faucet	In classroom 229	FT-112016-001369-A	4.9	FT-112016-001369-B	< 1
14	WHEATLEY EDUCATIONAL CAMPUS	WS- 001373	3/27/2017	2	Combo Faucet	In classroom 234	FT-112016-001373-A	4.1	FT-112016-001373-B	< 1
15	WHEATLEY EDUCATIONAL CAMPUS	WS- 001376	3/27/2017	2	Combo Faucet	In classroom 207	FT-112016-001376-A	4.3	FT-112016-001376-B	< 1
16	WHEATLEY EDUCATIONAL CAMPUS	WS- 001382	3/27/2017	2	Combo Faucet	In classroom 211	FT-112016-001382-A	5.9	FT-112016-001382-B	< 1
17	WHEATLEY EDUCATIONAL CAMPUS	WS- 001384	3/27/2017	2	Combo Faucet	In classroom 215	FT-112016-001384-A	5	FT-112016-001384-B	< 1
18	WHEATLEY EDUCATIONAL CAMPUS	WS- 001386	3/27/2017	2	Combo Faucet	In classroom 222	FT-112016-001386-A	3.3	FT-112016-001386-B	< 1

Note :
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb