



Wheatley EC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001305	5/22/2017	5/22/2018	Ground Floor	Combo Fountain	In classroom G08	WF-52017-001305	11/2/2017	FT-FY18-102017-001305-A	<1	FT-FY18-102017-001305-B	<1
WS- 001306	10/17/2017	10/17/2018	Ground Floor	Combo Faucet	In classroom G31	WF-102017-001306	11/2/2017	FT-FY18-102017-001306-A	<1	FT-FY18-102017-001306-B	<1
WS- 001307	5/22/2017	5/22/2018	Ground Floor	Combo Fountain	In classroom G31	WF-52017-001307	11/2/2017	FT-FY18-102017-001307-A	<1	FT-FY18-102017-001307-B	<1
WS- 001312	5/22/2017	5/22/2018	Ground Floor	Break Room	In staff lounge G33	WF-52017-001312	11/2/2017	FT-FY18-102017-001312-A	<1	FT-FY18-102017-001312-B	<1
WS- 001321	5/22/2017	5/22/2018	Ground Floor	Combo Fountain	In classroom G51	WF-52017-001321	11/2/2017	FT-FY18-102017-001321-A	<1	FT-FY18-102017-001321-B	<1
WS- 001324	10/18/2017	10/18/2018	Ground Floor	Combo Faucet	In classroom G54	WF-102017-001324	11/2/2017	FT-FY18-102017-001324-A	1	FT-FY18-102017-001324-B	<1
WS- 001327	10/18/2017	10/18/2018	Ground Floor	Combo Faucet	In classroom G57	WF-102017-001327	11/2/2017	FT-FY18-102017-001327-A	<1	FT-FY18-102017-001327-B	<1
WS- 001329	10/18/2017	10/18/2018	Ground Floor	Combo Faucet	In classroom G58	WF-102017-001329	11/2/2017	FT-FY18-102017-001329-A	<1	FT-FY18-102017-001329-B	<1
WS- 001334	5/22/2017	5/22/2018	1	Combo Fountain	In classroom 103	WF-52017-001334	11/2/2017	FT-FY18-102017-001334-A	<1	FT-FY18-102017-001334-B	<1
WS- 001337	5/22/2017	5/22/2018	1	Cooler	In hallway adjacent to room 105	WF-52017-001337	11/2/2017	FT-FY18-102017-001337-A	<1	FT-FY18-102017-001337-B	<1
WS- 001338	5/22/2017	5/22/2018	1	Combo Fountain	In classroom 111	WF-52017-001338	11/2/2017	FT-FY18-102017-001338-A	<1	FT-FY18-102017-001338-B	<1
WS- 001339	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 111	WF-102017-001339	11/2/2017	FT-FY18-102017-001339-A	1.6	FT-FY18-102017-001339-B	<1
WS- 001341	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 113	WF-102017-001341	11/2/2017	FT-FY18-102017-001341-A	1.3	FT-FY18-102017-001341-B	<1
WS- 001342	5/22/2017	5/22/2018	1	Combo Fountain	In classroom 114	WF-52017-001342	11/2/2017	FT-FY18-102017-001342-A	1.7	FT-FY18-102017-001342-B	<1
WS- 001343	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 114	WF-102017-001343	11/2/2017	FT-FY18-102017-001343-A	<1	FT-FY18-102017-001343-B	<1
WS- 001344	5/22/2017	5/22/2018	1	Combo Fountain	In classroom 115	WF-52017-001344	11/2/2017	FT-FY18-102017-001344-A	<1	FT-FY18-102017-001344-B	<1
WS- 001345	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 115	WF-102017-001345	11/2/2017	FT-FY18-102017-001345-A	<1	FT-FY18-102017-001345-B	<1
WS- 001347	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 136	WF-102017-001347	11/2/2017	FT-FY18-102017-001347-A	4	FT-FY18-102017-001347-B	<1
WS- 001348	5/22/2017	5/22/2018	1	Combo Fountain	In classroom 135	WF-52017-001348	11/2/2017	FT-FY18-102017-001348-A	<1	FT-FY18-102017-001348-B	<1
WS- 001351	10/17/2017	10/17/2018	1	Combo Faucet	In classroom 107	WF-102017-001351	11/2/2017	FT-FY18-102017-001351-A	<1	FT-FY18-102017-001351-B	<1
WS- 001370	5/22/2017	5/22/2018	2	Cooler	In hallway across from room 232	WF-52017-001370	11/2/2017	FT-FY18-102017-001370-A	<1	FT-FY18-102017-001370-B	<1
WS- 001382	10/17/2017	10/17/2018	2	Combo Faucet	In classroom 211	WF-102017-001382	11/2/2017	FT-FY18-102017-001382-A	<1	FT-FY18-102017-001382-B	<1
WS- 001387	5/22/2017	5/22/2018	2	Combo Fountain	In classroom 213	WF-52017-001387	11/2/2017	FT-FY18-102017-001387-A	<1	FT-FY18-102017-001387-B	<1

Greater than 5 ppb - Devices Requiring Remediation											
WS- 001323	5/22/2017	5/22/2018	Ground Floor	Combo Fountain	In classroom G54	WF-52017-001323	11/2/2017	FT-FY18-102017-001323-A	7.1	FT-FY18-102017-001323-B	<1
WS- 001365	10/17/2017	10/17/2018	2	Combo Faucet	In classroom 225	WF-102017-001365	11/2/2017	FT-FY18-102017-001365-A	11	FT-FY18-102017-001365-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 001301	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	Mid	11/2/2017	FT-FY18-102017-001301-A	<1	FT-FY18-102017-001301-B	<1		
WS- 001302	Ground Floor	Food Prep Sink	In kitchen first clockwise from entry door	Left	11/2/2017	FT-FY18-102017-001302-A	<1	FT-FY18-102017-001302-B	<1		