



# Whitlock Elementary School @ Kenilworth Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000416	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to 113 main office	WF-05232022-000416	11/8/2022	FT-FY23-10102022-000416-A	<1	FT-FY23-10102022-000416-B	<1	
WS- 000417	5/23/2022	5/23/2023	1	Cooler	In 119 health suite	WF-05232022-000417	11/8/2022	FT-FY23-10102022-000417-A	<1	FT-FY23-10102022-000417-B	<1	
WS- 000419	5/23/2022	5/23/2023	1	Cooler	In hallway adjacent to 101	WF-05232022-000419	11/8/2022	FT-FY23-10102022-000419-A	<1	FT-FY23-10102022-000419-B	<1	
WS- 000421	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to 213	WF-05232022-000421	11/8/2022	FT-FY23-10102022-000421-A	<1	FT-FY23-10102022-000421-B	<1	
WS- 000422	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to 201	WF-05232022-000422	11/8/2022	FT-FY23-10102022-000422-A	<1	FT-FY23-10102022-000422-B	<1	
WS- 000424	5/23/2022	5/23/2023	2	Cooler	In hallway adjacent to 231	WF-05232022-000424	11/8/2022	FT-FY23-10102022-000424-A	<1	FT-FY23-10102022-000424-B	<1	
WS- 000425	5/23/2022	5/23/2023	3	Break Room	In 304 staff lounge	WF-05232022-000425	11/8/2022	FT-FY23-10102022-000425-A	<1	FT-FY23-10102022-000425-B	<1	
WS- 000427	5/23/2022	5/23/2023	Ground Floor	Bottle Filler	In cafeteria bubble	WF-05232022-000427	11/8/2022	FT-FY23-10102022-000427-A	<1	FT-FY23-10102022-000427-B	<1	
WS- 000428	5/23/2022	5/23/2023	Ground Floor	Cooler	In cafeteria bubble	High Left	WF-05232022-000428	11/8/2022	FT-FY23-10102022-000428-A	<1	FT-FY23-10102022-000428-B	<1
WS- 000429	5/23/2022	5/23/2023	Ground Floor	Cooler	In cafeteria bubble	Low Right	WF-05232022-000429	11/8/2022	FT-FY23-10102022-000429-A	<1	FT-FY23-10102022-000429-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000432	2/22/2022	2/22/2023	Ground Floor	Food Prep Sink	In kitchen trailer 1st clockwise from outdoor entry	WF-02222022-000432	11/8/2022	FT-FY23-10102022-000432-A	<1	FT-FY23-10102022-000432-B	<1