



Whittier EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002331	10/14/2019	10/14/2020	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-10142019-002331	12/23/2019	FT-FY20-122019-002331-A	<1	FT-FY20-122019-002331-B	<1
WS- 002332	10/14/2019	10/14/2020	Ground Floor	Bathroom	In girls' restroom across from room 002 second from the left	WF-10142019-002332	12/23/2019	FT-FY20-122019-002332-A	<1	FT-FY20-122019-002332-B	<1
WS- 002334	10/14/2019	10/14/2020	Ground Floor	Bathroom	In girls' restroom across from room 002 third from the left	WF-10142019-002334	12/23/2019	FT-FY20-122019-002334-A	<1	FT-FY20-122019-002334-B	<1
WS- 002337	10/14/2019	10/14/2020	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the left	WF-10142019-002337	12/23/2019	FT-FY20-122019-002337-A	<1	FT-FY20-122019-002337-B	<1
WS- 002338	10/14/2019	10/14/2020	Ground Floor	Bathroom	In boys' restroom across from room 002 first from the left	WF-10142019-002338	12/23/2019	FT-FY20-122019-002338-A	<1	FT-FY20-122019-002338-B	<1
WS- 002340	10/14/2019	10/14/2020	Ground Floor	Bathroom	In boys' restroom across from room 002 second from the left	WF-10142019-002340	12/23/2019	FT-FY20-122019-002340-A	<1	FT-FY20-122019-002340-B	<1
WS- 002341	10/14/2019	10/14/2020	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the left	WF-10142019-002341	12/23/2019	FT-FY20-122019-002341-A	<1	FT-FY20-122019-002341-B	<1
WS- 003720	10/14/2019	10/14/2020	Ground Floor	Bathroom	In boys' restroom across from room 002 fourth from the left	WF-10142019-003720	12/23/2019	FT-FY20-122019-003720-A	<1	FT-FY20-122019-003720-B	<1
WS- 003722	5/20/2019	5/20/2020	1	Cooler	In hallway adjacent to room 138	WF-05202019-003722	12/23/2019	FT-FY20-122019-003722-A	<1	FT-FY20-122019-003722-B	<1
WS- 003723	5/20/2019	5/20/2020	1	Cooler	In hallway across from multi-purpose room	WF-05202019-003723	12/23/2019	FT-FY20-122019-003723-A	<1	FT-FY20-122019-003723-B	<1
WS- 003728	5/20/2019	5/20/2020	1	Cooler	In hallway across from room 102A	WF-05202019-003728	12/23/2019	FT-FY20-122019-003728-A	<1	FT-FY20-122019-003728-B	<1
WS- 003729	5/20/2019	5/20/2020	Ground Floor	Cooler	In hallway across from room 002	WF-05202019-003729	12/23/2019	FT-FY20-122019-003729-A	<1	FT-FY20-122019-003729-B	<1
WS- 003730	10/14/2019	10/14/2020	Ground Floor	Classroom Faucet	In classroom 002	WF-10142019-003730	12/23/2019	FT-FY20-122019-003730-A	<1	FT-FY20-122019-003730-B	<1
WS- 003731	10/14/2019	10/14/2020	Ground Floor	Classroom Faucet	In classroom 007	WF-10142019-003731	12/23/2019	FT-FY20-122019-003731-A	<1	FT-FY20-122019-003731-B	<1
WS- 003732	10/14/2019	10/14/2020	Ground Floor	Classroom Faucet	In classroom 003	WF-10142019-003732	12/23/2019	FT-FY20-122019-003732-A	1	FT-FY20-122019-003732-B	<1
WS- 003733	10/14/2019	10/14/2020	Ground Floor	Classroom Faucet	In classroom 004	WF-10142019-003733	12/23/2019	FT-FY20-122019-003733-A	<1	FT-FY20-122019-003733-B	<1
WS- 003734	10/14/2019	10/14/2020	Ground Floor	Classroom Faucet	In classroom 006	WF-10142019-003734	12/23/2019	FT-FY20-122019-003734-A	<1	FT-FY20-122019-003734-B	<1
WS- 003735	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to room 210	WF-05202019-003735	12/23/2019	FT-FY20-122019-003735-A	<1	FT-FY20-122019-003735-B	<1
WS- 003736	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to room 230	WF-05202019-003736	12/23/2019	FT-FY20-122019-003736-A	<1	FT-FY20-122019-003736-B	<1
WS- 003737	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to health suite	WF-05202019-003737	12/23/2019	FT-FY20-122019-003737-A	<1	FT-FY20-122019-003737-B	<1
WS- 003739	5/20/2019	5/20/2020	2	Health Suite	In health suite	WF-05202019-003739	12/23/2019	FT-FY20-122019-003739-A	<1	FT-FY20-122019-003739-B	<1
WS- 003741	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 308	WF-05202019-003741	12/23/2019	FT-FY20-122019-003741-A	<1	FT-FY20-122019-003741-B	<1
WS- 003746	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 310	WF-05202019-003746	12/23/2019	FT-FY20-122019-003746-A	<1	FT-FY20-122019-003746-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003724	7/2/2019	7/2/2020	1	Food Prep Sink	In kitchen	Mid	WF-07022019-003724	12/23/2019	FT-FY20-122019-003724-A	FT-FY20-122019-003724-B	<1