



# Whittier Education Campus Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002331	9/9/2024	9/9/2025	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-09092024-002331	12/3/2024	FT-FY25-10312024-002331-A	<2	FT-FY25-10312024-002331-B	<2
WS-002332	9/9/2024	9/9/2025	Ground Floor	Bathroom	In girls' restroom across from room 002 second from the left	WF-09092024-002332	12/3/2024	FT-FY25-10312024-002332-A	<2	FT-FY25-10312024-002332-B	<2
WS-002334	9/9/2024	9/9/2025	Ground Floor	Bathroom	In girls' restroom across from room 002 third from the left	WF-09092024-002334	12/3/2024	FT-FY25-10312024-002334-A	<2	FT-FY25-10312024-002334-B	<2
WS-002337	9/9/2024	9/9/2025	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the left	WF-09092024-002337	12/3/2024	FT-FY25-10312024-002337-A	<2	FT-FY25-10312024-002337-B	<2
WS-002338	9/9/2024	9/9/2025	Ground Floor	Bathroom	In boys' restroom across from room 002 first from the left	WF-09092024-002338	12/3/2024	FT-FY25-10312024-002338-A	<2	FT-FY25-10312024-002338-B	<2
WS-002340	9/9/2024	9/9/2025	Ground Floor	Bathroom	In boys' restroom across from room 002 second from the left	WF-09092024-002340	12/3/2024	FT-FY25-10312024-002340-A	<2	FT-FY25-10312024-002340-B	<2
WS-002341	9/9/2024	9/9/2025	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the left	WF-09092024-002341	12/3/2024	FT-FY25-10312024-002341-A	<2	FT-FY25-10312024-002341-B	<2
WS-002694	3/19/2024	3/19/2025	1	Bottle Filler	In hallway adjacent to room 138	WF-03192024-002694	12/3/2024	FT-FY25-10312024-002694-A	<2	FT-FY25-10312024-002694-B	<2
WS-002695	3/19/2024	3/19/2025	1	Bottle Filler	In hallway across from multi-purpose room	WF-03192024-002695	12/3/2024	FT-FY25-10312024-002695-A	<2	FT-FY25-10312024-002695-B	<2
WS-003720	9/9/2024	9/9/2025	Ground Floor	Bathroom	In boys' restroom across from room 002 fourth from the left	WF-09092024-003720	12/3/2024	FT-FY25-10312024-003720-A	<2	FT-FY25-10312024-003720-B	<2
WS-003722	3/19/2024	3/19/2025	1	Cooler	In hallway adjacent to room 138	WF-03192024-003722	12/3/2024	FT-FY25-10312024-003722-A	<2	FT-FY25-10312024-003722-B	<2
WS-003728	3/19/2024	3/19/2025	1	Cooler	In hallway across from room 102A	WF-03192024-003728	12/3/2024	FT-FY25-10312024-003728-A	<2	FT-FY25-10312024-003728-B	<2
WS-003729	3/19/2024	3/19/2025	Ground Floor	Cooler	In hallway across from room 002	WF-03192024-003729	12/3/2024	FT-FY25-10312024-003729-A	<2	FT-FY25-10312024-003729-B	<2
WS-003730	9/9/2024	9/9/2025	Ground Floor	Classroom Faucet	In classroom 002	WF-09092024-003730	12/3/2024	FT-FY25-10312024-003730-A	<2	FT-FY25-10312024-003730-B	<2
WS-003731	9/9/2024	9/9/2025	Ground Floor	Classroom Faucet	In classroom 007	WF-09092024-003731	12/3/2024	FT-FY25-10312024-003731-A	2.9	FT-FY25-10312024-003731-B	<2
WS-003732	9/9/2024	9/9/2025	Ground Floor	Classroom Faucet	In classroom 003	WF-09092024-003732	12/3/2024	FT-FY25-10312024-003732-A	3.1	FT-FY25-10312024-003732-B	<2
WS-003733	9/9/2024	9/9/2025	Ground Floor	Classroom Faucet	In classroom 004	WF-09092024-003733	12/3/2024	FT-FY25-10312024-003733-A	2.4	FT-FY25-10312024-003733-B	<2
WS-003735	3/19/2024	3/19/2025	2	Cooler	In hallway adjacent to room 210	WF-03192024-003735	12/3/2024	FT-FY25-10312024-003735-A	<2	FT-FY25-10312024-003735-B	<2
WS-003736	3/19/2024	3/19/2025	2	Cooler	In hallway adjacent to room 230	WF-03192024-003736	12/3/2024	FT-FY25-10312024-003736-A	<2	FT-FY25-10312024-003736-B	<2
WS-003737	3/19/2024	3/19/2025	2	Cooler	In hallway adjacent to health suite	WF-03192024-003737	12/3/2024	FT-FY25-10312024-003737-A	<2	FT-FY25-10312024-003737-B	<2
WS-003739	3/19/2024	3/19/2025	2	Health Suite	In health suite	WF-03192024-003739	12/3/2024	FT-FY25-10312024-003739-A	<2	FT-FY25-10312024-003739-B	<2
WS-003741	3/19/2024	3/19/2025	3	Cooler	In hallway adjacent to room 308	WF-03192024-003741	12/3/2024	FT-FY25-10312024-003741-A	<2	FT-FY25-10312024-003741-B	<2
WS-003746	3/19/2024	3/19/2025	3	Cooler	In hallway adjacent to room 310	WF-03192024-003746	12/3/2024	FT-FY25-10312024-003746-A	<2	FT-FY25-10312024-003746-B	<2
WS-004286	3/19/2024	3/19/2025	2	Bottle Filler	In hallway adjacent to room 230	WF-03192024-004286	12/3/2024	FT-FY25-10312024-004286-A	<2	FT-FY25-10312024-004286-B	<2
WS-004287	3/19/2024	3/19/2025	2	Bottle Filler	In hallway adjacent to health suite	WF-03192024-004287	12/3/2024	FT-FY25-10312024-004287-A	<2	FT-FY25-10312024-004287-B	<2
WS-004288	3/19/2024	3/19/2025	3	Bottle Filler	In hallway adjacent to room 308	WF-03192024-004288	12/3/2024	FT-FY25-10312024-004288-A	<2	FT-FY25-10312024-004288-B	<2
WS-004289	3/19/2024	3/19/2025	3	Bottle Filler	In hallway adjacent to room 310	WF-03192024-004289	12/3/2024	FT-FY25-10312024-004289-A	<2	FT-FY25-10312024-004289-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003724	12/11/2023	12/11/2024	1	Food Prep Sink	In kitchen	Mid	WF-12112023-003724	12/3/2024	FT-FY25-10312024-003724-A	<2	FT-FY25-10312024-003724-B	<2

### FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003734	9/9/2024	9/9/2025	Ground Floor	Classroom Faucet	in classroom 006	WF-09092024-003734	12/3/2024	FT-FY25-10312024-003734-A	12.5	FT-FY25-10312024-003734-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.