



Whittier Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002331	9/19/2022	9/19/2023	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-09192022-002331	1/9/2023	FT-FY23-11182022-002331-A	<1	FT-FY23-11182022-002331-B	<1
WS-002332	9/19/2022	9/19/2023	Ground Floor	Bathroom	In girls' restroom across from room 002 second from the left	WF-09192022-002332	1/9/2023	FT-FY23-11182022-002332-A	<1	FT-FY23-11182022-002332-B	<1
WS-002334	9/19/2022	9/19/2023	Ground Floor	Bathroom	In girls' restroom across from room 002 third from the left	WF-09192022-002334	1/9/2023	FT-FY23-11182022-002334-A	<1	FT-FY23-11182022-002334-B	<1
WS-002337	9/19/2022	9/19/2023	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the left	WF-09192022-002337	1/9/2023	FT-FY23-11182022-002337-A	<1	FT-FY23-11182022-002337-B	<1
WS-002338	9/19/2022	9/19/2023	Ground Floor	Bathroom	In boys' restroom across from room 002 first from the left	WF-09192022-002338	1/9/2023	FT-FY23-11182022-002338-A	<1	FT-FY23-11182022-002338-B	<1
WS-002340	9/19/2022	9/19/2023	Ground Floor	Bathroom	In boys' restroom across from room 002 second from the left	WF-09192022-002340	1/9/2023	FT-FY23-11182022-002340-A	<1	FT-FY23-11182022-002340-B	<1
WS-002341	9/19/2022	9/19/2023	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the left	WF-09192022-002341	1/9/2023	FT-FY23-11182022-002341-A	<1	FT-FY23-11182022-002341-B	<1
WS-002695	4/5/2022	4/5/2023	1	Bottle Filler	In hallway across from multi-purpose room	WF-04052022-002695	1/9/2023	FT-FY23-11182022-002695-A	<1	FT-FY23-11182022-002695-B	<1
WS-003720	9/19/2022	9/19/2023	Ground Floor	Bathroom	In boys' restroom across from room 002 fourth from the left	WF-09192022-003720	1/9/2023	FT-FY23-11182022-003720-A	<1	FT-FY23-11182022-003720-B	<1
WS-003728	4/5/2022	4/5/2023	1	Cooler	In hallway across from room 102A	WF-04052022-003728	1/9/2023	FT-FY23-11182022-003728-A	<1	FT-FY23-11182022-003728-B	<1
WS-003729	4/5/2022	4/5/2023	Ground Floor	Cooler	In hallway across from room 002	WF-04052022-003729	1/9/2023	FT-FY23-11182022-003729-A	<1	FT-FY23-11182022-003729-B	<1
WS-003730	9/19/2022	9/19/2023	Ground Floor	Classroom Faucet	In classroom 002	WF-09192022-003730	1/9/2023	FT-FY23-11182022-003730-A	<1	FT-FY23-11182022-003730-B	<1
WS-003731	9/19/2022	9/19/2023	Ground Floor	Classroom Faucet	In classroom 007	WF-09192022-003731	1/9/2023	FT-FY23-11182022-003731-A	<1	FT-FY23-11182022-003731-B	<1
WS-003733	9/19/2022	9/19/2023	Ground Floor	Classroom Faucet	In classroom 004	WF-09192022-003733	1/9/2023	FT-FY23-11182022-003733-A	<1	FT-FY23-11182022-003733-B	<1
WS-003734	9/19/2022	9/19/2023	Ground Floor	Classroom Faucet	In classroom 006	WF-09192022-003734	1/9/2023	FT-FY23-11182022-003734-A	1.2	FT-FY23-11182022-003734-B	<1
WS-003735	4/5/2022	4/5/2023	2	Cooler	In hallway adjacent to room 210	WF-04052022-003735	1/9/2023	FT-FY23-11182022-003735-A	<1	FT-FY23-11182022-003735-B	<1
WS-003736	6/14/2022	6/14/2023	2	Cooler	In hallway adjacent to room 230	WF-06142022-003736	1/9/2023	FT-FY23-11182022-003736-A	<1	FT-FY23-11182022-003736-B	<1
WS-003737	6/14/2022	6/14/2023	2	Cooler	In hallway adjacent to health suite	WF-06142022-003737	1/9/2023	FT-FY23-11182022-003737-A	<1	FT-FY23-11182022-003737-B	<1
WS-003739	4/5/2022	4/5/2023	2	Health Suite	In health suite	WF-04052022-003739	1/9/2023	FT-FY23-11182022-003739-A	<1	FT-FY23-11182022-003739-B	<1
WS-003741	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to room 308	WF-04052022-003741	1/9/2023	FT-FY23-11182022-003741-A	<1	FT-FY23-11182022-003741-B	<1
WS-003746	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to room 310	WF-04052022-003746	1/9/2023	FT-FY23-11182022-003746-A	<1	FT-FY23-11182022-003746-B	<1
WS-004286	6/14/2022	6/14/2023	2	Bottle Filler	In hallway adjacent to room 230	WF-06142022-004286	1/9/2023	FT-FY23-11182022-004286-A	<1	FT-FY23-11182022-004286-B	<1
WS-004287	6/14/2022	6/14/2023	2	Bottle Filler	In hallway adjacent to health suite	WF-06142022-004287	1/9/2023	FT-FY23-11182022-004287-A	<1	FT-FY23-11182022-004287-B	<1
WS-004288	4/5/2022	4/5/2023	3	Bottle Filler	In hallway adjacent to room 308	WF-04052022-004288	1/9/2023	FT-FY23-11182022-004288-A	<1	FT-FY23-11182022-004288-B	<1
WS-004289	4/5/2022	4/5/2023	3	Bottle Filler	In hallway adjacent to room 310	WF-04052022-004289	1/9/2023	FT-FY23-11182022-004289-A	<1	FT-FY23-11182022-004289-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003724	1/26/2022	1/26/2023	1	Food Prep Sink	In kitchen	Mid	WF-01262022-003724	1/9/2023	FT-FY23-11182022-003724-A	<1	FT-FY23-11182022-003724-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003732	9/19/2022	9/19/2023	Ground Floor	Classroom Faucet	In classroom 003	WF-09192022-003732	1/9/2023	FT-FY23-11182022-003732-A	6.0	FT-FY23-11182022-003732-B	<1