



Whittier Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002331	10/5/2020	10/5/2021	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-10052020-002331	3/3/2021	FT-FY21-022021-002331-A	<1	FT-FY21-022021-002331-B	<1
WS- 002332	10/5/2020	10/5/2021	Ground Floor	Bathroom	In girls' restroom across from room 002 second from the left	WF-10052020-002332	3/3/2021	FT-FY21-022021-002332-A	<1	FT-FY21-022021-002332-B	<1
WS- 002334	10/5/2020	10/5/2021	Ground Floor	Bathroom	In girls' restroom across from room 002 third from the left	WF-10052020-002334	3/3/2021	FT-FY21-022021-002334-A	<1	FT-FY21-022021-002334-B	<1
WS- 002337	10/5/2020	10/5/2021	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the left	WF-10052020-002337	3/3/2021	FT-FY21-022021-002337-A	<1	FT-FY21-022021-002337-B	<1
WS- 002338	10/5/2020	10/5/2021	Ground Floor	Bathroom	In boys' restroom across from room 002 first from the left	WF-10052020-002338	3/3/2021	FT-FY21-022021-002338-A	<1	FT-FY21-022021-002338-B	<1
WS- 002340	10/5/2020	10/5/2021	Ground Floor	Bathroom	In boys' restroom across from room 002 second from the left	WF-10052020-002340	3/3/2021	FT-FY21-022021-002340-A	<1	FT-FY21-022021-002340-B	<1
WS- 002341	10/5/2020	10/5/2021	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the left	WF-10052020-002341	3/3/2021	FT-FY21-022021-002341-A	<1	FT-FY21-022021-002341-B	<1
WS- 003720	10/5/2020	10/5/2021	Ground Floor	Bathroom	In boys' restroom across from room 002 fourth from the left	WF-10052020-003720	3/3/2021	FT-FY21-022021-003720-A	<1	FT-FY21-022021-003720-B	<1
WS- 003722	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to room 138	WF-05132020-003722	3/3/2021	FT-FY21-022021-003722-A	<1	FT-FY21-022021-003722-B	<1
WS- 003728	5/13/2020	5/13/2021	1	Cooler	In hallway across from room 102A	WF-05132020-003728	3/3/2021	FT-FY21-022021-003728-A	<1	FT-FY21-022021-003728-B	<1
WS- 003729	5/13/2020	5/13/2021	Ground Floor	Cooler	In hallway across from room 002	WF-05132020-003729	3/3/2021	FT-FY21-022021-003729-A	<1	FT-FY21-022021-003729-B	<1
WS- 003730	10/5/2020	10/5/2021	Ground Floor	Classroom Faucet	In classroom 002	WF-10052020-003730	3/3/2021	FT-FY21-022021-003730-A	<1	FT-FY21-022021-003730-B	<1
WS- 003731	10/5/2020	10/5/2021	Ground Floor	Classroom Faucet	In classroom 007	WF-10052020-003731	3/3/2021	FT-FY21-022021-003731-A	<1	FT-FY21-022021-003731-B	<1
WS- 003732	10/5/2020	10/5/2021	Ground Floor	Classroom Faucet	In classroom 003	WF-10052020-003732	3/3/2021	FT-FY21-022021-003732-A	1.4	FT-FY21-022021-003732-B	<1
WS- 003733	10/5/2020	10/5/2021	Ground Floor	Classroom Faucet	In classroom 004	WF-10052020-003733	3/3/2021	FT-FY21-022021-003733-A	<1	FT-FY21-022021-003733-B	<1
WS- 003734	10/5/2020	10/5/2021	Ground Floor	Classroom Faucet	In classroom 006	WF-10052020-003734	3/3/2021	FT-FY21-022021-003734-A	<1	FT-FY21-022021-003734-B	<1
WS- 003735	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to room 210	WF-05132020-003735	3/3/2021	FT-FY21-022021-003735-A	<1	FT-FY21-022021-003735-B	<1
WS- 003736	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to room 230	WF-05132020-003736	3/3/2021	FT-FY21-022021-003736-A	<1	FT-FY21-022021-003736-B	<1
WS- 003737	5/13/2020	5/13/2021	2	Cooler	In hallway adjacent to health suite	WF-05132020-003737	3/3/2021	FT-FY21-022021-003737-A	<1	FT-FY21-022021-003737-B	<1
WS- 003739	5/13/2020	5/13/2021	2	Health Suite	In health suite	WF-05132020-003739	3/3/2021	FT-FY21-022021-003739-A	<1	FT-FY21-022021-003739-B	<1
WS- 003741	5/13/2020	5/13/2021	3	Cooler	In hallway adjacent to room 308	WF-05132020-003741	3/3/2021	FT-FY21-022021-003741-A	<1	FT-FY21-022021-003741-B	<1
WS- 004286	11/23/2020	11/23/2021	2	Bottle Filler	In hallway adjacent to room 230	WF-11232020-004286	3/3/2021	FT-FY21-032021-004286-A	<1	FT-FY21-032021-004286-B	<1
WS- 004287	11/23/2020	11/23/2021	2	Bottle Filler	In hallway adjacent to health suite	WF-11232020-004287	3/3/2021	FT-FY21-032021-004287-A	<1	FT-FY21-032021-004287-B	<1
WS- 004288	11/23/2020	11/23/2021	3	Bottle Filler	In hallway adjacent to room 308	WF-11232020-004288	3/3/2021	FT-FY21-032021-004288-A	<1	FT-FY21-032021-004288-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003724	2/4/2021	2/4/2022	1	Food Prep Sink	In kitchen	Mid	WF-02042021-003724	3/3/2021	FT-FY21-022021-003724-A	<1	FT-FY21-022021-003724-B	<1