



# Whittier Education Campus Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002331	9/3/2025	9/3/2026	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-09032025-002331	12/6/2025	FT-FY26-10172025-002331-A	<2	FT-FY26-10172025-002331-B	<2
WS-002334	9/3/2025	9/3/2026	Ground Floor	Bathroom	In girls' restroom across from room 002 third from the left	WF-09032025-002334	12/6/2025	FT-FY26-10172025-002334-A	<2	FT-FY26-10172025-002334-B	<2
WS-002337	9/3/2025	9/3/2026	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the left	WF-09032025-002337	12/6/2025	FT-FY26-10172025-002337-A	<2	FT-FY26-10172025-002337-B	<2
WS-002338	9/3/2025	9/3/2026	Ground Floor	Bathroom	In boys' restroom across from room 002 first from the left	WF-09032025-002338	12/6/2025	FT-FY26-10172025-002338-A	<2	FT-FY26-10172025-002338-B	<2
WS-002340	9/3/2025	9/3/2026	Ground Floor	Bathroom	In boys' restroom across from room 002 second from the left	WF-09032025-002340	12/6/2025	FT-FY26-10172025-002340-A	<2	FT-FY26-10172025-002340-B	<2
WS-002341	9/3/2025	9/3/2026	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the left	WF-09032025-002341	12/6/2025	FT-FY26-10172025-002341-A	<2	FT-FY26-10172025-002341-B	<2
WS-002694	3/12/2025	3/12/2026	1	Bottle Filler	In hallway adjacent to room 138	WF-03122025-002694	12/6/2025	FT-FY26-10172025-002694-A	<2	FT-FY26-10172025-002694-B	<2
WS-002695	3/12/2025	3/12/2026	1	Bottle Filler	In hallway across from multi-purpose room	WF-03122025-002695	12/6/2025	FT-FY26-10172025-002695-A	<2	FT-FY26-10172025-002695-B	<2
WS-003720	9/3/2025	9/3/2026	Ground Floor	Bathroom	In boys' restroom across from room 002 fourth from the left	WF-09032025-003720	12/6/2025	FT-FY26-10172025-003720-A	<2	FT-FY26-10172025-003720-B	<2
WS-003722	3/12/2025	3/12/2026	1	Cooler	In hallway adjacent to room 138	WF-03122025-003722	12/6/2025	FT-FY26-10172025-003722-A	<2	FT-FY26-10172025-003722-B	<2
WS-003723	3/12/2025	3/12/2026	1	Cooler	In hallway across from multi-purpose room	WF-03122025-003723	12/6/2025	FT-FY26-10172025-003723-A	<2	FT-FY26-10172025-003723-B	<2
WS-003729	3/12/2025	3/12/2026	Ground Floor	Cooler	In hallway across from room 002	WF-03122025-003729	12/6/2025	FT-FY26-10172025-003729-A	<2	FT-FY26-10172025-003729-B	<2
WS-003730	9/3/2025	9/3/2026	Ground Floor	Classroom Faucet	In classroom 002	WF-09032025-003730	12/6/2025	FT-FY26-10172025-003730-A	2.2	FT-FY26-10172025-003730-B	<2
WS-003731	9/3/2025	9/3/2026	Ground Floor	Classroom Faucet	In classroom 007	WF-09032025-003731	12/6/2025	FT-FY26-10172025-003731-A	<2	FT-FY26-10172025-003731-B	<2
WS-003732	9/3/2025	9/3/2026	Ground Floor	Classroom Faucet	In classroom 003	WF-09032025-003732	12/6/2025	FT-FY26-10172025-003732-A	<2	FT-FY26-10172025-003732-B	<2
WS-003733	9/3/2025	9/3/2026	Ground Floor	Classroom Faucet	In classroom 004	WF-09032025-003733	12/6/2025	FT-FY26-10172025-003733-A	<2	FT-FY26-10172025-003733-B	<2
WS-003734	9/3/2025	9/3/2026	Ground Floor	Classroom Faucet	In classroom 006	WF-09032025-003734	12/6/2025	FT-FY26-10172025-003734-A	2.3	FT-FY26-10172025-003734-B	<2
WS-003735	3/12/2025	3/12/2026	2	Cooler	In hallway adjacent to room 210	WF-03122025-003735	12/6/2025	FT-FY26-10172025-003735-A	<2	FT-FY26-10172025-003735-B	<2
WS-003736	3/12/2025	3/12/2026	2	Cooler	In hallway adjacent to room 230	WF-03122025-003736	12/6/2025	FT-FY26-10172025-003736-A	<2	FT-FY26-10172025-003736-B	<2
WS-003739	3/12/2025	3/12/2026	2	Health Suite	In health suite	WF-03122025-003739	12/6/2025	FT-FY26-10172025-003739-A	<2	FT-FY26-10172025-003739-B	<2
WS-003741	3/12/2025	3/12/2026	3	Cooler	In hallway adjacent to room 308	WF-03122025-003741	12/6/2025	FT-FY26-10172025-003741-A	<2	FT-FY26-10172025-003741-B	<2
WS-003746	3/12/2025	3/12/2026	3	Cooler	In hallway adjacent to room 310	WF-03122025-003746	12/6/2025	FT-FY26-10172025-003746-A	<2	FT-FY26-10172025-003746-B	<2
WS-004286	3/12/2025	3/12/2026	2	Bottle Filler	In hallway adjacent to room 230	WF-03122025-004286	12/6/2025	FT-FY26-10172025-004286-A	<2	FT-FY26-10172025-004286-B	<2
WS-004288	3/12/2025	3/12/2026	3	Bottle Filler	In hallway adjacent to room 308	WF-03122025-004288	12/6/2025	FT-FY26-10172025-004288-A	<2	FT-FY26-10172025-004288-B	<2
WS-004289	3/12/2025	3/12/2026	3	Bottle Filler	In hallway adjacent to room 310	WF-03122025-004289	12/6/2025	FT-FY26-10172025-004289-A	<2	FT-FY26-10172025-004289-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003724	12/9/2024	12/9/2025	1	Food Prep Sink	In kitchen Mid	WF-12092024-003724	12/6/2025	FT-FY26-10172025-003724-A	<2	FT-FY26-10172025-003724-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.