



# WHITTIER LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003721	Utility	Basement	In boiler room (Main source)	WT-042916-3738- A	1.5	WT-042916-3738- B	< 1				
2 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003722	Cooler	1	In hallway adjacent to room 138	WT-042916-3739- A	< 1	WT-042916-3739- B	< 1				
3 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003723	Cooler	1	In hallway across from multipurpose room	WT-042916-3740- A	< 1	WT-042916-3740- B	< 1				
4 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003724	Kitchen	1	In kitchen Mid	WT-042916-3741- A	< 1	WT-042916-3741- B	< 1				
5 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003725	Kitchen	1	In kitchen Right	WT-042916-3742- A	< 1	WT-042916-3742- B	< 1				
6 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003726	Kitchen	1	In kitchen Left	WT-042916-3743- A	< 1	WT-042916-3743- B	< 1				
7 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003727	Classroom	1	In art room	WT-042916-3744- A	< 1	WT-042916-3744- B	< 1				
8 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003728	Cooler	1	In hallway adjacent to teachers bathroom	WT-042916-3745- A	< 1	WT-042916-3745- B	< 1				
9 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003729	Cooler	Ground Floor	In hallway adjacent to teachers bathroom	WT-042916-3746- A	< 1	WT-042916-3746- B	< 1				
10 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003730	Classroom	Ground Floor	In room 002	WT-042916-3747- A	< 1	WT-042916-3747- B	1.2				
11 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003731	Classroom	Ground Floor	In classroom 007	WT-042916-3748- A	< 1	WT-042916-3748- B	< 1				
12 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003732	Classroom	Ground Floor	In room 003	WT-042916-3749- A	< 1	WT-042916-3749- B	< 1				
13 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003733	Classroom	Ground Floor	In classroom 004	WT-042916-3750- A	< 1	WT-042916-3750- B	< 1				
14 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003734	Classroom	Ground Floor	In room 006	WT-042916-3751- A	< 1	WT-042916-3751- B	< 1				
15 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003735	Cooler	2	In hallway adjacent to the teachers restroom 210	WT-042916-3752- A	< 1	WT-042916-3752- B	< 1				
16 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003736	Cooler	2	In hallway adjacent to room 230	WT-042916-3753- A	< 1	WT-042916-3753- B	< 1				
17 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003737	Cooler	2	In hallway adjacent to health suite	WT-042916-3754- A	< 1	WT-042916-3754- B	< 1				
18 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003738	Other	2	In main office	WT-042916-3755- A	< 1	WT-042916-3755- B	1.7				
19 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003739	Health Suite	2	In health suite	WT-042916-3756- A	< 1	WT-042916-3756- B	< 1				
20 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003740	Classroom	2	In room 226	WT-042916-3757- A	9.8	WT-042916-3757- B	4.8				
21 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003741	Cooler	3	In hallway adjacent to room 308	WT-042916-3758- A	3.7	WT-042916-3758- B	2.4				
22 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003742	Classroom	3	In room 304 south wall Right	WT-042916-3759- A	17	WT-042916-3759- B	3.5	Filter will be installed and then retested			
23 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003743	Classroom	3	In classroom 304 south wall Mid	WT-042916-3760- A	1.2	WT-042916-3760- B	< 1				
24 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003744	Classroom	3	In classroom 304 south wall Left	WT-042916-3761- A	< 1	WT-042916-3761- B	< 1				
25 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003745	Classroom	3	In classroom 304 south wall	WT-042916-3762- A	1.8	WT-042916-3762- B	< 1				
26 WHITTIER EDUCATIONAL CAMPUS	5/6/2016	WS- 003746	Cooler	3	In hallway adjacent to 310	WT-042916-3763- A	< 1	WT-042916-3763- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.