



Whittier EC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002331	11/15/2017	11/15/2018	Ground Floor	Bathroom	In girls' restroom across from room 002 first from the left	WF-112017-002331	11/29/2017	FT-FY18-112017-002331-A	<1	FT-FY18-112017-002331-B	<1
WS-002332	11/15/2017	11/15/2018	Ground Floor	Bathroom	In girls' restroom across from room 002 second from the	WF-112017-002332	11/29/2017	FT-FY18-112017-002332-A	<1	FT-FY18-112017-002332-B	<1
WS-002337	11/15/2017	11/15/2018	Ground Floor	Bathroom	In girls' restroom across from room 002 fourth from the	WF-112017-002337	11/29/2017	FT-FY18-112017-002337-A	<1	FT-FY18-112017-002337-B	<1
WS-002341	11/15/2017	11/15/2018	Ground Floor	Bathroom	In boys' restroom across from room 002 third from the	WF-112017-002341	11/29/2017	FT-FY18-112017-002341-A	<1	FT-FY18-112017-002341-B	<1
WS-003729	6/20/2017	6/20/2018	Ground Floor	Cooler	In hallway across from room 002	WF-62017-003729	11/29/2017	FT-FY18--62017-003729-A	<1	FT-FY18--62017-003729-B	<1
WS-003734	11/15/2017	11/15/2018	Ground Floor	Classroom Faucet	In classroom 006	WF-112017-003734	11/29/2017	FT-FY18-112017-003734-A	<1	FT-FY18-112017-003734-B	<1
WS-003737	6/20/2017	6/20/2018	2	Cooler	In hallway adjacent to health suite	WF-62017-003737	11/29/2017	FT-FY18--62017-003737-A	<1	FT-FY18--62017-003737-B	<1
WS-003746	6/20/2017	6/20/2018	3	Cooler	In hallway adjacent to room 310	WF-62017-003746	11/29/2017	FT-FY18--62017-003746-A	<1	FT-FY18--62017-003746-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003724	1	Food Prep Sink	In kitchen Mid	11/29/2017	FT-FY18-102017-003724-A	<1	FT-FY18-102017-003724-B	<1
WS-003725	1	Food Prep Sink	In kitchen Right	11/29/2017	FT-FY18-102017-003725-A	<1	FT-FY18-102017-003725-B	<1