



WILLIAM RUMSEY LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	WILLIAM RUMSEY SR	WS- 005676	9/22/2016	1	Cooler	In hallway adjacent to women's restroom High Right	FT-82016-005676-A	< 1	FT-82016-005676-B	< 1
2	WILLIAM RUMSEY SR	WS- 005677	9/22/2016	1	Cooler	In hallway adjacent to women's restroom Low Left	FT-82016-005677-A	< 1	FT-82016-005677-B	< 1