



Wilson AC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012031	3/20/2020	3/20/2021	1	Cooler	In hallway adjacent to room 113	High Left	WF-03202020-012031	3/18/2021	FT-FY21-032021-012031-A	<1	FT-FY21-032021-012031-B	<1
WS- 012032	3/20/2020	3/20/2021	1	Cooler	In hallway adjacent to room 114	Low Right	WF-03202020-012032	3/18/2021	FT-FY21-032021-012032-A	<1	FT-FY21-032021-012032-B	<1
WS- 012033	3/20/2020	3/20/2021	1	Cooler	In pool area	High Left	WF-03202020-012033	3/18/2021	FT-FY21-032021-012033-A	<1	FT-FY21-032021-012033-B	<1
WS- 012034	3/20/2020	3/20/2021	1	Cooler	In pool area	Low Right	WF-03202020-012034	3/18/2021	FT-FY21-032021-012034-A	<1	FT-FY21-032021-012034-B	<1
WS- 012382	3/20/2020	3/20/2021	2	Cooler	In hallway across from 219 spectator seating	High Left	WF-03202020-012382	3/18/2021	FT-FY21-032021-012382-A	<1	FT-FY21-032021-012382-B	<1
WS- 012383	3/20/2020	3/20/2021	2	Cooler	In hallway across from 219 spectator seating	Low Right	WF-03202020-012383	3/18/2021	FT-FY21-032021-012383-A	<1	FT-FY21-032021-012383-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012029	1/11/2021	1/11/2022	2	Food Prep Sink	In recreation room 212		WF-01112021-012029	3/18/2021	FT-FY21-032021-012029-A	<1	FT-FY21-032021-012029-B	<1