



WILSON HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	W. WILSON HIGH SCHOOL	WS- 012348	8/21/2016	Basement	Cooler	In boy's locker room High Left	FT-82016-012348-A	< 1	FT-82016-012348-B	< 1
2	W. WILSON HIGH SCHOOL	WS- 012349	8/21/2016	Basement	Cooler	In boy's locker room Low Right	FT-82016-012349-A	< 1	FT-82016-012349-B	< 1
3	W. WILSON HIGH SCHOOL	WS- 012350	8/21/2016	Basement	Cooler	In girls' locker room High Left	FT-82016-012350-A	< 1	FT-82016-012350-B	< 1
4	W. WILSON HIGH SCHOOL	WS- 012351	8/21/2016	Basement	Cooler	In girls' locker room Low Right	FT-82016-012351-A	< 1	FT-82016-012351-B	< 1
5	W. WILSON HIGH SCHOOL	WS- 012352	8/21/2016	1	Cooler	In hallway adjacent to room A201A High Left	FT-82016-012352-A	< 1	FT-82016-012352-B	< 1
6	W. WILSON HIGH SCHOOL	WS- 012353	8/21/2016	1	Cooler	In hallway adjacent to room A201A Low Right	FT-82016-012353-A	< 1	FT-82016-012353-B	< 1
7	W. WILSON HIGH SCHOOL	WS- 012358	8/21/2016	1	Food Prep Sink	In kitchen	FT-82016-012358-A	< 1	FT-82016-012358-B	< 1
8	W. WILSON HIGH SCHOOL	WS- 012360	8/21/2016	1	Cooler	In hallway adjacent to room 119	FT-82016-012360-A	< 1	FT-82016-012360-B	< 1
9	W. WILSON HIGH SCHOOL	WS- 012363	8/21/2016	1	Cooler	In hallway adjacent to career center 108A	FT-82016-012363-A	< 1	FT-82016-012363-B	< 1
10	W. WILSON HIGH SCHOOL	WS- 012365	8/21/2016	1	Health Suite	In health suite	FT-82016-012365-A	< 1	FT-82016-012365-B	< 1
11	W. WILSON HIGH SCHOOL	WS- 012369	8/21/2016	1	Cooler	In hallway across from room B101	FT-82016-012369-A	< 1	FT-82016-012369-B	< 1
12	W. WILSON HIGH SCHOOL	WS- 012371	8/21/2016	1	Cooler	In hallway adjacent to room B109	FT-82016-012371-A	< 1	FT-82016-012371-B	< 1
13	W. WILSON HIGH SCHOOL	WS- 012381	8/21/2016	2	Cooler	In hallway adjacent to room A203b	FT-82016-012381-A	< 1	FT-82016-012381-B	< 1
14	W. WILSON HIGH SCHOOL	WS- 012382	8/21/2016	2	Cooler	In recreation area High Left	FT-82016-012382-A	< 1	FT-82016-012382-B	< 1
15	W. WILSON HIGH SCHOOL	WS- 012383	8/21/2016	2	Cooler	In recreation area Low Right	FT-82016-012383-A	< 1	FT-82016-012383-B	< 1
16	W. WILSON HIGH SCHOOL	WS- 012384	8/21/2016	2	Cooler	In hallway adjacent to room 223	FT-82016-012384-A	< 1	FT-82016-012384-B	< 1
17	W. WILSON HIGH SCHOOL	WS- 012385	8/21/2016	2	Cooler	In hallway adjacent to room 222	FT-82016-012385-A	< 1	FT-82016-012385-B	< 1
18	W. WILSON HIGH SCHOOL	WS- 012388	8/21/2016	2	Cooler	In hallway adjacent to room 213	FT-82016-012388-A	< 1	FT-82016-012388-B	< 1
19	W. WILSON HIGH SCHOOL	WS- 012389	8/21/2016	2	Cooler	In hallway adjacent to room 211	FT-82016-012389-A	< 1	FT-82016-012389-B	< 1
20	W. WILSON HIGH SCHOOL	WS- 012390	8/21/2016	2	Cooler	In hallway adjacent to room 200	FT-82016-012390-A	< 1	FT-82016-012390-B	< 1
21	W. WILSON HIGH SCHOOL	WS- 012391	8/21/2016	2	Cooler	In hallway adjacent to room 232	FT-82016-012391-A	< 1	FT-82016-012391-B	< 1
22	W. WILSON HIGH SCHOOL	WS- 012410	8/21/2016	2	Cooler	In hallway adjacent to room B202	FT-82016-012410-A	< 1	FT-82016-012410-B	< 1
23	W. WILSON HIGH SCHOOL	WS- 012412	8/21/2016	2	Cooler	In hallway adjacent to room B204 Left	FT-82016-012412-A	< 1	FT-82016-012412-B	< 1
24	W. WILSON HIGH SCHOOL	WS- 012413	8/21/2016	2	Cooler	In hallway adjacent to room C204 High Left	FT-82016-012413-A	< 1	FT-82016-012413-B	< 1
25	W. WILSON HIGH SCHOOL	WS- 012414	8/21/2016	2	Cooler	In hallway adjacent to room C204 Low Right	FT-82016-012414-A	< 1	FT-82016-012414-B	< 1
26	W. WILSON HIGH SCHOOL	WS- 012415	8/21/2016	2	Cooler	In hallway adjacent to room C207 High Left	FT-82016-012415-A	< 1	FT-82016-012415-B	< 1
27	W. WILSON HIGH SCHOOL	WS- 012416	8/21/2016	2	Cooler	In hallway adjacent to room C207 Low Right	FT-82016-012416-A	< 1	FT-82016-012416-B	< 1
28	W. WILSON HIGH SCHOOL	WS- 012417	8/21/2016	3	Cooler	In hallway adjacent to room 303	FT-82016-012417-A	< 1	FT-82016-012417-B	< 1
29	W. WILSON HIGH SCHOOL	WS- 012418	8/21/2016	3	Cooler	In hallway adjacent to room 331	FT-82016-012418-A	< 1	FT-82016-012418-B	< 1
30	W. WILSON HIGH SCHOOL	WS- 012430	8/21/2016	3	Classroom Faucet	In hallway adjacent to room 321	FT-82016-012430-A	< 1	FT-82016-012430-B	< 1
31	W. WILSON HIGH SCHOOL	WS- 012431	8/21/2016	3	Cooler	In hallway adjacent to room 320	FT-82016-012431-A	< 1	FT-82016-012431-B	< 1
32	W. WILSON HIGH SCHOOL	WS- 012433	8/21/2016	3	Cooler	In hallway adjacent to room 314	FT-82016-012433-A	< 1	FT-82016-012433-B	< 1
33	W. WILSON HIGH SCHOOL	WS- 012434	8/21/2016	3	Cooler	In hallway adjacent to room 312	FT-82016-012434-A	< 1	FT-82016-012434-B	< 1
34	W. WILSON HIGH SCHOOL	WS- 012435	8/21/2016	3	Cooler	In hallway adjacent to B301	FT-82016-012435-A	< 1	FT-82016-012435-B	< 1
35	W. WILSON HIGH SCHOOL	WS- 012436	8/21/2016	3	Cooler	In hallway adjacent to room B308	FT-82016-012436-A	< 1	FT-82016-012436-B	< 1
36	W. WILSON HIGH SCHOOL	WS- 012437	8/21/2016	4	Cooler	In hallway adjacent to room 421	FT-82016-012437-A	< 1	FT-82016-012437-B	< 1
37	W. WILSON HIGH SCHOOL	WS- 012438	8/21/2016	4	Cooler	In hallway adjacent to room 422	FT-82016-012438-A	< 1	FT-82016-012438-B	< 1
38	W. WILSON HIGH SCHOOL	WS- 012440	8/21/2016	4	Cooler	In hallway adjacent to room 414	FT-82016-012440-A	< 1	FT-82016-012440-B	< 1
39	W. WILSON HIGH SCHOOL	WS- 012441	8/21/2016	4	Cooler	In hallway adjacent to room 412	FT-82016-012441-A	< 1	FT-82016-012441-B	< 1
40	W. WILSON HIGH SCHOOL	WS- 012442	8/21/2016	4	Cooler	In hallway adjacent to room 403	FT-82016-012442-A	< 1	FT-82016-012442-B	< 1
41	W. WILSON HIGH SCHOOL	WS- 012443	8/21/2016	4	Cooler	In hallway adjacent to room 431	FT-82016-012443-A	< 1	FT-82016-012443-B	< 1