



Wilson High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012348	4/5/2021	4/5/2022	Basement	Cooler	In boy's locker room High Left	WF-04052021-012348	4/13/2021	FT-FY21-042021-012348-A	<1	FT-FY21-042021-012348-B	<1
WS- 012349	4/5/2021	4/5/2022	Basement	Cooler	In boy's locker room Low Right	WF-04052021-012349	4/13/2021	FT-FY21-042021-012349-A	<1	FT-FY21-042021-012349-B	<1
WS- 012350	4/5/2021	4/5/2022	Basement	Cooler	In girls' locker room High Left	WF-04052021-012350	4/13/2021	FT-FY21-042021-012350-A	<1	FT-FY21-042021-012350-B	<1
WS- 012351	4/5/2021	4/5/2022	Basement	Cooler	In girls' locker room Low Right	WF-04052021-012351	4/13/2021	FT-FY21-042021-012351-A	<1	FT-FY21-042021-012351-B	<1
WS- 012360	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to room 119	WF-04052021-012360	4/13/2021	FT-FY21-042021-012360-A	<1	FT-FY21-042021-012360-B	<1
WS- 012363	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to career center 108A	WF-04052021-012363	4/13/2021	FT-FY21-042021-012363-A	<1	FT-FY21-042021-012363-B	<1
WS- 012364	4/5/2021	4/5/2022	1	Break Room	In main office	WF-04052021-012364	4/13/2021	FT-FY21-042021-012364-A	<1	FT-FY21-042021-012364-B	<1
WS- 012365	4/5/2021	4/5/2022	1	Health Suite	In health suite	WF-04052021-012365	4/13/2021	FT-FY21-042021-012365-A	1.3	FT-FY21-042021-012365-B	<1
WS- 012369	4/5/2021	4/5/2022	1	Cooler	In hallway across from room B101	WF-04052021-012369	4/13/2021	FT-FY21-042021-012369-A	<1	FT-FY21-042021-012369-B	<1
WS- 012371	4/5/2021	4/5/2022	1	Cooler	In hallway adjacent to room B109	WF-04052021-012371	4/13/2021	FT-FY21-042021-012371-A	<1	FT-FY21-042021-012371-B	<1
WS- 012381	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room A203b	WF-04052021-012381	4/13/2021	FT-FY21-042021-012381-A	<1	FT-FY21-042021-012381-B	<1
WS- 012384	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room 223	WF-04052021-012384	4/13/2021	FT-FY21-042021-012384-A	<1	FT-FY21-042021-012384-B	<1
WS- 012385	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room 222	WF-04052021-012385	4/13/2021	FT-FY21-042021-012385-A	2.7	FT-FY21-042021-012385-B	2.5
WS- 012387	4/5/2021	4/5/2022	2	Break Room	In staff lounge 207E	WF-04052021-012387	4/13/2021	FT-FY21-042021-012387-A	<1	FT-FY21-042021-012387-B	<1
WS- 012390	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room 200	WF-04052021-012390	4/13/2021	FT-FY21-042021-012390-A	1.8	FT-FY21-042021-012390-B	<1
WS- 012391	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room 232	WF-04052021-012391	4/13/2021	FT-FY21-042021-012391-A	<1	FT-FY21-042021-012391-B	<1
WS- 012410	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room B202	WF-04052021-012410	4/13/2021	FT-FY21-042021-012410-A	<1	FT-FY21-042021-012410-B	<1
WS- 012412	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room B204 High Left	WF-04052021-012412	4/13/2021	FT-FY21-042021-012412-A	<1	FT-FY21-042021-012412-B	<1
WS- 012415	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room C207 High Left	WF-04052021-012415	4/13/2021	FT-FY21-042021-012415-A	<1	FT-FY21-042021-012415-B	<1
WS- 012416	4/5/2021	4/5/2022	2	Cooler	In hallway adjacent to room C207 Low Right	WF-04052021-012416	4/13/2021	FT-FY21-042021-012416-A	<1	FT-FY21-042021-012416-B	<1
WS- 012417	4/5/2021	4/5/2022	3	Cooler	In hallway adjacent to room 303	WF-04052021-012417	4/13/2021	FT-FY21-042021-012417-A	<1	FT-FY21-042021-012417-B	<1
WS- 012433	4/5/2021	4/5/2022	3	Cooler	In hallway adjacent to room 314	WF-04052021-012433	4/13/2021	FT-FY21-042021-012433-A	<1	FT-FY21-042021-012433-B	<1
WS- 012435	4/5/2021	4/5/2022	3	Cooler	In hallway adjacent to B301	WF-04052021-012435	4/13/2021	FT-FY21-042021-012435-A	<1	FT-FY21-042021-012435-B	<1
WS- 012436	4/5/2021	4/5/2022	3	Cooler	In hallway adjacent to room B308	WF-04052021-012436	4/13/2021	FT-FY21-042021-012436-A	<1	FT-FY21-042021-012436-B	<1
WS- 012437	4/5/2021	4/5/2022	4	Cooler	In hallway adjacent to room 421	WF-04052021-012437	4/13/2021	FT-FY21-042021-012437-A	<1	FT-FY21-042021-012437-B	<1
WS- 012438	4/5/2021	4/5/2022	4	Cooler	In hallway adjacent to room 422	WF-04052021-012438	4/13/2021	FT-FY21-042021-012438-A	<1	FT-FY21-042021-012438-B	<1
WS- 012439	4/5/2021	4/5/2022	4	Break Room	In break room 417	WF-04052021-012439	4/13/2021	FT-FY21-042021-012439-A	<1	FT-FY21-042021-012439-B	<1
WS- 012440	4/5/2021	4/5/2022	4	Cooler	In hallway adjacent to room 414	WF-04052021-012440	4/13/2021	FT-FY21-042021-012440-A	<1	FT-FY21-042021-012440-B	<1
WS- 012441	4/5/2021	4/5/2022	4	Cooler	In hallway adjacent to room 412	WF-04052021-012441	4/13/2021	FT-FY21-042021-012441-A	<1	FT-FY21-042021-012441-B	<1
WS- 012442	4/5/2021	4/5/2022	4	Cooler	In hallway adjacent to room 403	WF-04052021-012442	4/13/2021	FT-FY21-042021-012442-A	<1	FT-FY21-042021-012442-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012358	1/26/2021	1/26/2022	1	Food Prep Sink	In kitchen	WF-01262021-012358	4/13/2021	FT-FY21-042021-012358-A	<1	FT-FY21-042021-012358-B	<1