



W. Wilson HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012348	5/13/2019	5/13/2020	Basement	Cooler	In boy's locker room High Left	WF-05132019-012348	1/15/2020	FT-FY20-012020-012348-A	<1	FT-FY20-012020-012348-B	<1
WS- 012349	5/13/2019	5/13/2020	Basement	Cooler	In boy's locker room Low Right	WF-05132019-012349	1/15/2020	FT-FY20-012020-012349-A	<1	FT-FY20-012020-012349-B	<1
WS- 012350	5/13/2019	5/13/2020	Basement	Cooler	In girls' locker room High Left	WF-05132019-012350	1/15/2020	FT-FY20-012020-012350-A	<1	FT-FY20-012020-012350-B	<1
WS- 012351	5/13/2019	5/13/2020	Basement	Cooler	In girls' locker room Low Right	WF-05132019-012351	1/15/2020	FT-FY20-012020-012351-A	<1	FT-FY20-012020-012351-B	<1
WS- 012363	5/13/2019	5/13/2020	1	Cooler	In hallway adjacent to career center 108A	WF-05132019-012363	1/15/2020	FT-FY20-012020-012363-A	<1	FT-FY20-012020-012363-B	<1
WS- 012364	5/13/2019	5/13/2020	1	Break Room	In main office	WF-05132019-012364	1/15/2020	FT-FY20-012020-012364-A	<1	FT-FY20-012020-012364-B	<1
WS- 012365	5/13/2019	5/13/2020	1	Health Suite	In health suite	WF-05132019-012365	1/15/2020	FT-FY20-012020-012365-A	<1	FT-FY20-012020-012365-B	<1
WS- 012381	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room A203b	WF-05132019-012381	1/15/2020	FT-FY20-012020-012381-A	<1	FT-FY20-012020-012381-B	<1
WS- 012384	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 223	WF-05132019-012384	1/15/2020	FT-FY20-012020-012384-A	<1	FT-FY20-012020-012384-B	<1
WS- 012387	5/13/2019	5/13/2020	2	Break Room	In staff lounge 207E	WF-05132019-012387	1/15/2020	FT-FY20-012020-012387-A	<1	FT-FY20-012020-012387-B	<1
WS- 012388	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 213	WF-05132019-012388	1/15/2020	FT-FY20-012020-012388-A	<1	FT-FY20-012020-012388-B	<1
WS- 012390	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 200	WF-05132019-012390	1/15/2020	FT-FY20-012020-012390-A	<1	FT-FY20-012020-012390-B	<1
WS- 012391	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room 232	WF-05132019-012391	1/15/2020	FT-FY20-012020-012391-A	<1	FT-FY20-012020-012391-B	<1
WS- 012410	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room B202	WF-05132019-012410	1/15/2020	FT-FY20-012020-012410-A	<1	FT-FY20-012020-012410-B	<1
WS- 012412	5/13/2019	5/13/2020	2	Cooler	In hallway adjacent to room B204 High Left	WF-05132019-012412	1/15/2020	FT-FY20-012020-012412-A	<1	FT-FY20-012020-012412-B	<1
WS- 012417	5/13/2019	5/13/2020	3	Cooler	In hallway adjacent to room 303	WF-05132019-012417	1/15/2020	FT-FY20-012020-012417-A	<1	FT-FY20-012020-012417-B	<1
WS- 012430	5/13/2019	5/13/2020	3	Cooler	In hallway adjacent to room 321	WF-05132019-012430	1/15/2020	FT-FY20-012020-012430-A	<1	FT-FY20-012020-012430-B	<1
WS- 012433	5/13/2019	5/13/2020	3	Cooler	In hallway adjacent to room 314	WF-05132019-012433	1/15/2020	FT-FY20-012020-012433-A	<1	FT-FY20-012020-012433-B	<1
WS- 012436	5/13/2019	5/13/2020	3	Cooler	In hallway adjacent to room B308	WF-05132019-012436	1/15/2020	FT-FY20-012020-012436-A	<1	FT-FY20-012020-012436-B	<1
WS- 012437	5/13/2019	5/13/2020	4	Cooler	In hallway adjacent to room 421	WF-05132019-012437	1/15/2020	FT-FY20-012020-012437-A	<1	FT-FY20-012020-012437-B	<1
WS- 012438	5/13/2019	5/13/2020	4	Cooler	In hallway adjacent to room 422	WF-05132019-012438	1/15/2020	FT-FY20-012020-012438-A	<1	FT-FY20-012020-012438-B	<1
WS- 012439	5/13/2019	5/13/2020	4	Break Room	In break room 417	WF-05132019-012439	1/15/2020	FT-FY20-012020-012439-A	<1	FT-FY20-012020-012439-B	1.2
WS- 012440	5/13/2019	5/13/2020	4	Cooler	In hallway adjacent to room 414	WF-05132019-012440	1/15/2020	FT-FY20-012020-012440-A	<1	FT-FY20-012020-012440-B	<1
WS- 012441	5/13/2019	5/13/2020	4	Cooler	In hallway adjacent to room 412	WF-05132019-012441	1/15/2020	FT-FY20-012020-012441-A	<1	FT-FY20-012020-012441-B	<1
WS- 012461	5/13/2019	5/13/2020	2	Cooler	In room A205 fitness center High Left	WF-05132019-012461	1/15/2020	FT-FY20-012020-012461-A	<1	FT-FY20-012020-012461-B	<1
WS- 012462	5/13/2019	5/13/2020	2	Cooler	In room A205 fitness center Low Right	WF-05132019-012462	1/15/2020	FT-FY20-012020-012462-A	<1	FT-FY20-012020-012462-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012358	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen	WF-07032019-012358	1/15/2020	FT-FY20-012020-012358-A	<1	FT-FY20-012020-012358-B	<1