



# WILSON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	WILSON HIGH SCHOOL	5/17/2016	WS-012455	Classroom	4	In classroom 423 (3) Left	WT-042916-12472- A	< 1	WT-042916-12472- B	< 1			
2	WILSON HIGH SCHOOL	5/17/2016	WS-012454	Classroom	4	In classroom 423 Mid	WT-042916-12471- A	< 1	WT-042916-12471- B	< 1			
3	WILSON HIGH SCHOOL	5/17/2016	WS-012453	Classroom	4	In classroom 423 Right	WT-042916-12470- A	< 1	WT-042916-12470- B	< 1			
4	WILSON HIGH SCHOOL	5/17/2016	WS-012452	Classroom	4	In classroom 425	WT-042916-12469- A	2	WT-042916-12469- B	< 1			
5	WILSON HIGH SCHOOL	5/17/2016	WS-012451	Classroom	4	In classroom 425 Left	WT-042916-12468- A	2.7	WT-042916-12468- B	< 1			
6	WILSON HIGH SCHOOL	5/17/2016	WS-012450	Classroom	4	In classroom 426 Right	WT-042916-12467- A	< 1	WT-042916-12467- B	< 1			
7	WILSON HIGH SCHOOL	5/17/2016	WS-012449	Classroom	4	In classroom 426 Left	WT-042916-12466- A	1.1	WT-042916-12466- B	< 1			
8	WILSON HIGH SCHOOL	5/17/2016	WS-012448	Classroom	4	In classroom 427 Right	WT-042916-12465- A	< 1	WT-042916-12465- B	< 1			
9	WILSON HIGH SCHOOL	5/17/2016	WS-012447	Classroom	4	In classroom 427 Left	WT-042916-12464- A	2.1	WT-042916-12464- B	< 1			
10	WILSON HIGH SCHOOL	5/17/2016	WS-012446	Classroom	4	In classroom 428 (3)	WT-042916-12463- A	1.1	WT-042916-12463- B	< 1			
11	WILSON HIGH SCHOOL	5/17/2016	WS-012445	Classroom	4	In classroom 428 (2)	WT-042916-12462- A	1	WT-042916-12462- B	< 1			
12	WILSON HIGH SCHOOL	5/17/2016	WS-012444	Classroom	4	In classroom 428 (1)	WT-042916-12461- A	< 1	WT-042916-12461- B	< 1			
13	WILSON HIGH SCHOOL	5/17/2016	WS-012443	Cooler	4	In hallway adjacent to classroom 431	WT-042916-12460- A	< 1	WT-042916-12460- B	< 1			
14	WILSON HIGH SCHOOL	5/17/2016	WS-012442	Cooler	4	In hallway adjacent to 403	WT-042916-12459- A	< 1	WT-042916-12459- B	< 1			
15	WILSON HIGH SCHOOL	5/17/2016	WS-012441	Cooler	4	In hallway adjacent to 412	WT-042916-12458- A	< 1	WT-042916-12458- B	< 1			
16	WILSON HIGH SCHOOL	5/17/2016	WS-012440	Cooler	4	In hallway adjacent to classroom 412	WT-042916-12457- A	< 1	WT-042916-12457- B	< 1			
17	WILSON HIGH SCHOOL	5/17/2016	WS-012439	Classroom	4	In room 417	WT-042916-12456- A	< 1	WT-042916-12456- B	< 1			
18	WILSON HIGH SCHOOL	5/17/2016	WS-012438	Cooler	4	In hallway adjacent to 422	WT-042916-12455- A	< 1	WT-042916-12455- B	< 1			
19	WILSON HIGH SCHOOL	5/17/2016	WS-012437	Cooler	4	In hallway adjacent to room 421	WT-042916-12454- A	< 1	WT-042916-12454- B	< 1			
20	WILSON HIGH SCHOOL	5/17/2016	WS-012436	Cooler	3	In hallway adjacent to room B 308	WT-042916-12453- A	< 1	WT-042916-12453- B	< 1			
21	WILSON HIGH SCHOOL	5/17/2016	WS-012435	Cooler	3	In hallway adjacent to B 301	WT-042916-12452- A	< 1	WT-042916-12452- B	< 1			
22	WILSON HIGH SCHOOL	5/17/2016	WS-012434	Cooler	3	In hallway adjacent to classroom 311	WT-042916-12451- A	< 1	WT-042916-12451- B	< 1			
23	WILSON HIGH SCHOOL	5/17/2016	WS-012433	Cooler	3	In hallway adjacent to 314	WT-042916-12450- A	< 1	WT-042916-12450- B	< 1			
24	WILSON HIGH SCHOOL	5/17/2016	WS-012432	Classroom	3	In room 317	WT-042916-12449- A	3.8	WT-042916-12449- B	1.4			
25	WILSON HIGH SCHOOL	5/17/2016	WS-012431	Cooler	3	In hallway adjacent to classroom 320	WT-042916-12448- A	3.5	WT-042916-12448- B	1.2			
26	WILSON HIGH SCHOOL	5/17/2016	WS-012430	Classroom	3	In hallway adjacent to room 321	WT-042916-12447- A	< 1	WT-042916-12447- B	< 1			
27	WILSON HIGH SCHOOL	5/17/2016	WS-012429	Classroom	3	In classroom 323 (3)	WT-042916-12446- A	2.3	WT-042916-12446- B	< 1			
28	WILSON HIGH SCHOOL	5/17/2016	WS-012428	Classroom	3	In classroom 323 (2)	WT-042916-12445- A	1.4	WT-042916-12445- B	< 1			
29	WILSON HIGH SCHOOL	5/17/2016	WS-012427	Classroom	3	In classroom 323 (1)	WT-042916-12444- A	< 1	WT-042916-12444- B	< 1			
30	WILSON HIGH SCHOOL	5/17/2016	WS-012426	Classroom	3	In classroom 325 (3)	WT-042916-12443- A	6.5	WT-042916-12443- B	< 1			
31	WILSON HIGH SCHOOL	5/17/2016	WS-012425	Classroom	3	In classroom 325 (2)	WT-042916-12442- A	< 1	WT-042916-12442- B	< 1			
32	WILSON HIGH SCHOOL	5/17/2016	WS-012424	Classroom	3	In classroom 325 (1)	WT-042916-12441- A	< 1	WT-042916-12441- B	< 1			
33	WILSON HIGH SCHOOL	5/17/2016	WS-012423	Classroom	3	In room 327 Right	WT-042916-12440- A	< 1	WT-042916-12440- B	< 1			
34	WILSON HIGH SCHOOL	5/17/2016	WS-012422	Classroom	3	In room 327 Left	WT-042916-12439- A	< 1	WT-042916-12439- B	< 1			
35	WILSON HIGH SCHOOL	5/17/2016	WS-012421	Classroom	3	In room 328 (3)	WT-042916-12438- A	1	WT-042916-12438- B	< 1			
36	WILSON HIGH SCHOOL	5/17/2016	WS-012420	Classroom	3	In room 328 (2)	WT-042916-12437- A	1.9	WT-042916-12437- B	< 1			
37	WILSON HIGH SCHOOL	5/17/2016	WS-012419	Classroom	3	In room 328 (1)	WT-042916-12436- A	< 1	WT-042916-12436- B	< 1			
38	WILSON HIGH SCHOOL	5/17/2016	WS-012418	Cooler	3	In hallway adjacent to room 331	WT-042916-12435- A	< 1	WT-042916-12435- B	< 1			
39	WILSON HIGH SCHOOL	5/17/2016	WS-012417	Cooler	3	In hallway adjacent to room 303	WT-042916-12434- A	< 1	WT-042916-12434- B	< 1			
40	WILSON HIGH SCHOOL	5/17/2016	WS-012416	Cooler	2	In hallway adjacent to room C207 Right Low	WT-042916-12433- A	< 1	WT-042916-12433- B	< 1			
41	WILSON HIGH SCHOOL	5/17/2016	WS-012415	Cooler	2	In hallway adjacent toy room C-207 Left	WT-042916-12432- A	< 1	WT-042916-12432- B	< 1			
42	WILSON HIGH SCHOOL	5/17/2016	WS-012414	Cooler	2	In hallway C204 Right Low	WT-042916-12431- A	< 1	WT-042916-12431- B	< 1			
43	WILSON HIGH SCHOOL	5/17/2016	WS-012413	Cooler	2	In hallway adjacent to room C-204 Left High	WT-042916-12430- A	< 1	WT-042916-12430- B	< 1			
44	WILSON HIGH SCHOOL	5/17/2016	WS-012412	Classroom	Basement	In room 14 Left	WT-042916-12429- A	< 1	WT-042916-12429- B	< 1			
45	WILSON HIGH SCHOOL	5/17/2016	WS-012411	Classroom	2	In library	WT-042916-12428- A	3	WT-042916-12428- B	< 1			
46	WILSON HIGH SCHOOL	5/17/2016	WS-012410	Cooler	2	In hallway adjacent to room B-202	WT-042916-12427- A	< 1	WT-042916-12427- B	< 1			
47	WILSON HIGH SCHOOL	5/17/2016	WS-012409	Classroom	2	In room 227 (4)	WT-042916-12426- A	< 1	WT-042916-12426- B	< 1			
48	WILSON HIGH SCHOOL	5/17/2016	WS-012408	Classroom	2	In room 224 (3)	WT-042916-12425- A	< 1	WT-042916-12425- B	< 1			
49	WILSON HIGH SCHOOL	5/17/2016	WS-012407	Classroom	2	In room 224 (2)	WT-042916-12424- A	< 1	WT-042916-12424- B	< 1			
50	WILSON HIGH SCHOOL	5/17/2016	WS-012406	Classroom	2	In room 224 (1)	WT-042916-12423- A	8.8	WT-042916-12423- B	1.4			
51	WILSON HIGH SCHOOL	5/17/2016	WS-012405	Classroom	2	In room 226 (4)	WT-042916-12422- A	< 1	WT-042916-12422- B	< 1			
52	WILSON HIGH SCHOOL	5/17/2016	WS-012404	Classroom	2	In room 226 (3)	WT-042916-12421- A	< 1	WT-042916-12421- B	< 1			
53	WILSON HIGH SCHOOL	5/17/2016	WS-012403	Classroom	2	In room 226 (2)	WT-042916-12419- A	< 1	WT-042916-12419- B	< 1			
54	WILSON HIGH SCHOOL	5/17/2016	WS-012401	Classroom	2	In room 226 (1)	WT-042916-12418- A	< 1	WT-042916-12418- B	< 1			
55	WILSON HIGH SCHOOL	5/17/2016	WS-012400	Classroom	2	In room 227 Right	WT-042916-12417- A	< 1	WT-042916-12417- B	< 1			
56	WILSON HIGH SCHOOL	5/17/2016	WS-012399	Classroom	2	In room 227 Left	WT-042916-12416- A	< 1	WT-042916-12416- B	< 1			
57	WILSON HIGH SCHOOL	5/17/2016	WS-012398	Classroom	2	In room 228 Right	WT-042916-12415- A	< 1	WT-042916-12415- B	< 1			
58	WILSON HIGH SCHOOL	5/17/2016	WS-012397	Classroom	2	In room 228 Mid	WT-042916-12414- A	< 1	WT-042916-12414- B	< 1			
59	WILSON HIGH SCHOOL	5/17/2016	WS-012396	Classroom	2	In room 228 Left	WT-042916-12413- A	< 1	WT-042916-12413- B	< 1			
60	WILSON HIGH SCHOOL	5/17/2016	WS-012395	Classroom	2	In room 229 forth sink clockwise from entry door	WT-042916-12412- A	< 1	WT-042916-12412- B	< 1			



# WILSON LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
61	WILSON HIGH SCHOOL	5/17/2016	WS- 012394	Classroom	2	In room 229 third sink clockwise from entry door	WT-042916-12411- A	< 1	WT-042916-12411- B	< 1				
62	WILSON HIGH SCHOOL	5/17/2016	WS- 012393	Classroom	2	In room 229 second sink clockwise from entry door	WT-042916-12410- A	< 1	WT-042916-12410- B	< 1				
63	WILSON HIGH SCHOOL	5/17/2016	WS- 012392	Classroom	2	In room 229 first sink clockwise from entry door	WT-042916-12409- A	< 1	WT-042916-12409- B	< 1				
64	WILSON HIGH SCHOOL	5/17/2016	WS- 012391	Cooler	2	In hallway adjacent to room 232	WT-042916-12408- A	< 1	WT-042916-12408- B	< 1				
65	WILSON HIGH SCHOOL	5/17/2016	WS- 012390	Cooler	2	In hallway adjacent to room 200	WT-042916-12407- A	< 1	WT-042916-12407- B	< 1				
66	WILSON HIGH SCHOOL	5/17/2016	WS- 012389	Cooler	2	In hallway adjacent to room 211	WT-042916-12406- A	< 1	WT-042916-12406- B	< 1				
67	WILSON HIGH SCHOOL	5/17/2016	WS- 012388	Cooler	2	In hallway adjacent to room 213	WT-042916-12405- A	< 1	WT-042916-12405- B	< 1				
68	WILSON HIGH SCHOOL	5/17/2016	WS- 012387	Break Room	2	In staff lounge (207e)	WT-042916-12404- A	< 1	WT-042916-12404- B	< 1				
69	WILSON HIGH SCHOOL	5/17/2016	WS- 012386	Classroom	2	In room 216	WT-042916-12403- A	< 1	WT-042916-12403- B	< 1				
70	WILSON HIGH SCHOOL	5/17/2016	WS- 012385	Cooler	2	In hallway adjacent to room 222	WT-042916-12402- A	< 1	WT-042916-12402- B	< 1				
71	WILSON HIGH SCHOOL	5/17/2016	WS- 012384	Cooler	2	In hallway adjacent to room 223	WT-042916-12401- A	< 1	WT-042916-12401- B	< 1				
72	WILSON HIGH SCHOOL	5/17/2016	WS- 012383	Cooler	1	In recreation area	WT-042916-12400- A	< 1	WT-042916-12400- B	< 1				
73	WILSON HIGH SCHOOL	5/17/2016	WS- 012382	Cooler	2	In recreation area	WT-042916-12399- A	< 1	WT-042916-12399- B	< 1				
74	WILSON HIGH SCHOOL	5/17/2016	WS- 012381	Cooler	2	In hallway adjacent to room A203b	WT-042916-12398- A	< 1	WT-042916-12398- B	< 1				
75	WILSON HIGH SCHOOL	5/17/2016	WS- 012380	Classroom	1	In room C114	WT-042916-12397- A	< 1	WT-042916-12397- B	< 1				
76	WILSON HIGH SCHOOL	5/17/2016	WS- 012379	Classroom	1	In room C114	WT-042916-12396- A	< 1	WT-042916-12396- B	< 1				
77	WILSON HIGH SCHOOL	5/17/2016	WS- 012378	Classroom	1	In room C110	WT-042916-12395- A	< 1	WT-042916-12395- B	< 1				
78	WILSON HIGH SCHOOL	5/17/2016	WS- 012377	Classroom	1	In room C110	WT-042916-12394- A	< 1	WT-042916-12394- B	< 1				
79	WILSON HIGH SCHOOL	5/17/2016	WS- 012376	Classroom	1	In room C108	WT-042916-12393- A	< 1	WT-042916-12393- B	< 1				
80	WILSON HIGH SCHOOL	5/17/2016	WS- 012375	Classroom	1	In room C108	WT-042916-12392- A	< 1	WT-042916-12392- B	< 1				
81	WILSON HIGH SCHOOL	5/17/2016	WS- 012374	Classroom	1	In room C104	WT-042916-12391- A	< 1	WT-042916-12391- B	< 1				
82	WILSON HIGH SCHOOL	5/17/2016	WS- 012373	Classroom	1	In room C104	WT-042916-12390- A	< 1	WT-042916-12390- B	< 1				
83	WILSON HIGH SCHOOL	5/17/2016	WS- 012370	Classroom	1	In room B106	WT-042916-12387- A	< 1	WT-042916-12387- B	< 1				
84	WILSON HIGH SCHOOL	5/17/2016	WS- 012369	Cooler	1	In hallway across room B101	WT-042916-12386- A	< 1	WT-042916-12386- B	< 1				
85	WILSON HIGH SCHOOL	5/17/2016	WS- 012368	Classroom	1	In room B101	WT-042916-12385- A	< 1	WT-042916-12385- B	< 1				
86	WILSON HIGH SCHOOL	5/17/2016	WS- 012367	Classroom	1	In room B101	WT-042916-12384- A	< 1	WT-042916-12384- B	< 1				
87	WILSON HIGH SCHOOL	5/17/2016	WS- 012366	Other	1	In health suite (ice maker)	WT-042916-12383- A	< 1	WT-042916-12383- B	< 1				
88	WILSON HIGH SCHOOL	5/17/2016	WS- 012365	Health Suite	1	In health room	WT-042916-12382- A	< 1	WT-042916-12382- B	< 1				
89	WILSON HIGH SCHOOL	5/17/2016	WS- 012364	Break Room	1	In main office	WT-042916-12381- A	< 1	WT-042916-12381- B	< 1				
90	WILSON HIGH SCHOOL	5/17/2016	WS- 012363	Cooler	1	In hallway adjacent to career center (108a)	WT-042916-12380- A	< 1	WT-042916-12380- B	< 1				
91	WILSON HIGH SCHOOL	5/17/2016	WS- 012362	Break Room	1	In staff lounge	WT-042916-12379- A	< 1	WT-042916-12379- B	< 1				
92	WILSON HIGH SCHOOL	5/17/2016	WS- 012361	Break Room	1	In staff lounge	WT-042916-12378- A	< 1	WT-042916-12378- B	< 1				
93	WILSON HIGH SCHOOL	5/17/2016	WS- 012360	Cooler	1	In hallway adjacent to staff lounge	WT-042916-12377- A	< 1	WT-042916-12377- B	< 1				
94	WILSON HIGH SCHOOL	5/17/2016	WS- 012359	Other	1	In kitchen (steam kettles)	WT-042916-12376- A	< 1	WT-042916-12376- B	< 1				
95	WILSON HIGH SCHOOL	5/17/2016	WS- 012358	Kitchen	1	In kitchen prep sink	WT-042916-12375- A	< 1	WT-042916-12375- B	< 1				
96	WILSON HIGH SCHOOL	5/17/2016	WS- 012357	Kitchen	1	In kitchen sanitizing area	WT-042916-12374- A	< 1	WT-042916-12374- B	< 1				
97	WILSON HIGH SCHOOL	5/17/2016	WS- 012356	Kitchen	1	In kitchen sanitizing area	WT-042916-12373- A	< 1	WT-042916-12373- B	< 1				
98	WILSON HIGH SCHOOL	5/17/2016	WS- 012355	Other	1	In kitchen (sanitizing area/spray nozzle)	WT-042916-12372- A	< 1	WT-042916-12372- B	< 1				
99	WILSON HIGH SCHOOL	5/17/2016	WS- 012354	Other	1	In kitchen (ice maker)	WT-042916-12371- A	2.7	WT-042916-12371- B	1				
100	WILSON HIGH SCHOOL	5/17/2016	WS- 012353	Cooler	1	In hallway adjacent to room A-201a	WT-042916-12370- A	1.7	WT-042916-12370- B	< 1				
101	WILSON HIGH SCHOOL	5/17/2016	WS- 012352	Cooler	1	In hallway adjacent to room A201a	WT-042916-12369- A	< 1	WT-042916-12369- B	< 1				
102	WILSON HIGH SCHOOL	5/17/2016	WS- 012351	Cooler	Basement	In women's locker room	WT-042916-12368- A	< 1	WT-042916-12368- B	< 1				
103	WILSON HIGH SCHOOL	5/17/2016	WS- 012350	Cooler	Basement	In women's locker room	WT-042916-12367- A	< 1	WT-042916-12367- B	< 1				
104	WILSON HIGH SCHOOL	5/17/2016	WS- 012349	Cooler	Basement	In men's locker room	WT-042916-12366- A	< 1	WT-042916-12366- B	< 1				
105	WILSON HIGH SCHOOL	5/17/2016	WS- 012348	Cooler	Basement	In men's locker room	WT-042916-12365- A	< 1	WT-042916-12365- B	< 1				
106	WILSON HIGH SCHOOL	5/17/2016	WS- 012347	Utility	Basement	In room A121 (Main water source)	WT-042916-12364- A	< 1	WT-042916-12364- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.