



# Woodrow Wilson Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012348	6/14/17	6/14/18	Basement	Cooler	In boy's locker room	Left	High	WF-62017-012348	12/19/17	FT-FY18--62017-012348-A	<1	FT-FY18--62017-012348-B	<1
WS- 012353	6/14/17	6/14/18	2	Cooler	In hallway adjacent to room A201A	Right	Low	WF-62017-012353	12/19/17	FT-FY18--62017-012353-A	<1	FT-FY18--62017-012353-B	<1
WS- 012360	6/14/17	6/14/18	1	Cooler	In hallway adjacent to room 119			WF-62017-012360	12/19/17	FT-FY18--62017-012360-A	<1	FT-FY18--62017-012360-B	<1
WS- 012363	6/14/17	6/14/18	1	Cooler	In hallway adjacent to career center 108A			WF-62017-012363	12/19/17	FT-FY18--62017-012363-A	<1	FT-FY18--62017-012363-B	<1
WS- 012369	6/14/17	6/14/18	1	Cooler	In hallway across from room B101			WF-62017-012369	12/19/17	FT-FY18--62017-012369-A	<1	FT-FY18--62017-012369-B	<1
WS- 012382	9/11/17	9/11/18	2	Cooler	In recreation area	Left	High	WF-92017-012382	12/19/17	FT-FY18--92017-012382-A	<1	FT-FY18--92017-012382-B	<1
WS- 012384	6/14/17	6/14/18	2	Cooler	In hallway adjacent to room 223			WF-62017-012384	12/19/17	FT-FY18--62017-012384-A	<1	FT-FY18--62017-012384-B	<1
WS- 012389	6/14/17	6/14/18	2	Cooler	In hallway adjacent to room 211			WF-62017-012389	12/19/17	FT-FY18--62017-012389-A	<1	FT-FY18--62017-012389-B	<1
WS- 012391	6/14/17	6/14/18	2	Cooler	In hallway adjacent to room 232			WF-62017-012391	12/19/17	FT-FY18--62017-012391-A	<1	FT-FY18--62017-012391-B	<1
WS- 012413	6/14/17	6/14/18	2	Cooler	In hallway adjacent to room C204	Left	High	WF-62017-012413	12/19/17	FT-FY18--62017-012413-A	<1	FT-FY18--62017-012413-B	<1
WS- 012417	6/14/17	6/14/18	3	Cooler	In hallway adjacent to room 303			WF-62017-012417	12/19/17	FT-FY18--62017-012417-A	<1	FT-FY18--62017-012417-B	<1
WS- 012418	6/14/17	6/14/18	3	Cooler	In hallway adjacent to room 331			WF-62017-012418	12/19/17	FT-FY18--62017-012418-A	<1	FT-FY18--62017-012418-B	<1
WS- 012438	6/14/17	6/14/18	4	Cooler	In hallway adjacent to room 422			WF-62017-012438	12/19/17	FT-FY18--62017-012438-A	<1	FT-FY18--62017-012438-B	<1
WS- 012439	6/14/17	6/14/18	4	Break Room	In break room 417			WF-62017-012439	12/19/17	FT-FY18--62017-012439-A	<1	FT-FY18--62017-012439-B	<1
WS- 012442	7/20/17	7/20/18	4	Cooler	In hallway adjacent to room 403			WF-72017-012442	12/19/17	FT-FY18--72017-012442-A	<1	FT-FY18--72017-012442-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012358	1	Food Prep Sink	In kitchen			12/19/17	FT-FY18-102017-012358-A	<1	FT-FY18-102017-012358-B	<1