



WOODSON HS LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	WOODSON HIGH SCHOOL	WS- 002538	12/14/2016	1	Classroom Faucet	In day care room 174	FT-112016-002538-A	< 1	FT-112016-002538-B	< 1
2	WOODSON HIGH SCHOOL	WS- 002540	12/14/2016	1	Classroom Faucet	In day care room 175 adjacent to bathroom	FT-112016-002540-A	< 1	FT-112016-002540-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	WOODSON HIGH SCHOOL	WS- 002539	12/14/2016	1	Classroom Faucet	In day care room 175	FT-112016-002539-A	1.6	FT-112016-002539-B	< 1
2	WOODSON HIGH SCHOOL	WS- 004988	1/11/2017	1	Breakroom	In work room 104	FT-112016-004988-A	< 1	FT-112016-004988-B	1.2

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WOODSON HIGH SCHOOL	WS- 002539	1/25/2017	1	Classroom Faucet	In day care room 175	FT-112016-002539-A	3.2	FT-112016-002539-B	< 1
2	WOODSON HIGH SCHOOL	WS- 004988	2/8/2017	1	Breakroom	In work room 104	FT-112016-004988-A	2	FT-112016-004988-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WOODSON HIGH SCHOOL	WS- 002539	3/10/2017	1	Classroom Faucet	In day care room 175	FT-112016-002539-A	3.5	FT-112016-002539-B	< 1
2	WOODSON HIGH SCHOOL	WS- 004988	3/10/2017	1	Breakroom	In work room 104	FT-112016-004988-A	1.4	FT-112016-004988-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Devices Returned to Service										
1	WOODSON HIGH SCHOOL	WS- 002539	8/11/2017	1	Classroom Faucet	In day care room 175	FT-112016-002539-A	< 1	FT-112016-002539-B	< 1
2	WOODSON HIGH SCHOOL	WS- 004988	8/11/2017	1	Breakroom	In work room 104	FT-112016-004988-A	< 1	FT-112016-004988-B	< 1