



Woodson High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002538	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 174	WF-10062020-002538	3/26/2021	FT-FY21-032021-002538-A	<1	FT-FY21-032021-002538-B	<1	
WS- 002539	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 175	WF-10062020-002539	3/26/2021	FT-FY21-032021-002539-A	1.0	FT-FY21-032021-002539-B	<1	
WS- 002540	10/6/2020	10/6/2021	1	Classroom Faucet	In day care room 175 adjacent to bathroom	WF-10062020-002540	3/26/2021	FT-FY21-032021-002540-A	<1	FT-FY21-032021-002540-B	<1	
WS- 004892	3/31/2020	3/31/2021	Basement	Cooler	In hallway adjacent to room 002	High Left	WF-03312020-004892	3/26/2021	FT-FY21-032021-004892-A	<1	FT-FY21-032021-004892-B	<1
WS- 004893	3/31/2020	3/31/2021	Basement	Cooler	In hallway adjacent to room 002	Low Right	WF-03312020-004893	3/26/2021	FT-FY21-032021-004893-A	<1	FT-FY21-032021-004893-B	<1
WS- 004896	7/13/2020	7/13/2021	Basement	Cooler	In hallway adjacent to girls' restroom	High Left	WF-07132020-004896	3/26/2021	FT-FY21-032021-004896-A	<1	FT-FY21-032021-004896-B	<1
WS- 004897	7/13/2020	7/13/2021	Basement	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-07132020-004897	3/26/2021	FT-FY21-032021-004897-A	<1	FT-FY21-032021-004897-B	<1
WS- 004900	3/31/2020	3/31/2021	Basement	Bottle Filler	In classroom 015 (bottle filler)		WF-03312020-004900	3/26/2021	FT-FY21-032021-004900-A	<1	FT-FY21-032021-004900-B	<1
WS- 004901	3/31/2020	3/31/2021	Basement	Cooler	In classroom 015	High Left	WF-03312020-004901	3/26/2021	FT-FY21-032021-004901-A	<1	FT-FY21-032021-004901-B	<1
WS- 004902	3/31/2020	3/31/2021	Basement	Cooler	In classroom 015	Low Right	WF-03312020-004902	3/26/2021	FT-FY21-032021-004902-A	<1	FT-FY21-032021-004902-B	<1
WS- 004903	3/31/2020	3/31/2021	Basement	Bottle Filler	In classroom 016 (bottle filler)		WF-03312020-004903	3/26/2021	FT-FY21-032021-004903-A	<1	FT-FY21-032021-004903-B	<1
WS- 004904	3/31/2020	3/31/2021	Basement	Cooler	In classroom 016	High Left	WF-03312020-004904	3/26/2021	FT-FY21-032021-004904-A	<1	FT-FY21-032021-004904-B	<1
WS- 004905	3/31/2020	3/31/2021	Basement	Cooler	In classroom 016	Low Right	WF-03312020-004905	3/26/2021	FT-FY21-032021-004905-A	<1	FT-FY21-032021-004905-B	<1
WS- 004906	3/31/2020	3/31/2021	Basement	Bottle Filler	In the gym 012 (bottle filler)		WF-03312020-004906	3/26/2021	FT-FY21-032021-004906-A	<1	FT-FY21-032021-004906-B	<1
WS- 004907	3/31/2020	3/31/2021	Basement	Cooler	In the gym 012	High Left	WF-03312020-004907	3/26/2021	FT-FY21-032021-004907-A	<1	FT-FY21-032021-004907-B	<1
WS- 004908	3/31/2020	3/31/2021	Basement	Cooler	In the gym 012	Low Right	WF-03312020-004908	3/26/2021	FT-FY21-032021-004908-A	<1	FT-FY21-032021-004908-B	<1
WS- 004909	3/31/2020	3/31/2021	Basement	Cooler	In basketball court	High Left	WF-03312020-004909	3/26/2021	FT-FY21-032021-004909-A	<1	FT-FY21-032021-004909-B	<1
WS- 004910	3/31/2020	3/31/2021	Basement	Cooler	In basketball court	Low Right	WF-03312020-004910	3/26/2021	FT-FY21-032021-004910-A	<1	FT-FY21-032021-004910-B	<1
WS- 004911	3/31/2020	3/31/2021	Basement	Bottle Filler	In pool area (bottle filler)		WF-03312020-004911	3/26/2021	FT-FY21-032021-004911-A	<1	FT-FY21-032021-004911-B	<1
WS- 004912	3/31/2020	3/31/2021	Basement	Cooler	In pool area	High Left	WF-03312020-004912	3/26/2021	FT-FY21-032021-004912-A	<1	FT-FY21-032021-004912-B	<1
WS- 004913	3/31/2020	3/31/2021	Basement	Cooler	In pool area	Low Right	WF-03312020-004913	3/26/2021	FT-FY21-032021-004913-A	<1	FT-FY21-032021-004913-B	<1
WS- 004915	3/31/2020	3/31/2021	3	Cooler	In lobby adjacent to room 342		WF-03312020-004915	3/26/2021	FT-FY21-032021-004915-A	<1	FT-FY21-032021-004915-B	<1
WS- 004931	3/31/2020	3/31/2021	3	Cooler	In hallway adjacent to room 307	High Left	WF-03312020-004931	3/26/2021	FT-FY21-032021-004931-A	<1	FT-FY21-032021-004931-B	<1
WS- 004932	3/31/2020	3/31/2021	3	Cooler	In hallway adjacent to room 307	Low Right	WF-03312020-004932	3/26/2021	FT-FY21-032021-004932-A	<1	FT-FY21-032021-004932-B	<1
WS- 004950	3/31/2020	3/31/2021	2	Cooler	In hallway adjacent to room 209A (bottle filler)	High Left	WF-03312020-004950	3/26/2021	FT-FY21-032021-004950-A	<1	FT-FY21-032021-004950-B	<1
WS- 004952	3/31/2020	3/31/2021	2	Cooler	In hallway adjacent to room 209A	Low Right	WF-03312020-004952	3/26/2021	FT-FY21-032021-004952-A	<1	FT-FY21-032021-004952-B	<1
WS- 004954	3/31/2020	3/31/2021	2	Cooler	In lobby across from room 242	High Left	WF-03312020-004954	3/26/2021	FT-FY21-032021-004954-A	<1	FT-FY21-032021-004954-B	<1
WS- 004955	3/31/2020	3/31/2021	2	Cooler	In lobby across from room 242	Low Right	WF-03312020-004955	3/26/2021	FT-FY21-032021-004955-A	<1	FT-FY21-032021-004955-B	<1
WS- 004981	3/31/2020	3/31/2021	2	Cooler	In hallway across from room 230	High Left	WF-03312020-004981	3/26/2021	FT-FY21-032021-004981-A	<1	FT-FY21-032021-004981-B	<1
WS- 004982	3/31/2020	3/31/2021	2	Cooler	In hallway across from room 230	Low Right	WF-03312020-004982	3/26/2021	FT-FY21-032021-004982-A	<1	FT-FY21-032021-004982-B	<1
WS- 004985	3/31/2020	3/31/2021	2	Bottle Filler	In hallway adjacent to room 222 (bottle filler)		WF-03312020-004985	3/26/2021	FT-FY21-032021-004985-A	<1	FT-FY21-032021-004985-B	<1
WS- 004987	3/31/2020	3/31/2021	2	Cooler	In hallway adjacent to room 222	Low Right	WF-03312020-004987	3/26/2021	FT-FY21-032021-004987-A	<1	FT-FY21-032021-004987-B	<1
WS- 004988	3/31/2020	3/31/2021	1	Break Room	In work room 104		WF-03312020-004988	3/26/2021	FT-FY21-032021-004988-A	<1	FT-FY21-032021-004988-B	<1
WS- 004989	3/31/2020	3/31/2021	1	Break Room	In work room 105		WF-03312020-004989	3/26/2021	FT-FY21-032021-004989-A	<1	FT-FY21-032021-004989-B	<1

WS- 004990	3/31/2020	3/31/2021	1	Health Suite	In health suite in exam room W106		WF-03312020-004990	3/26/2021	FT-FY21-032021-004990-A	<1	FT-FY21-032021-004990-B	<1
WS- 004991	3/31/2020	3/31/2021	1	Health Suite	In health suite in exam room W104		WF-03312020-004991	3/26/2021	FT-FY21-032021-004991-A	<1	FT-FY21-032021-004991-B	<1
WS- 004992	3/31/2020	3/31/2021	1	Health Suite	In health suite in dental exam room W111		WF-03312020-004992	3/26/2021	FT-FY21-032021-004992-A	<1	FT-FY21-032021-004992-B	<1
WS- 004993	3/31/2020	3/31/2021	1	Health Suite	In health suite in exam room W112		WF-03312020-004993	3/26/2021	FT-FY21-032021-004993-A	<1	FT-FY21-032021-004993-B	<1
WS- 004994	3/31/2020	3/31/2021	1	Health Suite	In health suite in exam room W113		WF-03312020-004994	3/26/2021	FT-FY21-032021-004994-A	<1	FT-FY21-032021-004994-B	<1
WS- 004996	3/31/2020	3/31/2021	1	Cooler	In hallway adjacent to room 101	High Left	WF-03312020-004996	3/26/2021	FT-FY21-032021-004996-A	<1	FT-FY21-032021-004996-B	<1
WS- 004997	3/31/2020	3/31/2021	1	Cooler	In hallway adjacent to room 101	Low Right	WF-03312020-004997	3/26/2021	FT-FY21-032021-004997-A	<1	FT-FY21-032021-004997-B	<1
WS- 004998	3/31/2020	3/31/2021	1	Bottle Filler	In cafeteria (bottle filler)		WF-03312020-004998	3/26/2021	FT-FY21-032021-004998-A	<1	FT-FY21-032021-004998-B	<1
WS- 005000	3/31/2020	3/31/2021	1	Cooler	In cafeteria	High Left	WF-03312020-005000	3/26/2021	FT-FY21-032021-005000-A	<1	FT-FY21-032021-005000-B	<1
WS- 005001	3/31/2020	3/31/2021	1	Cooler	In cafeteria	Low Right	WF-03312020-005001	3/26/2021	FT-FY21-032021-005001-A	<1	FT-FY21-032021-005001-B	<1
WS- 005003	3/31/2020	3/31/2021	1	Cooler	In hallway adjacent to room 153	High Left	WF-03312020-005003	3/26/2021	FT-FY21-032021-005003-A	<1	FT-FY21-032021-005003-B	<1
WS- 005004	3/31/2020	3/31/2021	1	Cooler	In hallway adjacent to room 153	Low Right	WF-03312020-005004	3/26/2021	FT-FY21-032021-005004-A	<1	FT-FY21-032021-005004-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005006	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen west wall	WF-02172021-005006	3/26/2021	FT-FY21-032021-005006-A	<1	FT-FY21-032021-005006-B	<1