



# Woodson High School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002538	9/12/2023	9/12/2024	1	Classroom Faucet	In day care room 174	WF-09122023-002538	10/23/2023	FT-FY24-09282023-002538-A	<1	FT-FY24-09282023-002538-B	<1	
WS-002539	9/12/2023	9/12/2024	1	Classroom Faucet	In day care room 175	WF-09122023-002539	10/23/2023	FT-FY24-09282023-002539-A	<1	FT-FY24-09282023-002539-B	<1	
WS-002540	9/12/2023	9/12/2024	1	Classroom Faucet	In day care room 175 adjacent to bathroom	WF-09122023-002540	10/23/2023	FT-FY24-09282023-002540-A	<1	FT-FY24-09282023-002540-B	<1	
WS-004896	3/6/2023	3/6/2024	Basement	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03062023-004896	10/23/2023	FT-FY24-09282023-004896-A	<1	FT-FY24-09282023-004896-B	<1
WS-004897	3/6/2023	3/6/2024	Basement	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03062023-004897	10/23/2023	FT-FY24-09282023-004897-A	<1	FT-FY24-09282023-004897-B	<1
WS-004900	3/6/2023	3/6/2024	Basement	Bottle Filler	In classroom 015 (bottle filler)		WF-03062023-004900	10/23/2023	FT-FY24-09282023-004900-A	1.0	FT-FY24-09282023-004900-B	<1
WS-004901	3/6/2023	3/6/2024	Basement	Cooler	In classroom 015	High Left	WF-03062023-004901	10/23/2023	FT-FY24-09282023-004901-A	<1	FT-FY24-09282023-004901-B	<1
WS-004902	3/6/2023	3/6/2024	Basement	Cooler	In classroom 015	Low Right	WF-03062023-004902	10/23/2023	FT-FY24-09282023-004902-A	<1	FT-FY24-09282023-004902-B	<1
WS-004903	3/6/2023	3/6/2024	Basement	Bottle Filler	In classroom 016 (bottle filler)		WF-03062023-004903	10/23/2023	FT-FY24-09282023-004903-A	<1	FT-FY24-09282023-004903-B	<1
WS-004904	3/6/2023	3/6/2024	Basement	Cooler	In classroom 016	High Left	WF-03062023-004904	10/23/2023	FT-FY24-09282023-004904-A	<1	FT-FY24-09282023-004904-B	<1
WS-004905	3/6/2023	3/6/2024	Basement	Cooler	In classroom 016	Low Right	WF-03062023-004905	10/23/2023	FT-FY24-09282023-004905-A	<1	FT-FY24-09282023-004905-B	<1
WS-004906	3/6/2023	3/6/2024	Basement	Bottle Filler	In the gym 012 (bottle filler)		WF-03062023-004906	10/23/2023	FT-FY24-09282023-004906-A	<1	FT-FY24-09282023-004906-B	<1
WS-004907	3/6/2023	3/6/2024	Basement	Cooler	In the gym 012	High Left	WF-03062023-004907	10/23/2023	FT-FY24-09282023-004907-A	<1	FT-FY24-09282023-004907-B	<1
WS-004908	3/6/2023	3/6/2024	Basement	Cooler	In the gym 012	Low Right	WF-03062023-004908	10/23/2023	FT-FY24-09282023-004908-A	<1	FT-FY24-09282023-004908-B	<1
WS-004911	3/6/2023	3/6/2024	Basement	Bottle Filler	In pool area (bottle filler)		WF-03062023-004911	10/23/2023	FT-FY24-09282023-004911-A	<1	FT-FY24-09282023-004911-B	<1
WS-004912	3/6/2023	3/6/2024	Basement	Cooler	In pool area	High Left	WF-03062023-004912	10/23/2023	FT-FY24-09282023-004912-A	<1	FT-FY24-09282023-004912-B	<1
WS-004913	3/6/2023	3/6/2024	Basement	Cooler	In pool area	Low Right	WF-03062023-004913	10/23/2023	FT-FY24-09282023-004913-A	<1	FT-FY24-09282023-004913-B	<1
WS-004915	3/6/2023	3/6/2024	3	Cooler	In lobby adjacent to room 342		WF-03062023-004915	10/23/2023	FT-FY24-09282023-004915-A	<1	FT-FY24-09282023-004915-B	<1
WS-004929	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room 315	High Left	WF-03062023-004929	10/23/2023	FT-FY24-09282023-004929-A	<1	FT-FY24-09282023-004929-B	<1
WS-004930	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room 315	Low Right	WF-03062023-004930	10/23/2023	FT-FY24-09282023-004930-A	<1	FT-FY24-09282023-004930-B	<1
WS-004931	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room 307	High Left	WF-03062023-004931	10/23/2023	FT-FY24-09282023-004931-A	1.4	FT-FY24-09282023-004931-B	3.2
WS-004932	3/6/2023	3/6/2024	3	Cooler	In hallway adjacent to room 307	Low Right	WF-03062023-004932	10/23/2023	FT-FY24-09282023-004932-A	<1	FT-FY24-09282023-004932-B	<1
WS-004950	3/6/2023	3/6/2024	2	Cooler	In hallway adjacent to room 209A (bottle filler)	High Left	WF-03062023-004950	10/23/2023	FT-FY24-09282023-004950-A	<1	FT-FY24-09282023-004950-B	<1
WS-004952	3/6/2023	3/6/2024	2	Cooler	In hallway adjacent to room 209A	Low Right	WF-03062023-004952	10/23/2023	FT-FY24-09282023-004952-A	<1	FT-FY24-09282023-004952-B	<1
WS-004954	3/6/2023	3/6/2024	2	Cooler	In lobby across from room 242	High Left	WF-03062023-004954	10/23/2023	FT-FY24-09282023-004954-A	<1	FT-FY24-09282023-004954-B	<1
WS-004955	3/6/2023	3/6/2024	2	Cooler	In lobby across from room 242	Low Right	WF-03062023-004955	10/23/2023	FT-FY24-09282023-004955-A	<1	FT-FY24-09282023-004955-B	<1
WS-004988	3/6/2023	3/6/2024	1	Break Room	In work room 104		WF-03062023-004988	10/23/2023	FT-FY24-09282023-004988-A	<1	FT-FY24-09282023-004988-B	<1
WS-004989	3/6/2023	3/6/2024	1	Break Room	In work room 105		WF-03062023-004989	10/23/2023	FT-FY24-09282023-004989-A	<1	FT-FY24-09282023-004989-B	<1
WS-004990	3/6/2023	3/6/2024	1	Health Suite	In health suite in exam room W106		WF-03062023-004990	10/23/2023	FT-FY24-09282023-004990-A	1.2	FT-FY24-09282023-004990-B	<1
WS-004991	3/6/2023	3/6/2024	1	Health Suite	In health suite in exam room W104		WF-03062023-004991	10/23/2023	FT-FY24-09282023-004991-A	<1	FT-FY24-09282023-004991-B	<1
WS-004992	3/6/2023	3/6/2024	1	Health Suite	In health suite in dental exam room W111		WF-03062023-004992	10/23/2023	FT-FY24-09282023-004992-A	<1	FT-FY24-09282023-004992-B	<1
WS-004993	3/6/2023	3/6/2024	1	Health Suite	In health suite in exam room W112		WF-03062023-004993	10/23/2023	FT-FY24-09282023-004993-A	<1	FT-FY24-09282023-004993-B	<1
WS-004994	3/6/2023	3/6/2024	1	Health Suite	In health suite in exam room W113		WF-03062023-004994	10/23/2023	FT-FY24-09282023-004994-A	1.2	FT-FY24-09282023-004994-B	1.1
WS-004996	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to room 101	High Left	WF-03062023-004996	10/23/2023	FT-FY24-09282023-004996-A	<1	FT-FY24-09282023-004996-B	<1
WS-004997	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to room 101	Low Right	WF-03062023-004997	10/23/2023	FT-FY24-09282023-004997-A	1.2	FT-FY24-09282023-004997-B	<1

WS-005003	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to room 153	High Left	WF-03062023-005003	10/23/2023	FT-FY24-09282023-005003-A	<1	FT-FY24-09282023-005003-B	<1
WS-005004	3/6/2023	3/6/2024	1	Cooler	In hallway adjacent to room 153	Low Right	WF-03062023-005004	10/23/2023	FT-FY24-09282023-005004-A	<1	FT-FY24-09282023-005004-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005006	1/18/2023	1/18/2024	1	Food Prep Sink	In kitchen west wall	WF-01182023-005006	10/23/2023	FT-FY24-09282023-005006-A	<1	FT-FY24-09282023-005006-B	<1