



# Woodson High School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002538	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 174	WF-09272021-002538	3/24/2022	FT-FY22-02212022-002538-A	<1	FT-FY22-02212022-002538-B	<1	
WS- 002540	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 175 adjacent to bathroom	WF-09272021-002540	3/24/2022	FT-FY22-02212022-002540-A	<1	FT-FY22-02212022-002540-B	<1	
WS- 004892	3/22/2021	3/22/2022	Basement	Cooler	In hallway adjacent to room 002	High Left	WF-03222021-004892	3/24/2022	FT-FY22-02212022-004892-A	<1	FT-FY22-02212022-004892-B	<1
WS- 004893	3/22/2021	3/22/2022	Basement	Cooler	In hallway adjacent to room 002	Low Right	WF-03222021-004893	3/24/2022	FT-FY22-02212022-004893-A	<1	FT-FY22-02212022-004893-B	<1
WS- 004896	3/22/2021	3/22/2022	Basement	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03222021-004896	3/24/2022	FT-FY22-02212022-004896-A	<1	FT-FY22-02212022-004896-B	<1
WS- 004897	3/22/2021	3/22/2022	Basement	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03222021-004897	3/24/2022	FT-FY22-02212022-004897-A	<1	FT-FY22-02212022-004897-B	<1
WS- 004903	3/22/2021	3/22/2022	Basement	Bottle Filler	In classroom 016 (bottle filler)		WF-03222021-004903	3/24/2022	FT-FY22-02212022-004903-A	<1	FT-FY22-02212022-004903-B	<1
WS- 004904	3/22/2021	3/22/2022	Basement	Cooler	In classroom 016	High Left	WF-03222021-004904	3/24/2022	FT-FY22-02212022-004904-A	<1	FT-FY22-02212022-004904-B	<1
WS- 004905	3/22/2021	3/22/2022	Basement	Cooler	In classroom 016	Low Right	WF-03222021-004905	3/24/2022	FT-FY22-02212022-004905-A	<1	FT-FY22-02212022-004905-B	<1
WS- 004911	3/22/2021	3/22/2022	Basement	Bottle Filler	In pool area (bottle filler)		WF-03222021-004911	3/24/2022	FT-FY22-02212022-004911-A	<1	FT-FY22-02212022-004911-B	<1
WS- 004912	3/22/2021	3/22/2022	Basement	Cooler	In pool area	High Left	WF-03222021-004912	3/24/2022	FT-FY22-02212022-004912-A	<1	FT-FY22-02212022-004912-B	<1
WS- 004913	3/22/2021	3/22/2022	Basement	Cooler	In pool area	Low Right	WF-03222021-004913	3/24/2022	FT-FY22-02212022-004913-A	<1	FT-FY22-02212022-004913-B	<1
WS- 004915	3/22/2021	3/22/2022	3	Cooler	In lobby adjacent to room 342		WF-03222021-004915	3/24/2022	FT-FY22-02212022-004915-A	<1	FT-FY22-02212022-004915-B	<1
WS- 004929	3/22/2021	3/22/2022	3	Cooler	In hallway adjacent to room 315	High Left	WF-03222021-004929	3/24/2022	FT-FY22-02212022-004929-A	<1	FT-FY22-02212022-004929-B	<1
WS- 004930	3/22/2021	3/22/2022	3	Cooler	In hallway adjacent to room 315	Low Right	WF-03222021-004930	3/24/2022	FT-FY22-02212022-004930-A	<1	FT-FY22-02212022-004930-B	<1
WS- 004931	3/22/2021	3/22/2022	3	Cooler	In hallway adjacent to room 307	High Left	WF-03222021-004931	3/24/2022	FT-FY22-02212022-004931-A	<1	FT-FY22-02212022-004931-B	<1
WS- 004932	3/22/2021	3/22/2022	3	Cooler	In hallway adjacent to room 307	Low Right	WF-03222021-004932	3/24/2022	FT-FY22-02212022-004932-A	<1	FT-FY22-02212022-004932-B	<1
WS- 004950	3/22/2021	3/22/2022	2	Cooler	In hallway adjacent to room 209A (bottle filler)	High Left	WF-03222021-004950	3/24/2022	FT-FY22-02212022-004950-A	<1	FT-FY22-02212022-004950-B	<1
WS- 004952	3/22/2021	3/22/2022	2	Cooler	In hallway adjacent to room 209A	Low Right	WF-03222021-004952	3/24/2022	FT-FY22-02212022-004952-A	<1	FT-FY22-02212022-004952-B	<1
WS- 004954	3/22/2021	3/22/2022	2	Cooler	In lobby across from room 242	High Left	WF-03222021-004954	3/24/2022	FT-FY22-02212022-004954-A	<1	FT-FY22-02212022-004954-B	<1
WS- 004955	3/22/2021	3/22/2022	2	Cooler	In lobby across from room 242	Low Right	WF-03222021-004955	3/24/2022	FT-FY22-02212022-004955-A	<1	FT-FY22-02212022-004955-B	<1
WS- 004981	3/22/2021	3/22/2022	2	Cooler	In hallway across from room 230	High Left	WF-03222021-004981	3/24/2022	FT-FY22-02212022-004981-A	<1	FT-FY22-02212022-004981-B	<1
WS- 004982	3/22/2021	3/22/2022	2	Cooler	In hallway across from room 230	Low Right	WF-03222021-004982	3/24/2022	FT-FY22-02212022-004982-A	<1	FT-FY22-02212022-004982-B	<1
WS- 004988	3/22/2021	3/22/2022	1	Break Room	In work room 104		WF-03222021-004988	3/24/2022	FT-FY22-02212022-004988-A	<1	FT-FY22-02212022-004988-B	<1
WS- 004989	3/22/2021	3/22/2022	1	Break Room	In work room 105		WF-03222021-004989	3/24/2022	FT-FY22-02212022-004989-A	<1	FT-FY22-02212022-004989-B	<1
WS- 004990	3/22/2021	3/22/2022	1	Health Suite	In health suite in exam room W106		WF-03222021-004990	3/24/2022	FT-FY22-02212022-004990-A	<1	FT-FY22-02212022-004990-B	<1
WS- 004991	3/22/2021	3/22/2022	1	Health Suite	In health suite in exam room W104		WF-03222021-004991	3/24/2022	FT-FY22-02212022-004991-A	<1	FT-FY22-02212022-004991-B	<1
WS- 004992	3/22/2021	3/22/2022	1	Health Suite	In health suite in dental exam room W111		WF-03222021-004992	3/24/2022	FT-FY22-02212022-004992-A	<1	FT-FY22-02212022-004992-B	<1
WS- 004993	3/22/2021	3/22/2022	1	Health Suite	In health suite in exam room W112		WF-03222021-004993	3/24/2022	FT-FY22-02212022-004993-A	<1	FT-FY22-02212022-004993-B	<1
WS- 004994	3/22/2021	3/22/2022	1	Health Suite	In health suite in exam room W113		WF-03222021-004994	3/24/2022	FT-FY22-02212022-004994-A	<1	FT-FY22-02212022-004994-B	<1
WS- 004996	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 101	High Left	WF-03222021-004996	3/24/2022	FT-FY22-02212022-004996-A	<1	FT-FY22-02212022-004996-B	<1
WS- 004997	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 101	Low Right	WF-03222021-004997	3/24/2022	FT-FY22-02212022-004997-A	<1	FT-FY22-02212022-004997-B	<1
WS- 004998	3/22/2021	3/22/2022	1	Bottle Filler	In cafeteria (bottle filler)		WF-03222021-004998	3/24/2022	FT-FY22-02212022-004998-A	<1	FT-FY22-02212022-004998-B	<1
WS- 005000	3/22/2021	3/22/2022	1	Cooler	In cafeteria	High Left	WF-03222021-005000	3/24/2022	FT-FY22-02212022-005000-A	<1	FT-FY22-02212022-005000-B	<1
WS- 005001	3/22/2021	3/22/2022	1	Cooler	In cafeteria	Low Right	WF-03222021-005001	3/24/2022	FT-FY22-02212022-005001-A	<1	FT-FY22-02212022-005001-B	<1

WS- 005003	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 153	High Left	WF-03222021-005003	3/24/2022	FT-FY22-02212022-005003-A	<1	FT-FY22-02212022-005003-B	<1
WS- 005004	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to room 153	Low Right	WF-03222021-005004	3/24/2022	FT-FY22-02212022-005004-A	<1	FT-FY22-02212022-005004-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005006	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen west wall	WF-02092022-005006	3/24/2022	FT-FY22-02212022-005006-A	<1	FT-FY22-02212022-005006-B	<1	

### FY22 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002539	9/27/2021	9/27/2022	1	Classroom Faucet	In day care room 175	WF-09272021-002539	3/24/2022	FT-FY22-02212022-002539-A	21.4	FT-FY22-02212022-002539-B	5.6	

### First Re-test (After Plumbing Check)

#### FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002539	4/6/2022	4/6/2023	1	Classroom Faucet	In day care room 175	WF-04062022-002539	4/12/2022	FT-FY22-04062022-002539-A	<1	FT-FY22-04062022-002539-B	<1	