



# WOODSON LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	WOODSON HIGH SCHOOL	5/18/2016	WS-004891	Utility	Basement	In mechanical room 002	WT-042916-4908- A	15.2	WT-042916-4908- B	< 1	Non-drinking water source - Not accessible to children (boilers)			
2	WOODSON HIGH SCHOOL	5/18/2016	WS-004892	Cooler	Basement	In hallway adjacent to room 002 Left High	WT-042916-4909- A	< 1	WT-042916-4909- B	< 1				
3	WOODSON HIGH SCHOOL	5/18/2016	WS-004893	Cooler	Basement	In hallway adjacent to room 002 Right Low	WT-042916-4910- A	< 1	WT-042916-4910- B	< 1				
4	WOODSON HIGH SCHOOL	5/18/2016	WS-004894	Other	Basement	In room 005 (ice maker)	WT-042916-4911- A	< 1	WT-042916-4911- B	< 1				
5	WOODSON HIGH SCHOOL	5/18/2016	WS-004895	Classroom	Basement	In room 005	WT-042916-4912- A	< 1	WT-042916-4912- B	< 1				
6	WOODSON HIGH SCHOOL	5/18/2016	WS-004896	Cooler	Basement	In hallway adjacent to women's rest room. Left High	WT-042916-4913- A	< 1	WT-042916-4913- B	< 1				
7	WOODSON HIGH SCHOOL	5/18/2016	WS-004897	Cooler	Basement	In hallway adjacent to women's rest room Right Low	WT-042916-4914- A	< 1	WT-042916-4914- B	< 1				
8	WOODSON HIGH SCHOOL	5/18/2016	WS-004898	Classroom	Basement	In room 014	WT-042916-4915- A	< 1	WT-042916-4915- B	< 1				
9	WOODSON HIGH SCHOOL	5/18/2016	WS-004899	Classroom	Basement	In room 014 (ice maker)	WT-042916-4916- A	< 1	WT-042916-4916- B	< 1				
10	WOODSON HIGH SCHOOL	5/18/2016	WS-004900	Cooler	Basement	In room 015 Left	WT-042916-4917- A	< 1	WT-042916-4917- B	< 1				
11	WOODSON HIGH SCHOOL	5/18/2016	WS-004901	Cooler	Basement	In room 015 Mid High	WT-042916-4918- A	< 1	WT-042916-4918- B	< 1				
12	WOODSON HIGH SCHOOL	5/18/2016	WS-004902	Cooler	Basement	In room 015 Right Low	WT-042916-4919- A	< 1	WT-042916-4919- B	< 1				
13	WOODSON HIGH SCHOOL	5/18/2016	WS-004903	Classroom	Basement	In room 016 Left	WT-042916-4920- A	< 1	WT-042916-4920- B	< 1				
14	WOODSON HIGH SCHOOL	5/18/2016	WS-004904	Cooler	Basement	In room 016 Mid High	WT-042916-4921- A	< 1	WT-042916-4921- B	< 1				
15	WOODSON HIGH SCHOOL	5/18/2016	WS-004905	Cooler	Basement	In room 016 Right Low	WT-042916-4922- A	< 1	WT-042916-4922- B	< 1				
16	WOODSON HIGH SCHOOL	5/18/2016	WS-004906	Cooler	Basement	In the gymnasium 012 Left	WT-042916-4923- A	< 1	WT-042916-4923- B	< 1				
17	WOODSON HIGH SCHOOL	5/18/2016	WS-004907	Cooler	Basement	In the gymnasium 012 Mid High	WT-042916-4924- A	< 1	WT-042916-4924- B	< 1				
18	WOODSON HIGH SCHOOL	5/18/2016	WS-004908	Cooler	Basement	In the gymnasium 012 Right Low	WT-042916-4925- A	< 1	WT-042916-4925- B	< 1				
19	WOODSON HIGH SCHOOL	5/18/2016	WS-004909	Cooler	Basement	In basketball court Left High	WT-042916-4926- A	< 1	WT-042916-4926- B	< 1				
20	WOODSON HIGH SCHOOL	5/18/2016	WS-004910	Cooler	Basement	In basketball court Right Low	WT-042916-4927- A	< 1	WT-042916-4927- B	< 1				
21	WOODSON HIGH SCHOOL	5/18/2016	WS-004911	Cooler	Basement	In pool area Left High	WT-042916-4928- A	< 1	WT-042916-4928- B	< 1				
22	WOODSON HIGH SCHOOL	5/18/2016	WS-004912	Cooler	Basement	In pool area Mid High	WT-042916-4929- A	< 1	WT-042916-4929- B	< 1				
23	WOODSON HIGH SCHOOL	5/18/2016	WS-004913	Cooler	Basement	In pool area Right Low	WT-042916-4930- A	< 1	WT-042916-4930- B	< 1				
24	WOODSON HIGH SCHOOL	5/18/2016	WS-004914	Cooler	3	In lobby adjacent to 333	WT-042916-4931- A	< 1	WT-042916-4931- B	< 1				
25	WOODSON HIGH SCHOOL	5/18/2016	WS-004915	Cooler	3	In lobby adjacent to 342	WT-042916-4932- A	< 1	WT-042916-4932- B	< 1				
26	WOODSON HIGH SCHOOL	5/18/2016	WS-004916	Classroom	3	In room 342 adjacent to room 343	WT-042916-4933- A	< 1	WT-042916-4933- B	< 1				
27	WOODSON HIGH SCHOOL	5/18/2016	WS-004917	Classroom	3	In classroom 342 table 1 Right	WT-042916-4934- A	5.8	WT-042916-4934- B	< 1				
28	WOODSON HIGH SCHOOL	5/18/2016	WS-004918	Classroom	3	In classroom 342 table 1 Left	WT-042916-4935- A	5.9	WT-042916-4935- B	< 1				
29	WOODSON HIGH SCHOOL	5/18/2016	WS-004919	Classroom	3	In classroom 342 table 2 Left	WT-042916-4936- A	3.4	WT-042916-4936- B	< 1				
30	WOODSON HIGH SCHOOL	5/18/2016	WS-004920	Classroom	3	In classroom 342 table 2 Right	WT-042916-4937- A	12.1	WT-042916-4937- B	1.2				
31	WOODSON HIGH SCHOOL	5/18/2016	WS-004921	Classroom	3	In classroom 342 table 5 Right	WT-042916-4938- A	9.8	WT-042916-4938- B	< 1				
32	WOODSON HIGH SCHOOL	5/18/2016	WS-004922	Classroom	3	In classroom 342 table 5 Left	WT-042916-4939- A	6.4	WT-042916-4939- B	< 1				
33	WOODSON HIGH SCHOOL	5/18/2016	WS-004923	Classroom	3	In classroom 342 table 3 Right	WT-042916-4940- A	7.1	WT-042916-4940- B	< 1				
34	WOODSON HIGH SCHOOL	5/18/2016	WS-004924	Classroom	3	In classroom 342 table 3 Left	WT-042916-4941- A	9.6	WT-042916-4941- B	4.4				
35	WOODSON HIGH SCHOOL	5/18/2016	WS-004925	Classroom	3	In classroom 342 table 6 Right	WT-042916-4942- A	2.5	WT-042916-4942- B	< 1				
36	WOODSON HIGH SCHOOL	5/18/2016	WS-004926	Classroom	3	In classroom 342 table 6 Left	WT-042916-4943- A	2.3	WT-042916-4943- B	< 1				
37	WOODSON HIGH SCHOOL	5/18/2016	WS-004927	Classroom	3	In classroom 342 table 4 Left	WT-042916-4944- A	8.1	WT-042916-4944- B	< 1				
38	WOODSON HIGH SCHOOL	5/18/2016	WS-004928	Classroom	3	In classroom 342 table 4 Right	WT-042916-4945- A	9.7	WT-042916-4945- B	< 1				
39	WOODSON HIGH SCHOOL	5/18/2016	WS-004929	Cooler	3	In hallway adjacent to 315 Left High	WT-042916-4946- A	< 1	WT-042916-4946- B	1.1				
40	WOODSON HIGH SCHOOL	5/18/2016	WS-004930	Cooler	3	In hallway adjacent to 315 Right Low	WT-042916-4947- A	< 1	WT-042916-4947- B	< 1				
41	WOODSON HIGH SCHOOL	5/18/2016	WS-004931	Cooler	3	In hallway adjacent to 307 Left High	WT-042916-4948- A	< 1	WT-042916-4948- B	< 1				
42	WOODSON HIGH SCHOOL	5/18/2016	WS-004932	Cooler	3	In hallway adjacent to 307 Right Low	WT-042916-4949- A	< 1	WT-042916-4949- B	< 1				
43	WOODSON HIGH SCHOOL	5/18/2016	WS-004933	Classroom	3	In classroom 315 table 1 Right	WT-042916-4950- A	11.5	WT-042916-4950- B	< 1				
44	WOODSON HIGH SCHOOL	5/18/2016	WS-004934	Classroom	3	In classroom 315 table 1 Left	WT-042916-4951- A	11.8	WT-042916-4951- B	< 1				
45	WOODSON HIGH SCHOOL	5/18/2016	WS-004935	Classroom	3	In classroom 315 table 2 Left	WT-042916-4952- A	8.5	WT-042916-4952- B	< 1				
46	WOODSON HIGH SCHOOL	5/18/2016	WS-004936	Classroom	3	In classroom 315 table 2 Right	WT-042916-4953- A	6.5	WT-042916-4953- B	< 1				
47	WOODSON HIGH SCHOOL	5/18/2016	WS-004937	Classroom	3	In classroom 315 table 3 Right	WT-042916-4954- A	10	WT-042916-4954- B	< 1				
48	WOODSON HIGH SCHOOL	5/18/2016	WS-004938	Classroom	3	In classroom 315 table 3 Left	WT-042916-4955- A	4.9	WT-042916-4955- B	< 1				
49	WOODSON HIGH SCHOOL	5/18/2016	WS-004939	Classroom	3	In classroom 315 table 4 Left	WT-042916-4956- A	2.5	WT-042916-4956- B	< 1				
50	WOODSON HIGH SCHOOL	5/18/2016	WS-004940	Classroom	3	In classroom 315 table 4 Right	WT-042916-4957- A	16.4	WT-042916-4957- B	< 1	Filter will be installed and then retested			
51	WOODSON HIGH SCHOOL	5/18/2016	WS-004941	Classroom	3	In classroom 315 table 5 Left	WT-042916-4958- A	3.2	WT-042916-4958- B	2.6				



# WOODSON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
52	WOODSON HIGH SCHOOL	5/18/2016	WS-004942	Classroom	3	in classroom 315 table 5	Right	WT-042916-4959- A	2.3	WT-042916-4959- B	< 1			
53	WOODSON HIGH SCHOOL	5/18/2016	WS-004943	Classroom	3	in classroom 315 table 6	Right	WT-042916-4960- A	2.6	WT-042916-4960- B	< 1			
54	WOODSON HIGH SCHOOL	5/18/2016	WS-004944	Classroom	3	in classroom 315 table 6	Left	WT-042916-4961- A	< 1	WT-042916-4961- B	< 1			
55	WOODSON HIGH SCHOOL	5/18/2016	WS-004945	Classroom	3	in room 316A		WT-042916-4962- A	1.2	WT-042916-4962- B	< 1			
56	WOODSON HIGH SCHOOL	5/18/2016	WS-004946	Classroom	3	in classroom 307	Left	WT-042916-4963- A	3.7	WT-042916-4963- B	< 1			
57	WOODSON HIGH SCHOOL	5/18/2016	WS-004947	Classroom	3	in classroom 307	Right	WT-042916-4964- A	4.3	WT-042916-4964- B	< 1			
58	WOODSON HIGH SCHOOL	5/18/2016	WS-004948	Classroom	2	in classroom 207	Right	WT-042916-4965- A	1.4	WT-042916-4965- B	< 1			
59	WOODSON HIGH SCHOOL	5/18/2016	WS-004949	Classroom	3	in classroom 207	Right	WT-042916-4966- A	< 1	WT-042916-4966- B	< 1			
60	WOODSON HIGH SCHOOL	5/18/2016	WS-004950	Cooler	2	in hallway adjacent to 209A	Mid High	WT-042916-4967- A	< 1	WT-042916-4967- B	< 1			
61	WOODSON HIGH SCHOOL	5/18/2016	WS-004951	Cooler	2	in hallway adjacent to 209A	Left High	WT-042916-4968- A	< 1	WT-042916-4968- B	1.3			
62	WOODSON HIGH SCHOOL	5/18/2016	WS-004952	Cooler	2	in hallway adjacent to 209A	Right Low	WT-042916-4969- A	< 1	WT-042916-4969- B	< 1			
63	WOODSON HIGH SCHOOL	5/18/2016	WS-004953	Cooler	2	in lobby across from 242	Left High	WT-042916-4970- A	< 1	WT-042916-4970- B	< 1			
64	WOODSON HIGH SCHOOL	5/18/2016	WS-004954	Cooler	2	in lobby across from 242	Mid High	WT-042916-4971- A	< 1	WT-042916-4971- B	< 1			
65	WOODSON HIGH SCHOOL	5/18/2016	WS-004955	Cooler	2	in lobby across from 242	Right Low	WT-042916-4972- A	< 1	WT-042916-4972- B	< 1			
66	WOODSON HIGH SCHOOL	5/18/2016	WS-004956	Classroom	2	in classroom 239 table 1	Left	WT-042916-4973- A	17.1	WT-042916-4973- B	4.7	Filter will be installed and then retested		
67	WOODSON HIGH SCHOOL	5/18/2016	WS-004957	Classroom	2	in classroom 239 table 1	Right	WT-042916-4974- A	47.1	WT-042916-4974- B	< 1	Filter will be installed and then retested		
68	WOODSON HIGH SCHOOL	5/18/2016	WS-004958	Classroom	2	in classroom 239 table 2	Left	WT-042916-4975- A	1.4	WT-042916-4975- B	< 1			
69	WOODSON HIGH SCHOOL	5/18/2016	WS-004959	Classroom	2	in classroom 239 table 2	Right	WT-042916-4976- A	3.3	WT-042916-4976- B	< 1			
70	WOODSON HIGH SCHOOL	5/18/2016	WS-004960	Classroom	2	in classroom 239 table 6	Left	WT-042916-4977- A	1.6	WT-042916-4977- B	< 1			
71	WOODSON HIGH SCHOOL	5/18/2016	WS-004961	Classroom	2	in classroom 239 table 3	Right	WT-042916-4978- A	1.4	WT-042916-4978- B	< 1			
72	WOODSON HIGH SCHOOL	5/18/2016	WS-004962	Classroom	2	in classroom 239 table 4	Left	WT-042916-4979- A	< 1	WT-042916-4979- B	< 1			
73	WOODSON HIGH SCHOOL	5/18/2016	WS-004963	Classroom	2	in classroom 239 table 4	Right	WT-042916-4980- A	< 1	WT-042916-4980- B	< 1			
74	WOODSON HIGH SCHOOL	5/18/2016	WS-004964	Classroom	2	in classroom 239 table 5	Left	WT-042916-4981- A	1	WT-042916-4981- B	< 1			
75	WOODSON HIGH SCHOOL	5/18/2016	WS-004965	Classroom	2	in classroom 239 table 5	Right	WT-042916-4982- A	1.1	WT-042916-4982- B	< 1			
76	WOODSON HIGH SCHOOL	5/18/2016	WS-004966	Classroom	2	in classroom 239 table 6	Right	WT-042916-4983- A	1.5	WT-042916-4983- B	< 1			
77	WOODSON HIGH SCHOOL	5/18/2016	WS-004967	Classroom	2	in classroom 239 table 3	Left	WT-042916-4984- A	2.1	WT-042916-4984- B	1.6			
78	WOODSON HIGH SCHOOL	5/18/2016	WS-004968	Classroom	2	in room 236		WT-042916-4985- A	< 1	WT-042916-4985- B	< 1			
79	WOODSON HIGH SCHOOL	5/18/2016	WS-004969	Classroom	2	in classroom 235 table 1	Left	WT-042916-4986- A	< 1	WT-042916-4986- B	< 1			
80	WOODSON HIGH SCHOOL	5/18/2016	WS-004970	Classroom	2	in classroom 235 table 1	Right	WT-042916-4987- A	< 1	WT-042916-4987- B	< 1			
81	WOODSON HIGH SCHOOL	5/18/2016	WS-004971	Classroom	2	in classroom 235 table 2	Left	WT-042916-4988- A	< 1	WT-042916-4988- B	< 1			
82	WOODSON HIGH SCHOOL	5/18/2016	WS-004972	Classroom	2	in classroom 235 table 2	Right	WT-042916-4989- A	1.1	WT-042916-4989- B	< 1			
83	WOODSON HIGH SCHOOL	5/18/2016	WS-004973	Classroom	2	in classroom 235 table 3	Left	WT-042916-4990- A	1.7	WT-042916-4990- B	< 1			
84	WOODSON HIGH SCHOOL	5/18/2016	WS-004974	Classroom	2	in classroom 235 table 3	Right	WT-042916-4991- A	1.5	WT-042916-4991- B	< 1			
85	WOODSON HIGH SCHOOL	5/18/2016	WS-004975	Classroom	2	in classroom 235 table 4	Left	WT-042916-4992- A	< 1	WT-042916-4992- B	< 1			
86	WOODSON HIGH SCHOOL	5/18/2016	WS-004976	Classroom	2	in classroom 235 table 4	Right	WT-042916-4993- A	16.1	WT-042916-4993- B	1	Filter will be installed and then retested		
87	WOODSON HIGH SCHOOL	5/18/2016	WS-004977	Classroom	2	in classroom 235 table 5	Left	WT-042916-4994- A	1	WT-042916-4994- B	< 1			
88	WOODSON HIGH SCHOOL	5/18/2016	WS-004978	Classroom	2	in classroom 235 table 5	Right	WT-042916-4995- A	< 1	WT-042916-4995- B	< 1			
89	WOODSON HIGH SCHOOL	5/18/2016	WS-004979	Classroom	2	in classroom 235 table 6	Right	WT-042916-4996- A	22.7	WT-042916-4996- B	< 1	Filter will be installed and then retested		
90	WOODSON HIGH SCHOOL	5/18/2016	WS-004980	Classroom	2	in classroom 235 table 6	Left	WT-042916-4997- A	11.5	WT-042916-4997- B	< 1			
91	WOODSON HIGH SCHOOL	5/18/2016	WS-004981	Cooler	2	in hallway across from 230	Left High	WT-042916-4998- A	< 1	WT-042916-4998- B	< 1			
92	WOODSON HIGH SCHOOL	5/18/2016	WS-004982	Cooler	2	in lobby across from 232	Right Low	WT-042916-4999- A	< 1	WT-042916-4999- B	< 1			
93	WOODSON HIGH SCHOOL	5/18/2016	WS-004983	Classroom	2	in classroom 217 art room	Left	WT-042916-5000- A	< 1	WT-042916-5000- B	< 1			
94	WOODSON HIGH SCHOOL	5/18/2016	WS-004984	Classroom	2	in classroom 217 art room	Right	WT-042916-5001- A	< 1	WT-042916-5001- B	< 1			
95	WOODSON HIGH SCHOOL	5/18/2016	WS-004985	Cooler	2	in hallway adjacent to room 222	Left High	WT-042916-5002- A	< 1	WT-042916-5002- B	< 1			
96	WOODSON HIGH SCHOOL	5/18/2016	WS-004986	Cooler	2	in hallway adjacent to room 222	Mid	WT-042916-5003- A	< 1	WT-042916-5003- B	< 1			
97	WOODSON HIGH SCHOOL	5/18/2016	WS-004987	Classroom	2	in hallway adjacent to room 222	Right Low	WT-042916-5004- A	< 1	WT-042916-5004- B	< 1			
98	WOODSON HIGH SCHOOL	5/18/2016	WS-004988	Classroom	1	in room 104		WT-042916-5005- A	< 1	WT-042916-5005- B	< 1			
99	WOODSON HIGH SCHOOL	5/18/2016	WS-004989	Classroom	1	in room 105		WT-042916-5006- A	< 1	WT-042916-5006- B	< 1			
100	WOODSON HIGH SCHOOL	5/18/2016	WS-004990	Health Suite	1	in room W106		WT-042916-5007- A	< 1	WT-042916-5007- B	< 1			
101	WOODSON HIGH SCHOOL	5/18/2016	WS-004991	Health Suite	1	in room W104		WT-042916-5008- A	< 1	WT-042916-5008- B	< 1			



# WOODSON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
102 WOODSON HIGH SCHOOL	5/18/2016	WS- 004992	Health Suite	1	in dental exam room W111	WT-042916-5009- A	2.1	WT-042916-5009- B	< 1				
103 WOODSON HIGH SCHOOL	5/18/2016	WS- 004993	Health Suite	1	in room W112	WT-042916-5010- A	< 1	WT-042916-5010- B	< 1				
104 WOODSON HIGH SCHOOL	5/18/2016	WS- 004994	Health Suite	1	in room W113	WT-042916-5011- A	1.2	WT-042916-5011- B	< 1				
105 WOODSON HIGH SCHOOL	5/18/2016	WS- 004995	Cooler	1	in hallway adjacent to room 101 Left High	WT-042916-5012- A	< 1	WT-042916-5012- B	< 1				
106 WOODSON HIGH SCHOOL	5/18/2016	WS- 004996	Cooler	1	in hallway adjacent to room 101 Mid High	WT-042916-5013- A	< 1	WT-042916-5013- B	< 1				
107 WOODSON HIGH SCHOOL	5/18/2016	WS- 004997	Cooler	1	in hallway adjacent to room 101 Right Low	WT-042916-5014- A	< 1	WT-042916-5014- B	< 1				
108 WOODSON HIGH SCHOOL	5/18/2016	WS- 004998	Cooler	1	in cafeteria Left High	WT-042916-5015- A	< 1	WT-042916-5015- B	< 1				
109 WOODSON HIGH SCHOOL	5/18/2016	WS- 005000	Cooler	1	in cafeteria Mid High	WT-042916-5017- A	< 1	WT-042916-5017- B	< 1				
110 WOODSON HIGH SCHOOL	5/18/2016	WS- 005001	Cooler	1	in cafeteria Right Low	WT-042916-5018- A	< 1	WT-042916-5018- B	< 1				
111 WOODSON HIGH SCHOOL	5/18/2016	WS- 005002	Cooler	1	in hallway adjacent to 153 Left High	WT-042916-5019- A	< 1	WT-042916-5019- B	< 1				
112 WOODSON HIGH SCHOOL	5/18/2016	WS- 005003	Cooler	1	in hallway adjacent to 153 Mid High	WT-042916-5020- A	< 1	WT-042916-5020- B	< 1				
113 WOODSON HIGH SCHOOL	5/18/2016	WS- 005004	Cooler	1	in hallway adjacent to 153 Right Low	WT-042916-5021- A	< 1	WT-042916-5021- B	< 1				
114 WOODSON HIGH SCHOOL	5/18/2016	WS- 005005	Kitchen	1	in room 142A (shower head)	WT-042916-5022- A	2.7	WT-042916-5022- B	1.2				
115 WOODSON HIGH SCHOOL	5/18/2016	WS- 005006	Kitchen	1	in kitchen west wall	WT-042916-5023- A	< 1	WT-042916-5023- B	< 1				
116 WOODSON HIGH SCHOOL	5/18/2016	WS- 005007	Kitchen	1	in kitchen north wall Left	WT-042916-5024- A	< 1	WT-042916-5024- B	< 1				
117 WOODSON HIGH SCHOOL	5/18/2016	WS- 005008	Kitchen	1	in kitchen north wall Mid	WT-042916-5025- A	< 1	WT-042916-5025- B	< 1				
118 WOODSON HIGH SCHOOL	5/18/2016	WS- 005009	Kitchen	1	in kitchen north wall (shower head) Right	WT-042916-5026- A	< 1	WT-042916-5026- B	< 1				
119 WOODSON HIGH SCHOOL	5/18/2016	WS- 005010	Kitchen	1	in kitchen (ice maker)	WT-042916-5027- A	< 1	WT-042916-5027- B	< 1				
120 WOODSON HIGH SCHOOL	5/18/2016	WS- 005011	Cooler	Basement	in hallway adjacent mechanical room 002 Left High	WT-042916-5028- A	< 1	WT-042916-5028- B	< 1				
121 WOODSON HIGH SCHOOL	5/18/2016	WS- 005012	Cooler	Basement	in hallway adjacent women's restroom Left High	WT-042916-5029- A	< 1	WT-042916-5029- B	< 1				
122 WOODSON HIGH SCHOOL	5/18/2016	WS- 005013	Cooler	3	in hallway adjacent to room 315 Left High	WT-042916-5030- A	< 1	WT-042916-5030- B	< 1				
123 WOODSON HIGH SCHOOL	5/18/2016	WS- 005014	Cooler	3	in hallway adjacent to room 307 Left High	WT-042916-5031- A	< 1	WT-042916-5031- B	< 1				
124 WOODSON HIGH SCHOOL	5/18/2016	WS- 005015	Classroom	3	in room 324 adjacent storage room 332	WT-042916-5032- A	31.7	WT-042916-5032- B	1.5	Filter will be installed and then retested			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.