



Woodson HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002538	10/24/2018	10/24/2019	1	Classroom Faucet	In day care room 174	WF-10242018-002538	1/11/2019	FT-FY19-012019-002538-A	<1	FT-FY19-012019-002538-B	<1	
WS- 002539	10/24/2018	10/24/2019	1	Classroom Faucet	In day care room 175	WF-10242018-002539	1/11/2019	FT-FY19-012019-002539-A	<1	FT-FY19-012019-002539-B	<1	
WS- 004892	4/16/2018	4/16/2019	Basement	Cooler	In hallway adjacent to room 002	High Left	WF-04162018-004892	1/11/2019	FT-FY19-012019-004892-A	<1	FT-FY19-012019-004892-B	<1
WS- 004893	4/16/2018	4/16/2019	Basement	Cooler	In hallway adjacent to room 002	Low Right	WF-04162018-004893	1/11/2019	FT-FY19-012019-004893-A	<1	FT-FY19-012019-004893-B	<1
WS- 004896	4/16/2018	4/16/2019	Basement	Cooler	In hallway adjacent to girls' restroom	High Left	WF-04162018-004896	1/11/2019	FT-FY19-012019-004896-A	<1	FT-FY19-012019-004896-B	<1
WS- 004897	4/16/2018	4/16/2019	Basement	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04162018-004897	1/11/2019	FT-FY19-012019-004897-A	<1	FT-FY19-012019-004897-B	<1
WS- 004900	4/16/2018	4/16/2019	Basement	Bottle Filler	In classroom 015 (bottle filler)		WF-04162018-004900	1/11/2019	FT-FY19-012019-004900-A	<1	FT-FY19-012019-004900-B	<1
WS- 004901	4/16/2018	4/16/2019	Basement	Cooler	In classroom 015	High Left	WF-04162018-004901	1/11/2019	FT-FY19-012019-004901-A	<1	FT-FY19-012019-004901-B	<1
WS- 004902	4/16/2018	4/16/2019	Basement	Cooler	In classroom 015	Low Right	WF-04162018-004902	1/11/2019	FT-FY19-012019-004902-A	<1	FT-FY19-012019-004902-B	<1
WS- 004903	4/16/2018	4/16/2019	Basement	Bottle Filler	In classroom 016 (bottle filler)		WF-04162018-004903	1/11/2019	FT-FY19-012019-004903-A	<1	FT-FY19-012019-004903-B	<1
WS- 004904	4/16/2018	4/16/2019	Basement	Cooler	In classroom 016	High Left	WF-04162018-004904	1/11/2019	FT-FY19-012019-004904-A	<1	FT-FY19-012019-004904-B	<1
WS- 004905	4/16/2018	4/16/2019	Basement	Cooler	In classroom 016	Low Right	WF-04162018-004905	1/11/2019	FT-FY19-012019-004905-A	<1	FT-FY19-012019-004905-B	<1
WS- 004906	4/16/2018	4/16/2019	Basement	Bottle Filler	In the gym 012 (bottle filler)		WF-04162018-004906	1/11/2019	FT-FY19-012019-004906-A	<1	FT-FY19-012019-004906-B	<1
WS- 004907	4/16/2018	4/16/2019	Basement	Cooler	In the gym 012	High Left	WF-04162018-004907	1/11/2019	FT-FY19-012019-004907-A	<1	FT-FY19-012019-004907-B	<1
WS- 004908	4/16/2018	4/16/2019	Basement	Cooler	In the gym 012	Low Right	WF-04162018-004908	1/11/2019	FT-FY19-012019-004908-A	<1	FT-FY19-012019-004908-B	<1
WS- 004911	4/16/2018	4/16/2019	Basement	Bottle Filler	In pool area (bottle filler)		WF-04162018-004911	1/11/2019	FT-FY19-012019-004911-A	<1	FT-FY19-012019-004911-B	<1
WS- 004912	4/16/2018	4/16/2019	Basement	Cooler	In pool area	High Left	WF-04162018-004912	1/11/2019	FT-FY19-012019-004912-A	<1	FT-FY19-012019-004912-B	<1
WS- 004913	4/16/2018	4/16/2019	Basement	Cooler	In pool area	Low Right	WF-04162018-004913	1/11/2019	FT-FY19-012019-004913-A	<1	FT-FY19-012019-004913-B	<1
WS- 004914	4/16/2018	4/16/2019	3	Cooler	In lobby adjacent to room 333		WF-04162018-004914	1/11/2019	FT-FY19-012019-004914-A	<1	FT-FY19-012019-004914-B	<1
WS- 004915	4/16/2018	4/16/2019	3	Cooler	In lobby adjacent to room 342		WF-04162018-004915	1/11/2019	FT-FY19-012019-004915-A	<1	FT-FY19-012019-004915-B	<1
WS- 004929	4/16/2018	4/16/2019	3	Cooler	In hallway adjacent to room 315	High Left	WF-04162018-004929	1/11/2019	FT-FY19-012019-004929-A	<1	FT-FY19-012019-004929-B	<1
WS- 004930	4/16/2018	4/16/2019	3	Cooler	In hallway adjacent to room 315	Low Right	WF-04162018-004930	1/11/2019	FT-FY19-012019-004930-A	<1	FT-FY19-012019-004930-B	<1
WS- 004931	4/16/2018	4/16/2019	3	Cooler	In hallway adjacent to room 307	High Left	WF-04162018-004931	1/11/2019	FT-FY19-012019-004931-A	<1	FT-FY19-012019-004931-B	<1
WS- 004932	4/16/2018	4/16/2019	3	Cooler	In hallway adjacent to room 307	Low Right	WF-04162018-004932	1/11/2019	FT-FY19-012019-004932-A	<1	FT-FY19-012019-004932-B	<1
WS- 004950	4/16/2018	4/16/2019	2	Cooler	In hallway adjacent to room 209A (bottle filler)	High Left	WF-04162018-004950	1/11/2019	FT-FY19-012019-004950-A	<1	FT-FY19-012019-004950-B	<1
WS- 004952	4/16/2018	4/16/2019	2	Cooler	In hallway adjacent to room 209A	Low Right	WF-04162018-004952	1/11/2019	FT-FY19-012019-004952-A	<1	FT-FY19-012019-004952-B	<1
WS- 004988	4/16/2018	4/16/2019	1	Break Room	In work room 104		WF-04162018-004988	1/11/2019	FT-FY19-012019-004988-A	<1	FT-FY19-012019-004988-B	<1
WS- 004989	4/16/2018	4/16/2019	1	Break Room	In work room 105		WF-04162018-004989	1/11/2019	FT-FY19-012019-004989-A	<1	FT-FY19-012019-004989-B	<1
WS- 004990	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room W106		WF-04162018-004990	1/11/2019	FT-FY19-012019-004990-A	<1	FT-FY19-012019-004990-B	<1
WS- 004991	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room W104		WF-04162018-004991	1/11/2019	FT-FY19-012019-004991-A	<1	FT-FY19-012019-004991-B	<1
WS- 004992	4/16/2018	4/16/2019	1	Health Suite	In health suite in dental exam room W111		WF-04162018-004992	1/11/2019	FT-FY19-012019-004992-A	<1	FT-FY19-012019-004992-B	<1
WS- 004993	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room W112		WF-04162018-004993	1/11/2019	FT-FY19-012019-004993-A	<1	FT-FY19-012019-004993-B	<1
WS- 004994	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room W113		WF-04162018-004994	1/11/2019	FT-FY19-012019-004994-A	<1	FT-FY19-012019-004994-B	<1
WS- 004995	4/16/2018	4/16/2019	1	Bottle Filler	In hallway adjacent to room 101 (bottle filler)		WF-04162018-004995	1/11/2019	FT-FY19-012019-004995-A	<1	FT-FY19-012019-004995-B	<1
WS- 004996	4/16/2018	4/16/2019	1	Cooler	In hallway adjacent to room 101	High Left	WF-04162018-004996	1/11/2019	FT-FY19-012019-004996-A	<1	FT-FY19-012019-004996-B	<1
WS- 004997	4/16/2018	4/16/2019	1	Cooler	In hallway adjacent to room 101	Low Right	WF-04162018-004997	1/11/2019	FT-FY19-012019-004997-A	<1	FT-FY19-012019-004997-B	<1

WS- 004998	4/16/2018	4/16/2019	1	Bottle Filler	In cafeteria (bottle filler)		WF-04162018-004998	1/11/2019	FT-FY19-012019-004998-A	<1	FT-FY19-012019-004998-B	<1
WS- 005000	4/16/2018	4/16/2019	1	Cooler	In cafeteria	High Left	WF-04162018-005000	1/11/2019	FT-FY19-012019-005000-A	<1	FT-FY19-012019-005000-B	<1
WS- 005001	4/16/2018	4/16/2019	1	Cooler	In cafeteria	Low Right	WF-04162018-005001	1/11/2019	FT-FY19-012019-005001-A	<1	FT-FY19-012019-005001-B	<1
WS- 005003	4/16/2018	4/16/2019	1	Cooler	In hallway adjacent to room 153	High Left	WF-04162018-005003	1/11/2019	FT-FY19-012019-005003-A	<1	FT-FY19-012019-005003-B	<1
WS- 005004	4/16/2018	4/16/2019	1	Cooler	In hallway adjacent to room 153	Low Right	WF-04162018-005004	1/11/2019	FT-FY19-012019-005004-A	<1	FT-FY19-012019-005004-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005006	1	Food Prep Sink	In kitchen west wall	1/11/2019	FT-FY19-012019-005006-A	<1	FT-FY19-012019-005006-B	<1