



YOUTH REHAB LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	YOUTH REHABILITATION BUILDING	WS- 011473	8/8/2016	Basement	Cooler	In workshop room 0102	FT-72016-011473-A	< 1	FT-72016-011473-B	< 1
2	YOUTH REHABILITATION BUILDING	WS- 011514	8/8/2016	2	Cooler	In gym High Left	FT-72016-011514-A	< 1	FT-72016-011514-B	< 1
3	YOUTH REHABILITATION BUILDING	WS- 011515	8/8/2016	2	Cooler	In gym Low Right	FT-72016-011515-A	< 1	FT-72016-011515-B	< 1