



# Youth Rehabilitation Building Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011473	4/5/2024	4/5/2025	Basement	Cooler	In workshop room 0102	WF-04052024-011473	4/24/2024	FT-FY24-04082024-011473-A	<1	FT-FY24-04082024-011473-B	<1
WS- 011475	4/5/2024	4/5/2025	1	Cooler	In health suite High Left	WF-04052024-011475	4/24/2024	FT-FY24-04082024-011475-A	<1	FT-FY24-04082024-011475-B	<1
WS- 011476	4/5/2024	4/5/2025	1	Cooler	In health suite Low Right	WF-04052024-011476	4/24/2024	FT-FY24-04082024-011476-A	<1	FT-FY24-04082024-011476-B	<1
WS- 011477	4/5/2024	4/5/2025	1	Bottle Filler	In health suite	WF-04052024-011477	4/24/2024	FT-FY24-04082024-011477-A	<1	FT-FY24-04082024-011477-B	<1
WS- 011514	4/5/2024	4/5/2025	2	Cooler	In gym High Left	WF-04052024-011514	4/24/2024	FT-FY24-04082024-011514-A	<1	FT-FY24-04082024-011514-B	<1
WS- 011515	4/5/2024	4/5/2025	2	Cooler	In gym Low Right	WF-04052024-011515	4/24/2024	FT-FY24-04082024-011515-A	<1	FT-FY24-04082024-011515-B	<1